

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
A. G. Baillie Memorial School	Source-Municipal	MSG804	0.0017	Passed	0.0490	Passed	Remediation has been completed
A. G. Baillie Memorial School	Bottle Filler Gym Entrance	MSG805	0.0000	Passed	0.8700	Passed	Remediation has been completed
A. G. Baillie Memorial School	Bottle Filler 1st Floor North Wing	QMD461	0.0001	Passed	0.0006	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 124	MSG807	0.0022	Passed	0.2400	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 122	QMD464	0.0000	Passed	0.0010	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 130	MSG809	0.0000	Passed	0.0760	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 130 Laundry Sink	MSG810	0.0000	Passed	0.6400	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 133	MSG811	0.0008	Passed	0.0670	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 134, Sink A	MSG812	0.0021	Passed	0.0750	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 134, Sink B	MSG813	0.0025	Passed	0.0490	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 137	MSG814	0.0021	Passed	0.0670	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 155	MSG815	0.0000	Passed	0.5200	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 156	MSG816	0.0007	Passed	0.0039	Passed	Remediation has been completed
A. G. Baillie Memorial School	Principal's Office Sink	MSG817	0.0018	Passed	0.0910	Passed	Remediation has been completed
A. G. Baillie Memorial School	Cafeteria Kitchen Sink	MSG818	0.0026	Passed	0.0510	Passed	Remediation has been completed
A. G. Baillie Memorial School	Kitchen Handwashing Sink	MSG819	0.0009	Passed	0.0850	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 205	MSG820	0.0012	Passed	0.0770	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 207	NVS092	0.0014	Passed	0.2000	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 208	QMD463	0.0000	Passed	0.0004	Passed	Remediation has been completed
A. G. Baillie Memorial School	Room 209	MSG823	0.0023	Passed	0.0900	Passed	Remediation has been completed
A. G. Baillie Memorial School	Bottle Filler 2nd Floor Main Wing	QMD462	0.0016	Passed	0.0010	Passed	Remediation has been completed
A. G. Baillie Memorial School	Bottle Filler 2nd Floor North Wing	MSG825	0.0023	Passed	0.0079	Passed	Remediation has been completed
A. G. Baillie Memorial School	005 Room 124 Washroom	NFR465	0.0054	Passed	0.1700	Passed	Remediation has been completed
A. G. Baillie Memorial School	008 Room 130 Washroom	NFR466	0.0052	Passed	0.1300	Passed	Remediation has been completed
A. G. Baillie Memorial School	011 Room 133 Washroom	NFR467	0.0005	Passed	0.0420	Passed	Remediation has been completed
A. G. Baillie Memorial School	015 Room 137 Washroom	NFR468	0.0012	Passed	0.0400	Passed	Remediation has been completed
A. G. Baillie Memorial School	027 Main Level Staff Washroom A	NFR469	0.0023	Passed	0.1600	Passed	Remediation has been completed
A. G. Baillie Memorial School	028 Main Level Staff Washroom B	NFR470	0.0021	Passed	0.1900	Passed	Remediation has been completed
A. G. Baillie Memorial School	029 Gym Office Washroom	NFR471	0.0056	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	030 Gym Washroom Girls	NFR472	0.0031	Passed	0.0440	Passed	Remediation has been completed
A. G. Baillie Memorial School	031 Gym Washroom Boys	NFR473	0.0079	Exceeds Limit	0.0840	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	032 Bottom Floor Washroom Girls A	NFR474	0.0460	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	033 Bottom Floor Washroom Girls B	NFR475	0.0059	Exceeds Limit	0.0850	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	034 Bottom Floor Washroom Girls C	NFR476	0.0190	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	035 Bottom Floor Washroom Girls D	NFR477	0.0390	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	036 Bottom Floor Washroom Girls E	NFR478	0.0220	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	037 Bottom Floor Washroom Boys A	NFR479	0.0220	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	038 Bottom Floor Washroom Boys B	NFR480	0.0130	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	039 Bottom Floor Washroom Boys C	NFR481	0.0130	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	040 Bottom Floor Washroom Boys D	NFR482	0.0120	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	041 Main Floor Washroom Girls	NFR483	0.0006	Passed	0.0490	Passed	Remediation has been completed
A. G. Baillie Memorial School	042 Main Floor Washroom Boys	NFR484	0.0000	Passed	0.0250	Passed	Remediation has been completed
A. G. Baillie Memorial School	043 Bottom Floor Custodial Closet	NFR485	0.0130	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
A. G. Baillie Memorial School	044 Main Floor Custodial Closet	NFR486	0.0000	Passed	0.0110	Passed	Remediation has been completed
A. G. Baillie Memorial School	045 2nd Floor Custodial Closet	NFR487	0.0014	Passed	0.0430	Passed	Remediation has been completed
A. G. Baillie Memorial School	046 2nd Floor Washroom Girls A	NFR488	0.0008	Passed	0.0480	Passed	Remediation has been completed
A. G. Baillie Memorial School	047 2nd Floor Washroom Girls B	NFR489	0.0014	Passed	0.0450	Passed	Remediation has been completed
A. G. Baillie Memorial School	048 2nd Floor Washroom B	NFR490	0.0012	Passed	0.0590	Passed	Remediation has been completed
A. G. Baillie Memorial School	049 2nd Floor Washroom Boys B	NFR491	0.0012	Passed	0.0790	Passed	Remediation has been completed
Advocate District School	Tap #1	LDD605	0.0012	Passed	0.1600	Passed	Remediation has been completed
Advocate District School	Tap #2	LDD606	0.0025	Passed	0.1500	Passed	Remediation has been completed
Advocate District School	Tap #3	LDD607	0.0013	Passed	0.1600	Passed	Remediation has been completed
Advocate District School	Tap #4 - Removed	LDD608	0.0580	Exceeds Limit	0.7000	Passed	Remediation has been completed
Advocate District School	Tap #5	LDD609	0.0010	Passed	0.6700	Passed	Remediation has been completed
Advocate District School	Bottle Filler #1	LDD610	0.0020	Passed	0.1100	Passed	Remediation has been completed
Advocate District School	Bottle Filler #2	LDD611	0.0000	Passed	0.3600	Passed	Remediation has been completed
Advocate District School	Water Source	LDD612	0.0028	Passed	0.0250	Passed	Remediation has been completed
Advocate District School	Boiler Room	NDQ901	0.0000	Passed	0.0400	Passed	Remediation has been completed
Advocate District School	Boys Locker Room	NDQ902	0.0008	Passed	0.0850	Passed	Remediation has been completed
Advocate District School	Girls Locker Room	NDQ903	0.0007	Passed	0.1100	Passed	Remediation has been completed
Advocate District School	Main Office Washroom	NDQ904	0.0007	Passed	0.0600	Passed	Remediation has been completed
Advocate District School	Staff #1	NDQ905	0.0000	Passed	0.0700	Passed	Remediation has been completed
Advocate District School	Staff #2	NDQ906	0.0000	Passed	0.4900	Passed	Remediation has been completed
Advocate District School	Boys #1	NDQ907	0.0011	Passed	0.0730	Passed	Remediation has been completed
Advocate District School	Boys #2	NDQ908	0.0018	Passed	0.0700	Passed	Remediation has been completed
Advocate District School	Boys #3	NDQ909	0.0011	Passed	0.0650	Passed	Remediation has been completed
Advocate District School	Boys #4	NDQ910	0.0000	Passed	0.0510	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Advocate District School	Custodial Closet	NDQ911	0.0000	Passed	0.0410	Passed	Remediation has been completed
Advocate District School	Girls #1	NDQ912	0.0008	Passed	0.0840	Passed	Remediation has been completed
Advocate District School	Girls #2	NDQ913	0.0000	Passed	0.0500	Passed	Remediation has been completed
Advocate District School	Girls #3	NDQ914	0.0000	Passed	0.0430	Passed	Remediation has been completed
Advocate District School	Girls #4	NDQ915	0.0000	Passed	0.0410	Passed	Remediation has been completed
Amherst Regional High School	Cafeteria #1 - Kitchen Faucet	MVN551	0.0009	Passed	0.0460	Passed	Remediation has been completed
Amherst Regional High School	Cafeteria #2 - Hand Wash Sink	PED150	0.0002	Passed	0.0150	Passed	Remediation has been completed
Amherst Regional High School	Room 140 - Classroom Kitchen Faucet	NIN077	0.0010	Passed	0.5200	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler by Locker Rooms	PED140	0.0016	Passed	0.0004	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler in Cafeteria	MVN555	0.0010	Passed	0.0770	Passed	Remediation has been completed
Amherst Regional High School	Room 130 - Classroom Kitchen Faucet	MVN556	0.0026	Passed	0.0440	Passed	Remediation has been completed
Amherst Regional High School	Room 143 - Classroom Kitchen Faucet	MVN557	0.0000	Passed	0.0370	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler by Bottle Filler by Music Room	PMY953	0.0000	Passed	0.1100	Passed	Remediation has been completed
Amherst Regional High School	Room 128 - Classroom Kitchen Faucet	MVN559	0.0029	Passed	0.0580	Passed	Remediation has been completed
Amherst Regional High School	Room 139 - Classroom Kitchen Faucet	PED139	0.0025	Passed	0.3000	Passed	Remediation has been completed
Amherst Regional High School	Guidance Office - Kitchen Faucet	MVN561	0.0000	Passed	0.0520	Passed	Remediation has been completed
Amherst Regional High School	Main Office Photo Room - Kitchen Faucet	MVN562	0.0000	Passed	0.0640	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler Replaced Bottle Filler by Main Office	PED143	0.0032	Passed	0.4400	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler Replaced Bottle Filler in Atrium	PMY954	0.0000	Passed	0.0004	Passed	Remediation has been completed
Amherst Regional High School	Library - Kitchen Faucet	MVN565	0.0009	Passed	0.0740	Passed	Remediation has been completed
Amherst Regional High School	Room 131 - Classroom Kitchen Faucet	PMY942	0.0000	Passed	0.4400	Passed	Remediation has been completed
Amherst Regional High School	Room 130 - Classroom Kitchen Faucet	NIN073	0.0006	Passed	0.4100	Passed	Remediation has been completed
Amherst Regional High School	Room 127 - Classroom Kitchen Faucet	PED148	0.0035	Passed	0.5900	Passed	Remediation has been completed
Amherst Regional High School	Room 125 - Classroom Kitchen Faucet	PYM939	0.0000	Passed	0.2700	Passed	Remediation has been completed
Amherst Regional High School	Room 123 #1 - Classroom Kitchen Faucet	MVN571	0.0019	Passed	0.9400	Passed	Remediation has been completed
Amherst Regional High School	Room 123 #2 - Classroom Kitchen Faucet	MVN572	0.0009	Passed	0.6700	Passed	Remediation has been completed
Amherst Regional High School	Room 123 #3 - Classroom Kitchen Faucet	MVN573	0.0026	Passed	0.6300	Passed	Remediation has been completed
Amherst Regional High School	Room 123 #4 - Classroom Kitchen Faucet	MVN574	0.0034	Passed	0.8500	Passed	Remediation has been completed
Amherst Regional High School	Room 123 #5 - Classroom Kitchen Faucet	MY939	0.0000	Passed	0.0270	Passed	Remediation has been completed
Amherst Regional High School	Room 121 - Classroom Kitchen Faucet	PMY940	0.0000	Passed	0.2500	Passed	Remediation has been completed
Amherst Regional High School	Room 112 - Classroom Kitchen Faucet	MVN577	0.0043	Passed	0.3600	Passed	Remediation has been completed
Amherst Regional High School	Room 110 - Classroom Kitchen Faucet	PED153	0.0014	Passed	0.1900	Passed	Remediation has been completed
Amherst Regional High School	Room 108 - Classroom Kitchen Faucet	MVN579	0.0014	Passed	0.3700	Passed	Remediation has been completed
Amherst Regional High School	Room 111 - Classroom Kitchen Faucet	PMY944	0.0000	Passed	0.2500	Passed	Remediation has been completed
Amherst Regional High School	Room 109 - Classroom Kitchen Faucet	PED152	0.0011	Passed	0.3300	Passed	Remediation has been completed
Amherst Regional High School	Room 107 - Classroom Kitchen Faucet	MVN582	0.0046	Passed	0.3700	Passed	Remediation has been completed
Amherst Regional High School	Room 105 - Classroom Kitchen Faucet	PED154	0.0012	Passed	0.3000	Passed	Remediation has been completed
Amherst Regional High School	Room 103 - Classroom Kitchen Faucet	MVN584	0.0022	Passed	0.3200	Passed	Remediation has been completed
Amherst Regional High School	Room 101 #1 - Classroom Kitchen Faucet	MVN585	0.0050	Passed	0.5300	Passed	Remediation has been completed
Amherst Regional High School	Room 101 #2 - Classroom Kitchen Faucet	PBJ469	0.0006	Passed	0.3800	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler in Green Wing	PED147	0.0014	Passed	0.0006	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler in Trades Building	MVN588	0.0007	Passed	0.6200	Passed	Remediation has been completed
Amherst Regional High School	Room 224 #1 - Classroom Kitchen Faucet	PJY743	0.0009	Passed	0.1500	Passed	Remediation has been completed
Amherst Regional High School	Room 224 #2 - Classroom Kitchen Faucet	PJY744	0.0009	Passed	0.1500	Passed	Remediation has been completed
Amherst Regional High School	Room 224 #3 - Classroom Kitchen Faucet	MVN591	0.0024	Passed	0.4000	Passed	Remediation has been completed
Amherst Regional High School	Room 224 #4 - Classroom Kitchen Faucet	PJY745	0.0010	Passed	0.0150	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler in Yellow Wing	PED151	0.0022	Passed	0.4100	Passed	Remediation has been completed
Amherst Regional High School	Room 231 - Classroom Kitchen Faucet	PJY741	0.0010	Passed	0.4100	Passed	Remediation has been completed
Amherst Regional High School	Room 229 - Classroom Kitchen Faucet	PMY943	0.0008	Passed	0.2500	Passed	Remediation has been completed
Amherst Regional High School	Room 227 - Classroom Kitchen Faucet	PJY740	0.0013	Passed	0.3700	Passed	Remediation has been completed
Amherst Regional High School	Room 225 - Classroom Kitchen Faucet	PJY739	0.0011	Passed	0.3600	Passed	Remediation has been completed
Amherst Regional High School	Room 223 - Classroom Kitchen Faucet	PMY941	0.0007	Passed	0.2100	Passed	Remediation has been completed
Amherst Regional High School	Room 221 - Classroom Kitchen Faucet	PMY948	0.0006	Passed	0.2000	Passed	Remediation has been completed
Amherst Regional High School	Room 216 - Classroom Kitchen Faucet	PMY945	0.0006	Passed	0.1900	Passed	Remediation has been completed
Amherst Regional High School	Room 222 - Classroom Kitchen Faucet	MVN601	0.0037	Passed	0.4600	Passed	Remediation has been completed
Amherst Regional High School	Room 204 - Classroom Kitchen Faucet	PMY946	0.0017	Passed	0.4800	Passed	Remediation has been completed
Amherst Regional High School	Room 208 - Classroom Kitchen Faucet	MVN603	0.0028	Passed	0.4100	Passed	Remediation has been completed
Amherst Regional High School	Room 206 - Classroom Kitchen Faucet	PMY949	0.0007	Passed	0.2000	Passed	Remediation has been completed
Amherst Regional High School	Room 209 - Classroom Kitchen Faucet	MVN605	0.0007	Passed	0.2500	Passed	Remediation has been completed
Amherst Regional High School	Bottle Filler in Red Wing	PED146	0.0026	Passed	0.3800	Passed	Remediation has been completed
Amherst Regional High School	Room 201 - Classroom Kitchen Faucet	PMY950	0.0009	Passed	0.3400	Passed	Remediation has been completed
Amherst Regional High School	Room 203 - Classroom Kitchen Faucet	MVN608	0.0040	Passed	0.3300	Passed	Remediation has been completed
Amherst Regional High School	Room 205 - Classroom Kitchen Faucet	MVN609	0.0041	Passed	0.3200	Passed	Remediation has been completed
Amherst Regional High School	Room 207 - Classroom Kitchen Faucet	PMY947	0.0006	Passed	0.1900	Passed	Remediation has been completed
Amherst Regional High School	Room 202 - Classroom Kitchen Faucet	PMY951	0.0006	Passed	0.3500	Passed	Remediation has been completed
Amherst Regional High School	Room 211 - Classroom Kitchen Faucet	PMY952	0.0012	Passed	0.0003	Passed	Remediation has been completed
Amherst Regional High School	Room 3001 - Classroom Kitchen Faucet	MVN613	0.0021	Passed	0.2300	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Amherst Regional High School	Mech Gym - Kitchen Faucet	MVN614	0.0016	Passed	0.2400	Passed	Remediation has been completed
Amherst Regional High School	Room 2500 - Classroom Kitchen Faucet	MVN615	0.0005	Passed	0.0620	Passed	Remediation has been completed
Amherst Regional High School	Girls Green Sink #2 - Washroom Faucet	NFR329	0.0014	Passed	0.2600	Passed	Remediation has been completed
Amherst Regional High School	Girls Green Sink #1 - Washroom Faucet	NFR330	0.0034	Passed	0.4000	Passed	Remediation has been completed
Amherst Regional High School	Girls Green Sink #4 - Washroom Faucet	NFR331	0.0021	Passed	0.2200	Passed	Remediation has been completed
Amherst Regional High School	Girls Green Sink #3 - Washroom Faucet	NFR332	0.0023	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	Teacher Green Sink - Washroom Faucet	NFR333	0.0017	Passed	0.2800	Passed	Remediation has been completed
Amherst Regional High School	Janitor Sink Yellow Section - Custodial Kitchen Faucet	NFR334	0.0020	Passed	0.2000	Passed	Remediation has been completed
Amherst Regional High School	Trans Gen Sink by Office - Washroom Faucet	NFR335	0.0006	Passed	0.1400	Passed	Remediation has been completed
Amherst Regional High School	Nurse Office Sink - Washroom Faucet	NFR336	0.0000	Passed	0.0510	Passed	Remediation has been completed
Amherst Regional High School	Boys Blue Sink #1 - Washroom Faucet	NFR337	0.0008	Passed	0.0600	Passed	Remediation has been completed
Amherst Regional High School	Boys Blue Sink #2 - Washroom Faucet	NFR338	0.0008	Passed	0.0560	Passed	Remediation has been completed
Amherst Regional High School	Girls Blue Sink #3 - Washroom Faucet	NFR339	0.0000	Passed	0.0490	Passed	Remediation has been completed
Amherst Regional High School	Girls Blue Sink #4 - Washroom Faucet	NFR340	0.0005	Passed	0.0880	Passed	Remediation has been completed
Amherst Regional High School	Girls Blue Sink #2 - Washroom Faucet	NFR341	0.0005	Passed	0.0530	Passed	Remediation has been completed
Amherst Regional High School	Girls Blue Sink #1 - Washroom Faucet	NFR342	0.0006	Passed	0.0580	Passed	Remediation has been completed
Amherst Regional High School	Teach 115 Blue - Washroom Faucet	NFR343	0.0008	Passed	0.2100	Passed	Remediation has been completed
Amherst Regional High School	Main Office Bathroom Sink - Washroom Faucet	NFR344	0.0005	Passed	0.0940	Passed	Remediation has been completed
Amherst Regional High School	Stage Washroom - Washroom Faucet	NFR345	0.0010	Passed	0.0480	Passed	Remediation has been completed
Amherst Regional High School	Café Boys Sink #3 - Washroom Faucet	NFR346	0.0000	Passed	0.0290	Passed	Remediation has been completed
Amherst Regional High School	Café Boys Sink #1 - Washroom Faucet	NFR347	0.0005	Passed	0.0360	Passed	Remediation has been completed
Amherst Regional High School	Café Boys Sink #2 - Washroom Faucet	NFR348	0.0000	Passed	0.0320	Passed	Remediation has been completed
Amherst Regional High School	Boys Change Room A - Washroom Faucet	NFR349	0.0005	Passed	0.0480	Passed	Remediation has been completed
Amherst Regional High School	Boys Change Room B - Washroom Faucet	NFR350	0.0000	Passed	0.0370	Passed	Remediation has been completed
Amherst Regional High School	Café Girls #1 - Washroom Faucet	NFR351	0.0026	Passed	0.0880	Passed	Remediation has been completed
Amherst Regional High School	Café Girls #2 - Washroom Faucet	PED141	0.0022	Passed	0.1500	Passed	Remediation has been completed
Amherst Regional High School	Café Girls #3 - Washroom Faucet	NFR353	0.0007	Passed	0.0530	Passed	Remediation has been completed
Amherst Regional High School	Stage Prep #1 - Washroom Faucet	NFR354	0.0000	Passed	0.0370	Passed	Remediation has been completed
Amherst Regional High School	Stage Prep #2 - Washroom Faucet	NFR355	0.0000	Passed	0.0310	Passed	Remediation has been completed
Amherst Regional High School	Janitor Sink Blue - Custodial Kitchen Faucet	NFR356	0.0022	Passed	0.2600	Passed	Remediation has been completed
Amherst Regional High School	Special Needs Sink - Washroom Faucet	NFR357	0.0011	Passed	0.4300	Passed	Remediation has been completed
Amherst Regional High School	Staff Blue Sink #1 - Washroom Faucet	NFR358	0.0030	Passed	0.1800	Passed	Remediation has been completed
Amherst Regional High School	Boys Blue Sink #3 - Washroom Faucet	NFR359	0.0008	Passed	0.0560	Passed	Remediation has been completed
Amherst Regional High School	Boys Blue Sink #4 - Washroom Faucet	NFR360	0.0006	Passed	0.0540	Passed	Remediation has been completed
Amherst Regional High School	Janitor Sink Tess Room - Custodial Kitchen Faucet	NFR361	0.0000	Passed	0.0340	Passed	Remediation has been completed
Amherst Regional High School	Room 142 - Washroom Faucet	NFR362	0.0011	Passed	0.0810	Passed	Remediation has been completed
Amherst Regional High School	Café Worker Sink - Washroom Faucet	NFR363	0.0006	Passed	0.0690	Passed	Remediation has been completed
Amherst Regional High School	Café Hand Sink - Washroom Faucet	NFR364	0.0006	Passed	0.0520	Passed	Remediation has been completed
Amherst Regional High School	Maintenance Washroom Sink - Washroom Faucet	NFR365	0.0005	Passed	0.0420	Passed	Remediation has been completed
Amherst Regional High School	Room 144 - Washroom Faucet	NFR366	0.0006	Passed	0.0520	Passed	Remediation has been completed
Amherst Regional High School	Girls Locker Sink - Washroom Faucet	NFR367	0.0016	Passed	0.1100	Passed	Remediation has been completed
Amherst Regional High School	Girls Locker Sink B - Washroom Faucet	NFR368	0.0051	Passed	0.3700	Passed	Remediation has been completed
Amherst Regional High School	Staff Blue Sink #2 - Washroom Faucet	NFR369	0.0031	Passed	0.1600	Passed	Remediation has been completed
Amherst Regional High School	Boys Green Bath Sink #1 - Washroom Faucet	NFR370	0.0025	Passed	0.2400	Passed	Remediation has been completed
Amherst Regional High School	Boys Green Bath Sink #2 - Washroom Faucet	NFR371	0.0020	Passed	0.2200	Passed	Remediation has been completed
Amherst Regional High School	Boys Green Bath Sink #3 - Washroom Faucet	NFR372	0.0020	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	Boys Green Bath Sink #4 - Washroom Faucet	NFR373	0.0018	Passed	0.2200	Passed	Remediation has been completed
Amherst Regional High School	Guidance Sink - Washroom Faucet	NFR374	0.0006	Passed	0.0680	Passed	Remediation has been completed
Amherst Regional High School	Custodial/Office - Custodial Kitchen Faucet	NFR375	0.0006	Passed	0.0910	Passed	Remediation has been completed
Amherst Regional High School	2102 Sink #1 - Washroom Faucet	NHD717	0.0029	Passed	0.2400	Passed	Remediation has been completed
Amherst Regional High School	2102 Sink #2 - Washroom Faucet	NHD718	0.0031	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2102 Sink #3 - Washroom Faucet	NHD719	0.0029	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2102 Sink #4 - Washroom Faucet	NHD720	0.0028	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2104 Sink #1 - Washroom Faucet	NHD721	0.0028	Passed	0.2400	Passed	Remediation has been completed
Amherst Regional High School	2104 Sink #2 - Washroom Faucet	NHD722	0.0027	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2104 Sink #3 - Washroom Faucet	NHD723	0.0028	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2104 Sink #4 - Washroom Faucet	NHD724	0.0029	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2320 - Washroom Faucet	NHD725	0.0028	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	2311 - Washroom Faucet	NHD726	0.0028	Passed	0.2400	Passed	Remediation has been completed
Amherst Regional High School	2304 Sink #1 - Washroom Faucet	NHD727	0.0033	Passed	0.1800	Passed	Remediation has been completed
Amherst Regional High School	2304 Sink #2 - Washroom Faucet	NHD728	0.0033	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2304 Sink #3 - Washroom Faucet	NHD729	0.0030	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2304 Sink #4 - Washroom Faucet	NHD730	0.0030	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2302 Sink #1 - Washroom Faucet	NHD731	0.0029	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2302 Sink #2 - Washroom Faucet	NHD732	0.0030	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2302 Sink #3 - Washroom Faucet	NHD733	0.0031	Passed	0.1700	Passed	Remediation has been completed
Amherst Regional High School	2302 Sink #4 - Washroom Faucet	NHD734	0.0035	Passed	0.1800	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Amherst Regional High School	2110 - Washroom Faucet	NHD735	0.0028	Passed	0.3100	Passed	Remediation has been completed
Amherst Regional High School	2011 - Washroom Faucet	NHD736	0.0029	Passed	0.2300	Passed	Remediation has been completed
Amherst Regional High School	Trades Building Janitor Sink - Custodial Kitchen Sink	NHD737	0.0017	Passed	0.4500	Passed	Remediation has been completed
Amherst Regional High School	Trades Building Bathroom Sink	NHD738	0.0015	Passed	0.4000	Passed	Remediation has been completed
Amherst Regional High School	Room 120	NIN075	0.0016	Passed	0.4400	Passed	Remediation has been completed
Amherst Regional High School	Room 119 Sink 1	NIN076	0.0042	Passed	0.5800	Passed	Remediation has been completed
Amherst Regional High School	Room 108	NIN078	0.0010	Passed	0.8800	Passed	Remediation has been completed
Amherst Regional High School	Room 158	NIN080	0.0008	Passed	0.0570	Passed	Remediation has been completed
Amherst Regional High School	Room 160	NIN081	0.0010	Passed	0.0710	Passed	Remediation has been completed
Amherst Regional High School	Room 159	NIN082	0.0006	Passed	0.0670	Passed	Remediation has been completed
Amherst Regional High School	Room 161	NIN083	0.0010	Passed	0.0580	Passed	Remediation has been completed
Amherst Regional High School	Room 207	NIN084	0.0017	Passed	0.1600	Passed	Remediation has been completed
Amherst Regional High School	Room 208	NIN085	0.0016	Passed	0.1500	Passed	Remediation has been completed
Amherst Regional High School	Room 212	NIN086	0.0027	Passed	0.2000	Passed	Remediation has been completed
Amherst Regional High School	Room 228 Sink #3	NIN087	0.0011	Passed	0.1500	Passed	Remediation has been completed
Amherst Regional High School	Room 230	NIN088	0.0001	Passed	0.1200	Passed	Remediation has been completed
Amherst Regional High School	Blue Wing Bottle Filler	PED149	0.0016	Passed	0.3200	Passed	Remediation has been completed
Bible Hill Consolidated	Kitchen Tray Washing Tap, T5	MQE325	0.0015	Passed	0.2000	Passed	Remediation has been completed
Bible Hill Consolidated	Kitchen Main Sink, T7	MQE326	0.0000	Passed	0.2200	Passed	Remediation has been completed
Bible Hill Consolidated	Recycle Room 108 Tap, T11	MQE327	0.0000	Passed	0.2300	Passed	Remediation has been completed
Bible Hill Consolidated	Bottle Filler by Wash Area 112, F1	MQE328	0.0000	Passed	0.1900	Passed	Remediation has been completed
Bible Hill Consolidated	Learning Centre Room 116 Tap, T17	MQE329	0.0000	Passed	0.1500	Passed	Remediation has been completed
Bible Hill Consolidated	Staff Room 119 Tap, T18	MQE330	0.0000	Passed	0.1100	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 120 Tap, T21	MQE331	0.0000	Passed	0.1400	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 124 Tap, T22	MQE332	0.0000	Passed	0.1400	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 123 Tap, T35	MQE333	0.0000	Passed	0.1800	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 127 Tap, T36	MQE334	0.0000	Passed	0.2000	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 132 Tap 27	MQE335	0.0000	Passed	0.2300	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 131 Tap, T29	MQE336	0.0000	Passed	0.2200	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 136 Tap, T28	MQE337	0.0000	Passed	0.1800	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 135 Tap, T30	MQE338	0.0000	Passed	0.2600	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 144 Tap, T37	MQE339	0.0000	Passed	0.2300	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom Room 148 Tap, T38	MQE340	0.0000	Passed	0.2500	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 143 Tap, T33	MQE341	0.0005	Passed	0.1900	Passed	Remediation has been completed
Bible Hill Consolidated	Classroom 147 Tap, T34	MQE342	0.0006	Passed	0.2300	Passed	Remediation has been completed
Bible Hill Junior High School	Metal Shop (BM), F7	QWJ546	0.0000	Passed	0.0030	Passed	Remediation has been completed
Bible Hill Junior High School	Cafeteria, F2	QWJ547	0.0016	Passed	0.0130	Passed	Remediation has been completed
Bible Hill Junior High School	Main Kitchen Sink, T14	QWJ548	0.0043	Passed	0.0250	Passed	Remediation has been completed
Bible Hill Junior High School	Kitchen Sink near Dishwasher, T15	RNF536	0.0960	Exceeds Limit	0.0370	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Bible Hill Junior High School	Bottle Filler Main Floor Across from Rm 103, F3	QWJ550	0.0000	Passed	0.0061	Passed	Remediation has been completed
Bible Hill Junior High School	Upper FS Room 210 Hall Wall, T29	RNF536	0.0058	Exceeds Limit	0.0380	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Bible Hill Junior High School	Upper FS Room 210 Far Left, T28	QKQ758	0.0037	Passed	0.0220	Passed	Remediation has been completed
Bible Hill Junior High School	Upper FS Room 210, Mid Left, T30	QKQ759	0.0031	Passed	0.0150	Passed	Remediation has been completed
Bible Hill Junior High School	Upper FS Room 210, Mid Right, T31	QKQ760	0.0023	Passed	0.0140	Passed	Remediation has been completed
Bible Hill Junior High School	Upper FS Room 210, Far Right, T32	QWJ552	0.0043	Passed	0.0260	Passed	Remediation has been completed
Bible Hill Junior High School	Near FS Upstairs 210, F4	QKQ762	0.0000	Passed	0.0290	Passed	Remediation has been completed
Bible Hill Junior High School	Kitchen Room 209, T34	MOY694	0.0460	Exceeds Limit	0.6000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Bible Hill Junior High School	Across from Rm 203, F5	QKQ763	0.0016	Passed	0.1500	Passed	Remediation has been completed
Bible Hill Junior High School	Staff Room Kitchen Upstairs, T51	OGU962	0.0048	Passed	0.5700	Passed	Remediation has been completed
Bible Hill Junior High School	Male Washroom, T1	NUB407	0.0190	Exceeds Limit	0.6300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Female Washroom, T2	NUB408	0.0110	Exceeds Limit	0.6000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Wood Shop, T3	NUB409	0.0180	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Storage 006 Wood Shop, T5	NUB410	0.0550	Exceeds Limit	0.7500	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Classroom Shop, T4	NUB411	0.0390	Exceeds Limit	1.2000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Staff Washroom by Music, T6	NUB412	0.0043	Passed	0.4300	Passed	Remediation has been completed
Bible Hill Junior High School	Gym Everyone Washroom Left, T9	NUB413	0.0210	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	M/F Girls Locker Room Left Tap, T7	NUB414	0.0007	Passed	0.1100	Passed	Remediation has been completed
Bible Hill Junior High School	M/F Girls Locker Room Right Tap, T8	NUB415	0.0013	Passed	0.2200	Passed	Remediation has been completed
Bible Hill Junior High School	Gym Office Left Womens, T10	NUB416	0.0072	Exceeds Limit	0.6500	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Everyone Washroom Right, T11	NUB417	0.0100	Exceeds Limit	0.6200	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Gym Office Right Mens, T12	NUB418	0.0530	Exceeds Limit	0.8200	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Main Kitchen Handwash Sink, T13	NUB419	0.0200	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Handicap Washroom by Rm 103, T26	NUB420	0.0270	Exceeds Limit	0.5700	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Custodial Room by 103, T27	NUB421	0.0220	Exceeds Limit	0.9200	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Schools Plus Washroom, T25	NUB422	0.0130	Exceeds Limit	0.7300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Everyone Washroom by Schools Plus, T24	NUB423	0.0200	Exceeds Limit	0.8200	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Staff Washroom by Schools Plus, T23	NUB424	0.0061	Exceeds Limit	0.9000	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Bible Hill Junior High School	Boys Washroom Left Tap, T21	NUB425	0.0120	Exceeds Limit	0.5500	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Boys Washroom Right Tap, T22	NUB426	0.0030	Passed	0.7500	Passed	Remediation has been completed
Bible Hill Junior High School	Girls Washroom Far Left, T16	NUB427	0.0400	Exceeds Limit	0.8800	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle Left, T17	NUB428	0.0200	Exceeds Limit	0.7300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle, T18	NUB429	0.5900	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle Right, T19	NUB430	0.0110	Exceeds Limit	1.3000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Right, T20	NUB431	0.0088	Exceeds Limit	1.2000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Special Needs 209 Washroom, T33	NUB438	0.0033	Passed	0.7700	Passed	Remediation has been completed
Bible Hill Junior High School	Science 208 Left Tap, T36	NUB439	0.0770	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Science 208 Right Tap, T35	NUB440	0.0570	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Library IT Office, T54	NUB441	0.0430	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Classroom 207 Left Tap, T38	NUB442	0.0140	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Classroom 207 Right Tap, T37	NUB443	0.0150	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Classroom 213 Left Tap, T49	NUB444	0.0940	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Classroom 213 Right Tap, T50	NUB445	0.8300	Exceeds Limit	0.4600	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Far Left, T43	NUB446	0.0240	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle Left, T42	NUB447	0.0140	Exceeds Limit	0.8800	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle Tap, T41	NUB448	0.0200	Exceeds Limit	0.8500	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Middle Right Tap, T40	NUB449	0.0099	Exceeds Limit	0.8400	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Girls Washroom Right Tap, T39	NUB450	0.0210	Exceeds Limit	0.8300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Custodial Room, T44	NUB451	0.0043	Passed	0.4900	Passed	Remediation has been completed
Bible Hill Junior High School	Boys Washroom Left Tap, T48	NUB452	0.0044	Passed	0.4400	Passed	Remediation has been completed
Bible Hill Junior High School	Boys Washroom Left Middle Tap, T47	NUB453	0.0160	Exceeds Limit	0.7100	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Boys Washroom Right Middle, T46	NUB454	0.0049	Passed	0.7100	Passed	Remediation has been completed
Bible Hill Junior High School	Boys Washroom Right Tap, T45	NUB455	0.0046	Passed	0.6900	Passed	Remediation has been completed
Bible Hill Junior High School	Staff Washroom Left Tap, T53	NUB456	0.0080	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Bible Hill Junior High School	Staff Washroom Right Tap, T52	NUB457	0.0130	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Room 5 Kitchen T5 Staff Washroom	MOP210	0.0570	Exceeds Limit	1.3000	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Kitchen Sink, T4	QND332	0.0028	Passed	0.0038	Passed	Remediation has been completed
Brookfield Elementary School	Cafeteria (for BP) - REMOVED	QTV330	0.0130	Exceeds Limit	0.0036	Passed	Remediation has been completed
Brookfield Elementary School	Staff Rm Kitchen, T17	PEJ024	0.0018	Passed	0.0510	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Brookfield Elementary School	Bottle Filler Replaced Bottle Filler by Gym, F2	PEJ025	0.0006	Passed	0.0420	Passed	Remediation has been completed
Brookfield Elementary School	Bottle Filler Replaced Bottle Filler Upstairs, F3	PEJ026	0.0000	Passed	0.0760	Passed	Remediation has been completed
Brookfield Elementary School	LC Room 32 Sink on Left, T27 -Removed	NWL914	0.3700	Exceeds Limit	0.7100	Passed	Remediation has been completed
Brookfield Elementary School	LC Room 32 Sink in Mid, T28 - Removed	MOP217	0.1700	Exceeds Limit	3.6000	Exceeds Limit	Remediation has been completed
Brookfield Elementary School	LC Room 32 Kitchen RT Wall, T29	QND334	0.0008	Passed	0.0052	Passed	Remediation has been completed
Brookfield Elementary School	LC Room 32 Kitchen by Dr RM 33, T30	QND335	0.0024	Passed	0.0043	Passed	Remediation has been completed
Brookfield Elementary School	Dish Sprayer, T32	NWL890	0.0007	Passed	0.0540	Passed	Remediation has been completed
Brookfield Elementary School	Main Kitchen Handwash Tap, T6	NWL896	0.0250	Exceeds Limit	0.5900	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Boys Washroom Left Tap, T10	NWL897	0.0340	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Boys Washroom Middle Tap, T9	NWL898	0.1800	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Boys Washroom Right Tap, T8	NWL899	0.0310	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Custodial Room by Staff Room, T11	NWL900	0.0098	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Staff Washroom by Staff Room, T16	NWL901	0.0020	Passed	0.0410	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Girls Washroom Left Tap, T14	NWL902	0.0190	Exceeds Limit	0.0940	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Girls Washroom Middle Tap, T13	NWL903	0.0055	Exceeds Limit	0.0760	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Girls Washroom Right Tap, T12	NWL904	0.0150	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Principals Washroom, T33	NWL905	0.2300	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Boys Washroom Left Tap, T20	NWL906	0.0210	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Boys Washroom Right Tap, T19	NWL907	0.0083	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Staff Washroom by Room 47, T25	NWL908	0.0027	Passed	0.0280	Passed	Remediation has been completed
Brookfield Elementary School	Storage Room off Room 47, T26	NWL909	4.7000	Exceeds Limit	7.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Brookfield Elementary School	Custodial Room, T21	NWL910	0.0061	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Brookfield Elementary School	Girls Washroom Left Tap, T24	NWL911	0.0027	Passed	0.0570	Passed	Remediation has been completed
Brookfield Elementary School	Girls Washroom Middle Tap, T23	NWL912	0.0042	Passed	0.0750	Passed	Remediation has been completed
Brookfield Elementary School	Girls Washroom Right Tap, T22	NWL913	0.0074	Exceeds Limit	0.0740	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Room 48 Kit Tap Back of Tech Shop, T2	MVH514	0.0160	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Kitchen Main Sink Tap, T9	RDF122	0.0023	Passed	0.0250	Passed	Remediation has been completed
Central Colchester Junior High School	Kit Three Compartment Sink Tap, T11	QKQ289	0.0075	Exceeds Limit	0.0250	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Kitchen Single Sink Tap, T12	QKQ290	0.0033	Passed	0.0150	Passed	Remediation has been completed
Central Colchester Junior High School	Cooking Lab Tap on Left, T14	OLP020	0.0000	Passed	0.0970	Passed	Remediation has been completed
Central Colchester Junior High School	Cooking Lab Tap on Right, T15	OLP021	0.0006	Passed	1.6000	Passed	Remediation has been completed
Central Colchester Junior High School	Sewing Lab Tap on Wall, T16	OLP022	0.0039	Passed	0.1900	Passed	Remediation has been completed
Central Colchester Junior High School	Sewing Lab Tap by Washer, T57	MVH521	0.0045	Passed	0.2200	Passed	Remediation has been completed
Central Colchester Junior High School	Kit Tap Off of Library, T20	OLP023	0.0120	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Fountain by Main Office, F1	QWJ655	0.0000	Passed	0.0980	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Central Colchester Junior High School	Room 22 Learning Centre Kit Tap, T27	OLP024	0.0042	Passed	0.5100	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Central Colchester Junior High School	Staff Room Kitchen Tap on Right, T31	QKQ292	0.0017	Passed	0.0590	Passed	Remediation has been completed
Central Colchester Junior High School	Staff Room Kitchen Tap on Left, T32	QKQ293	0.0023	Passed	0.0046	Passed	Remediation has been completed
Central Colchester Junior High School	Bottle Filler L/F by Boys Washroom, F2	RNF499	0.0034	Passed	0.0320	Passed	Remediation has been completed
Central Colchester Junior High School	Fountain Upper Floor by Boys Washroom, F3	MVH528	0.0000	Passed	0.0034	Passed	Remediation has been completed
Central Colchester Junior High School	Tech Shop - Shop 27 (Tech), T1	NVB995	0.0017	Passed	0.0003	Passed	Remediation has been completed
Central Colchester Junior High School	Gym Hall Washroom Left, T3	NVB996	0.0050	Passed	0.0007	Passed	Remediation has been completed
Central Colchester Junior High School	Gym Hall Washroom Right, T4	NVB997	0.0010	Passed	0.0000	Passed	Remediation has been completed
Central Colchester Junior High School	Custodial Closet Gym Hall, T5	NVB998	0.0110	Exceeds Limit	0.0000	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Room 34 Gym Hall, T6	NVB999	0.0180	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Locker (Not Used), T8	NVC001	0.0440	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Main Kitchen Handwash Sink, T10	NVC002	0.0034	Passed	0.0004	Passed	Remediation has been completed
Central Colchester Junior High School	Main Kitchen Sprayer Sink, T13	NVC003	0.0240	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Custodial Room, T17	NVC004	0.0950	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Washroom by Custodial Room, T18	NVC005	0.0083	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom across from Office Left, T21	NVC006	0.0055	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom across from Office Middle, T22	NVC007	0.0110	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys E/R across from Office Right, T23	NVC008	0.0036	Passed	0.0003	Passed	Remediation has been completed
Central Colchester Junior High School	Girls Washroom across from Office Left, T24	NVC009	0.0078	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom across from Office Middle, T25	NVC010	0.0350	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom across from Office Right, T26	NVC011	0.0130	Exceeds Limit	0.0000	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Main Floor Washroom by VP Office, T29	NVC012	0.0094	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Staff Room Mens Washroom, T30	NVC013	0.0038	Passed	0.0005	Passed	Remediation has been completed
Central Colchester Junior High School	Staff Room Girls Washroom Left, T33	NVC014	0.0045	Passed	0.0004	Passed	Remediation has been completed
Central Colchester Junior High School	Staff Room Girls Washroom Right, T34	NVC015	0.0035	Passed	0.0000	Passed	Remediation has been completed
Central Colchester Junior High School	Custodial Closet, T35	NVC016	0.0030	Passed	0.0000	Passed	Remediation has been completed
Central Colchester Junior High School	Boys Washroom Left, T36	NVC017	0.0030	Passed	0.0002	Passed	Remediation has been completed
Central Colchester Junior High School	Boys Washroom Middle, T37	NVC018	0.0095	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Middle Left, T38	NVC019	0.0079	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Middle Right, T39	NVC020	0.0062	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Right Middle, T40	NVC021	0.0066	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Right, T41	NVC022	0.0088	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Left, T42	NVC023	0.0110	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Middle, T44	NVC024	0.0061	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Right, T46	NVC025	0.0082	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Custodial Closet, T47	NVC026	0.0240	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Left, T48	NVC027	0.0170	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Middle, T49	NVC028	0.0095	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Right Middle, T50	NVC029	0.0110	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Boys Washroom Right, T51	NVC030	0.0140	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Left, T52	NVC031	0.0220	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Left Middle, T53	NVC032	0.0078	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Middle, T54	NVC033	0.0062	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Right Middle, T55	NVC034	0.0064	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Girls Washroom Right, T56	NVC035	0.0093	Exceeds Limit	0.0000	Passed	Signage to be added to instruct handwashing only
Central Colchester Junior High School	Bottle Filler by Main Office, F1	QKQ291	0.0099	Exceeds Limit	0.0350	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Central Colchester Junior High School	Bottle Filler Lower Floor by Boys Washroom, F2	QKQ294	0.0100	Exceeds Limit	0.0680	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Central Colchester Junior High School	Bottle Filler Upper Floor by Washroom, F3	QWJ657	0.0000	Passed	0.0098	Passed	Remediation has been completed
Chiganois Elementary School	Staff Rm Kitchen, T1	OIM528	0.0042	Passed	0.0000	Passed	Remediation has been completed
Chiganois Elementary School	Learning Centre Kitchen Sink, T2	OIM529	0.0000	Passed	0.0000	Passed	Remediation has been completed
Chiganois Elementary School	Pre-Primary Kitchen Sink, T5	OIM530	0.0005	Passed	0.0000	Passed	Remediation has been completed
Chiganois Elementary School	Kitchen Sink to Left, T6	OIM531	0.0011	Passed	0.0001	Passed	Remediation has been completed
Chiganois Elementary School	Kitchen Sink in Middle, T7	OIM532	0.0013	Passed	0.0000	Passed	Remediation has been completed
Chiganois Elementary School	Kitchen Sink to Right, T8	OIM533	0.0046	Passed	0.0000	Passed	Remediation has been completed
Chiganois Elementary School	Bottle Filler by Boys Washroom, F1	MOP476	0.0013	Passed	0.0010	Passed	Remediation has been completed
Chiganois Elementary School	Bottle Filler by Girls Washroom, F2	MOP477	0.0000	Passed	0.5900	Passed	Remediation has been completed
Chiganois Elementary School	Staff Room Washroom Tap, T17	NMH847	0.0270	Exceeds Limit	0.0011	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Learning Centre Washroom Tap, T3	NMH849	0.0180	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Pre-Primary Washroom Tap, T4	NMH851	0.0150	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Boys Washroom Left Tap - T11	NMH855	0.0150	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Boys Washroom Middle Tap, T10	NMH856	0.0190	Exceeds Limit	0.0007	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Boys Washroom Right Tap, T9	NMH857	0.0150	Exceeds Limit	0.0012	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Custodial Room Tap, T12	NMH858	0.0092	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Girls Washroom Left Tap, T13	NMH859	0.0130	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Girls Washroom Middle Tap, T14	NMH860	0.0110	Exceeds Limit	0.0007	Passed	Signage to be added to instruct handwashing only
Chiganois Elementary School	Girls Washroom Right Tap, T15	NMH861	0.0000	Passed	0.0004	Passed	Remediation has been completed
Chiganois Elementary School	Staff Washroom Off of Hall, T16	NMH862	0.0000	Passed	0.0012	Passed	Remediation has been completed
Cobequid Consolidated Elementary School	Staff Rm Kitchen Sink, T2	NXK295	0.0032	Passed	0.4600	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Cobequid Consolidated Elementary School	Bottle Filler, F1	MRG578	0.0014	Passed	0.0003	Passed	Remediation has been completed
Cobequid Consolidated Elementary School	Kitchen Sink, T6	NXK296	0.0016	Passed	0.0009	Passed	Remediation has been completed
Cobequid Consolidated Elementary School	Custodial Room Tap, T1	NMI034	0.0110	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Staff Washroom Tap in Hall, T3	NMI035	0.0680	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Boys Washroom Left Tap, T10	NMI036	0.0140	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Boys Washroom Middle Tap, T9	NMI037	0.0046	Passed	0.0002	Passed	Remediation has been completed
Cobequid Consolidated Elementary School	Boys Washroom Right Tap, T8	NMI038	0.0054	Passed	0.0003	Passed	Remediation has been completed
Cobequid Consolidated Elementary School	Girls Washroom Left Tap, T11	NMI039	0.0110	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Girls Washroom Middle Tap, T12	NMI040	0.0180	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Girls Washroom Right Tap, T13	NMI041	0.0180	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Art Room Tap, T14	NMI042	0.0210	Exceeds Limit	0.0003	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Staff Washroom in Room 109, T15	NMI043	0.0180	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Pre-Primary Room 122 Washroom Tap, T4	NMI044	0.0082	Exceeds Limit	0.0005	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Music Room Washroom Tap, T5	NMI045	0.0081	Exceeds Limit	0.0006	Passed	Signage to be added to instruct handwashing only
Cobequid Consolidated Elementary School	Main Kitchen Handwashing Tap, T7	NMI046	0.0290	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Kitchen Tap in Principals Office, T20 - Removed	LDZ932	0.1000	Exceeds Limit	0.2600	Passed	Remediation has been completed
Cobequid District Elementary School	Staff Washroom Tap Upstairs, T9	LDZ933	0.0029	Passed	0.0970	Passed	Remediation has been completed
Cobequid District Elementary School	Girls Washroom Upstairs 1st, T3	LDZ934	0.0095	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Girls Washroom Upstairs 2nd, T4	LDZ935	0.0200	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Girls Washroom Upstairs 3rd, T5	LDZ936	0.0490	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Bottle Filler, Outside GW, F2	QTU243	0.0000	Passed	0.0130	Passed	Remediation has been completed
Cobequid District Elementary School	Boys Washroom Upstairs 1st, T6	LDZ937	0.0110	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Boys Washroom Upstairs 2nd, T7	LDZ938	0.0150	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	Boys Washroom Upstairs 3rd, T8	LDZ939	0.0590	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Cobequid District Elementary School	New Bottle Filler Upstairs, F1	QTU245	0.0000	Passed	0.7200	Passed	Remediation has been completed
Cobequid District Elementary School	Staff Room Kitchen Tap, T1	MED917	0.0043	Passed	0.1500	Passed	Remediation has been completed
Cobequid District Elementary School	Accessible Washroom Upstairs	LDZ946	0.0032	Passed	0.5800	Passed	Remediation has been completed
Cobequid District Elementary School	Raw Water in Boiler Room	LDZ947	0.0000	Passed	0.2000	Passed	Remediation has been completed
Cobequid District Elementary School	Room 114 Kitchen Tap, T17	QTU242	0.0048	Passed	0.3800	Passed	Remediation has been completed
Cobequid District Elementary School	New Tap in Room 118	QTU244	0.0047	Passed	0.0060	Passed	Remediation has been completed
Cobequid Educational Centre	Main Office by Kitchen Tap MFP1, T4	MXS676	0.0016	Passed	0.1500	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 6 MFP1, F1	MXS678	0.0000	Passed	0.0900	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 10 MFP1, F3	MXS679	0.0017	Passed	0.3700	Passed	Remediation has been completed
Cobequid Educational Centre	Special Needs Room 11 Kitchen Tap MFP1, T28	MXS680	0.0000	Passed	0.0930	Passed	Remediation has been completed
Cobequid Educational Centre	Nurses Station Kitchen Tap MFP1, T33	MXS681	0.0020	Passed	0.3100	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 24 MFP1, F4	MXS682	0.0000	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 20 MFP1, F5	MXS683	0.0000	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Music Room 97 Kitchen Sink MFP1, T45	MXS684	0.0019	Passed	0.3200	Passed	Remediation has been completed
Cobequid Educational Centre	Lab Storage MFP1, T25	MXS685	0.0042	Passed	0.2200	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler MY Room 15 MFP1, F6	MXS686	0.0028	Passed	1.1000	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Double Sink Tap MFP1, T49	RNF344	0.0009	Passed	0.2500	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Tap by Sprayer MFP1, T50	MXS688	0.0010	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Island Sink Tap MFP1, T51	MXS689	0.0000	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Pot Fill by Stove MFP1, T53	MXS690	0.0026	Passed	0.2900	Passed	Remediation has been completed
Cobequid Educational Centre	Café Rm 13 Count Sink Tap MFP, T52	MXS691	0.0009	Passed	0.0790	Passed	Remediation has been completed
Cobequid Educational Centre	Library Kitchen Sink in Office TFP1, T64	MXS863	0.0045	Passed	0.6600	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 25, TPF1, F7	MXS864	0.0000	Passed	0.1000	Passed	Remediation has been completed
Cobequid Educational Centre	2nd Flr, Bottle Filler by Stud. Coun. FTP1, F8 (REMOVED)	RNF345	0.0190	Exceeds Limit	0.5600	Passed	Remediation has been completed
Cobequid Educational Centre	Room 255 Office Sink TFP1, T95	RNF347	0.0027	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 34, TFP1, T9	MXS867	0.0000	Passed	0.0780	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 48, TFP1, F10	MXS868	0.0000	Passed	0.1000	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 44B TFP1, F11	MXS869	0.0000	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Rom 39 TFP1, F12	MXS870	0.0023	Passed	0.9800	Passed	Remediation has been completed
Cobequid Educational Centre	Room 236 T185	MXS871	0.0036	Passed	0.1100	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 104 LFP2, F13	MXS892	0.0007	Passed	0.1200	Passed	Remediation has been completed
Cobequid Educational Centre	Room 108 Kitchen Tap LFP2, T198	MXS893	0.0045	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Room 111 Corner Tap LFP2, T200	RNF348	0.0490	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Bottle Filler by Room 112, LFP2, F14	MXS895	0.0000	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Room 140 by Gym Bar Tap LFP2, T209	MXS896	0.0031	Passed	0.4200	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 140 LFP2, F15	MXS897	0.0000	Passed	0.2900	Passed	Remediation has been completed
Cobequid Educational Centre	Room 212 Old Staff Room Kit.Tap UFP2, T212	RNF349	0.0032	Passed	0.0220	Passed	Remediation has been completed
Cobequid Educational Centre	Room 207 News Room Kit Tap UFP2, T215	RNF350	0.0570	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Bottle Filler across from Cougar Cage UFP2, F16	MXT074	0.0037	Passed	0.1700	Passed	Remediation has been completed
Cobequid Educational Centre	Room 216 Family Study, 1st on Lt.Tap UFP2, T216	MXT075	0.0043	Passed	0.1600	Passed	Remediation has been completed
Cobequid Educational Centre	Room 216 Family Study 2nd on Lt Tap UFP2, T217	MXT076	0.0014	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Room 216 Family Study 3rd on Lt Tap UFP2, T218	MXT077	0.0017	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Room 216 Family Study 4th on Lt Tap UFP2, T219	MXT078	0.0025	Passed	0.2400	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
							To be updated as work progresses. All schools have clean drinkable bottled water available.
Cobequid Educational Centre	Room 216 Family Study Last Tap on Rt UFP2, T220	MXT079	0.0022	Passed	0.2400	Passed	Remediation has been completed
Cobequid Educational Centre	Room 231 Staff Room Kitchen Tap UFP2, T221	RNF351	0.0990	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Room 219 Kitchen Tap UFP2, T222	RNF352	0.0400	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Bottle Filler by Room 223, UFP2, F17	MXT082	0.0020	Passed	0.2800	Passed	Remediation has been completed
Cobequid Educational Centre	Room 223 Kitchen Tap UFP2, T223	RNF353	0.0370	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Art Room 228 Front Kitchen Tap UFP2, T225	MXT084	0.0380	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Art Room 228 1st on Lt Kitchen Tap, UFP2, T226	MXT085	0.2700	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Art Room 228 2nd on Lt Kitchen Tap UFP2, T227	MXT086	0.0260	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Art Room 228 Kitchen Tap on Rt UFP2, T228	MXT087	0.0077	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Cafeteria Canteen UFP2, T229	RNF355	0.0450	Exceeds Limit	0.3100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Cobequid Educational Centre	Cafeteria Kitchen Tap on Lt UFP2, T230	MXT089	0.0033	Passed	0.1200	Passed	Remediation has been completed
Cobequid Educational Centre	Cafeteria Kitchen Tap on Rt UFP2, T231	MXT090	0.0016	Passed	0.0960	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Girls Washroom LFP3, F18	MXT247	0.0006	Passed	0.2800	Passed	Remediation has been completed
Cobequid Educational Centre	Bottle Filler by Room 255, UFP3, F19	MXT290	0.0000	Passed	0.3700	Passed	Remediation has been completed
Cobequid Educational Centre	Room 256 Lunch Room UFP3, T241	MXT291	0.0032	Passed	0.2400	Passed	Remediation has been completed
Cobequid Educational Centre	Main Floor Lobby Boys Washroom Left, T1	OCA714	0.0006	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Main Floor Lobby Boys Washroom Middle, T2	OCA715	0.0007	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Main Floor Lobby Boys Washroom Right, T3	OCA716	0.0019	Passed	0.3700	Passed	Remediation has been completed
Cobequid Educational Centre	Main Office Girls Washroom, T5	OCA717	0.0024	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Node 1 Boys Washroom, T7	OCA718	0.0020	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Node 1 Girls Washroom, T8	OCA719	0.0015	Passed	0.1700	Passed	Remediation has been completed
Cobequid Educational Centre	Custodial By Node 1, T9	OCA720	0.0160	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Girls Washroom by Room 5 Left, T10	OCA721	0.0000	Passed	0.2700	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom By Room 5 Middle, T11	OCA722	0.0006	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 5 Right, T12 Middle	OCA723	0.0000	Passed	0.1700	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 5 Right, T13	OCA724	0.0000	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 6 Left, T14	OCA725	0.0007	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 6 Middle, T15	OCA726	0.0010	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 6 Right, T16	OCA727	0.0009	Passed	0.2200	Passed	Remediation has been completed
Cobequid Educational Centre	Stage Washroom Left, T17	OCA728	0.0028	Passed	0.1600	Passed	Remediation has been completed
Cobequid Educational Centre	Custodial Sink on Stage, T18	OCA729	0.0200	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Stage Washroom Right, T19	OCA730	0.0043	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Node 2 Boys Washroom, T23	OCA731	0.0008	Passed	0.0970	Passed	Remediation has been completed
Cobequid Educational Centre	Node 2 Girls Washroom, T24	OCA732	0.0042	Passed	0.1000	Passed	Remediation has been completed
Cobequid Educational Centre	Classroom 100 Hand Wash Sink, T26	OCA733	0.0084	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Classroom 100 Lab Sink, T27	OCA734	0.3800	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Special Needs Room 10 Washroom, T29	OCA735	0.0000	Passed	0.1100	Passed	Remediation has been completed
Cobequid Educational Centre	Main Lobby All Gender Washroom Left, T30	OCA736	0.0026	Passed	0.2600	Passed	Remediation has been completed
Cobequid Educational Centre	Main Lobby All Gender Washroom Middle, T31	OCA737	0.0097	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Nurse Station Washroom, T34	OCA738	0.0027	Passed	0.1500	Passed	Remediation has been completed
Cobequid Educational Centre	Guidance Boys Washroom, T35	OCA739	0.0018	Passed	0.2300	Passed	Remediation has been completed
Cobequid Educational Centre	Guidance Girls Washroom, T36	OCA740	0.0011	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Node 4 Boys Left, T37	OCA741	0.0011	Passed	0.1000	Passed	Remediation has been completed
Cobequid Educational Centre	Node 4 Girls Right, T38	OCA742	0.0012	Passed	0.0910	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 20 Left, T39	OCA743	0.0000	Passed	0.4200	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 20 Middle, T40	OCA744	0.0000	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 20 Right, T41	OCA745	0.0000	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 19 Left, T42	OCA746	0.0042	Passed	0.4800	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 19 Middle, T43	OCA747	0.0000	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 19 Right, T44	OCA748	0.0000	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Node 3 All Gender Left, T46	OCA749	0.0000	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Node 3 All Gender Right, T47	OCA750	0.0008	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Hand Wash Sink, T48	OCA751	0.0018	Passed	0.5000	Passed	Remediation has been completed
Cobequid Educational Centre	CEP Kitchen Hand Wash Sink by Swing Door, T52	OCA752	0.0020	Passed	0.4800	Passed	Remediation has been completed
Cobequid Educational Centre	Classroom 102, T55	OCA753	0.0084	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Classroom 101 Hand Wash Sink, T56	OCA754	0.0150	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Classroom 201 Lab Sink, T57	QEV425	0.0018	Passed	0.0120	Passed	Remediation has been completed
Cobequid Educational Centre	All Gender Washroom by Room 101 Left, T58	QEV430	0.1200	Exceeds Limit	0.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Cobequid Educational Centre	All Gender Washroom by Room 101 Middle, T59	QEV426	0.00098	Passed	0.0140	Passed	Remediation has been completed
Cobequid Educational Centre	All Gender Washroom by Room 101 Right, T60	QEV428	0.00078	Passed	0.0110	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 101 Left, T61	QEV427	0.0015	Passed	0.0045	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 101 Middle, T62	QEV429	0.00091	Passed	0.0035	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 101 Right, T63	OCA761	0.0008	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Lab 241 Front Counter Sink, T65A	OCA762	0.0033	Passed	0.5000	Passed	Remediation has been completed
Cobequid Educational Centre	Lab Storage Between 241 & 240, T67	OCA763	0.0650	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 240 1st Row Left, T68	OCA764	0.0110	Exceeds Limit	0.4100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 240 Right, T70	OCA765	0.0160	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
							To be updated as work progresses. All schools have clean drinkable bottled water available.
Cobequid Educational Centre	Lab 240 2nd Row Left, T71	OCA766	0.0300	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 240 2nd Row Middle, T72	OCA767	1.5000	Exceeds Limit	20.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 240 2nd Row Right, T73	OCA768	0.1100	Exceeds Limit	0.6300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 240 by Door, T75	OCA769	0.1400	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Top Floor Lobby Girls Washroom Right, T76	OCA770	0.0037	Passed	0.2600	Passed	Remediation has been completed
Cobequid Educational Centre	Top Floor Lobby Girls Washroom Middle, T77	OCA771	0.0010	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Top Floor Lobby Girls Washroom Left, T78	OCA772	0.0045	Passed	0.2300	Passed	Remediation has been completed
Cobequid Educational Centre	Lab Room 245 Lab Sink by Door, T79	OCA773	0.0060	Exceeds Limit	0.4200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab Room 245 Island Sink, T80	OCA774	0.0590	Exceeds Limit	0.3600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab Room 246 Lab Sink in Corner, T81	OCA775	0.0120	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab Room 246 Island Sink, T82	OCA776	0.0710	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Node 5 Right Washroom, T84	OCA777	0.0010	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	Node 5 Left Washroom, T85	OCA778	0.0019	Passed	0.1700	Passed	Remediation has been completed
Cobequid Educational Centre	Custodial by Student Council, T86	OCA779	0.0018	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 29 Left, T88	OCA781	0.0037	Passed	0.3400	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 29 Left Middle, T89	OCA782	0.0030	Passed	0.3000	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by Room 29 Right Middle, T90	OCA783	0.0013	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 30 Left, T92	OCA784	0.0009	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 30 Left Middle, T93	OCA785	0.0006	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Room 30 Right Middle, T94	OCA786	0.0008	Passed	0.1700	Passed	Remediation has been completed
Cobequid Educational Centre	Node 6 Girls Washroom Right, T96	OCA787	0.0027	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Node 6 Boys Washroom Left, T97	OCA788	0.0009	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Lab 242 Counter Island L-R 1, T98	OCA789	0.0091	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 242 Counter Island 2, T99	OCA790	0.0120	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 242 Counter Island 3, T100	OCA791	6.2000	Exceeds Limit	14.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 242 Counter Island 4, T101	OCA792	0.1800	Exceeds Limit	1.5000	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 242 Counter Island 5, T102	OCA793	0.0014	Passed	0.5600	Passed	Remediation has been completed
Cobequid Educational Centre	Lab 242 Counter Island 6, T103	OCA794	0.0081	Exceeds Limit	0.5700	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 242 Counter Island Out Door, T104	OCA795	0.6300	Exceeds Limit	3.9000	Exceeds Limit	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab Storage Between 242 & 241, T105	OCA796	0.0190	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Top Floor Lobby Boys Washroom Left, T106	OCA797	0.0015	Passed	0.2800	Passed	Remediation has been completed
Cobequid Educational Centre	Top Floor Lobby Boys Washroom Middle, T107	OCA798	0.0015	Passed	0.2300	Passed	Remediation has been completed
Cobequid Educational Centre	Top Floor Lobby Boys Washroom Right, T108	OCA799	0.0012	Passed	0.0950	Passed	Remediation has been completed
Cobequid Educational Centre	Chem Prep Room, T109	OCA800	0.0520	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Front Island, T110	OCA801	0.0130	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 1B, T112	OCA802	0.0220	Exceeds Limit	0.3900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 1D, T114	OCA803	0.0047	Passed	0.3400	Passed	Remediation has been completed
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 2C, T117	OCA804	0.0500	Exceeds Limit	0.8100	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 3D, T122	OCA805	0.0250	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 4A, T123	OCA806	0.0180	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 4C, T125	OCA807	0.1300	Exceeds Limit	0.4700	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 5A, T127	OCA808	0.0400	Exceeds Limit	0.9400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 5B, T128	OCA809	0.0300	Exceeds Limit	0.8600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 5C, T129	OCA810	0.0060	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 6B, T132	OCA811	0.0085	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 6D, T134	OCA812	0.0081	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 7A, T135	OCA813	0.0260	Exceeds Limit	0.4200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 243 Starting at Fume Hood 7V, T137	OCA814	0.0320	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Front Island, T139	OCA815	0.0490	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 2B, T145	OCA816	0.0200	Exceeds Limit	0.6300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 3B, 149	OCA817	0.0150	Exceeds Limit	0.5900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 6B, 161	OCA818	0.0064	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 6D, 163	OCA819	0.0380	Exceeds Limit	0.6200	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 7B, T165	OCA820	0.0240	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lab 244 Start at Far Wall 7D, T167	OCA821	0.0180	Exceeds Limit	0.3900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Node 8 Washroom Right, 172	OCA822	0.0010	Passed	0.1200	Passed	Remediation has been completed
Cobequid Educational Centre	Node 8 Washroom Left, 173	OCA823	0.0008	Passed	0.1200	Passed	Remediation has been completed
Cobequid Educational Centre	Custodial by 44B, T174	OCA824	0.0063	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Girls Washroom by 44, T175	OCA825	0.0011	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 44 Left Middle, T176	OCA826	0.0020	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 44 Right Middle, T177	OCA827	0.0010	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 44 Right, T178	OCA828	0.0007	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 43 Left, T179	OCA829	0.0014	Passed	0.3000	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washrom by 43 Left Middle, T180	OCA830	0.0013	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 43 Right Middle, T181	OCA831	0.0007	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 43 Right, T182	OCA832	0.0007	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Node 7 Boys Washroom, 183	OCA833	0.0006	Passed	0.1500	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Cobequid Educational Centre	Node 7 Girls Washroom, 184	OCA834	0.0013	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Classroom 236 Handwash, T185	OCA835	0.0013	Passed	0.1200	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 235 Left, T186	OCA836	0.0030	Passed	0.2400	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 235 Middle, T187	OCA837	0.0009	Passed	0.1500	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 43 Right, T182	OCA838	0.0007	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Washroom by 235 Right, T189	OCA839	0.0014	Passed	0.1500	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 235 Left, T189	OCA840	0.0039	Passed	0.3500	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 235 Middle, T190	OCA841	0.0041	Passed	0.4100	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by 235 Right, T191	OCA842	0.0056	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Room 104 Wood Shop, T192	OCC950	0.0033	Passed	0.1500	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Pop Machine Left, T193	OCC951	0.0020	Passed	0.1900	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Pop Machine Middle, T194	OCC952	0.0019	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Washroom by Pop Machine Right, T195	OCC953	0.0050	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Custodial Room by Pop Machine, T196	OCC954	0.0190	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Classroom 107, T197	OCC955	0.0074	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Class 111 Wood Shop Hand Wash, T199	OCC956	0.0010	Passed	0.1000	Passed	Remediation has been completed
Cobequid Educational Centre	Shop Room 111 Wash Tub, T201	OCC957	0.0015	Passed	0.6400	Passed	Remediation has been completed
Cobequid Educational Centre	Shop Room 112 Handwash, T202	OCC958	0.0014	Passed	0.4700	Passed	Remediation has been completed
Cobequid Educational Centre	Room 115 Wash Rub Pottery Room, T203	OCC959	0.0240	Exceeds Limit	0.7300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Girls Locker Left, T204	OCC960	0.0016	Passed	0.2200	Passed	Remediation has been completed
Cobequid Educational Centre	Girls Locker Right, T205	OCC961	0.0032	Passed	0.2600	Passed	Remediation has been completed
Cobequid Educational Centre	Boys Locker Left, T206	OCC962	0.0092	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Boys Locker Right, T207	OCC963	0.0020	Passed	0.0980	Passed	Remediation has been completed
Cobequid Educational Centre	Room 144 Laundry Tub Sink, T208	OCC964	0.0076	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Gym Office 125 Washroom, T210	OCC965	0.0071	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Gym Office Washroom (Mr. Roberts), T211	OCC966	0.0015	Passed	0.0950	Passed	Remediation has been completed
Cobequid Educational Centre	Top Floor Room 212 Old Staff Student, T213	OCC967	0.0027	Passed	0.1800	Passed	Remediation has been completed
Cobequid Educational Centre	Room 212 Old Staff Washroom, T214	OCC968	0.0210	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Top Floor Custodial 225 Tub Sink, T224	OCC969	0.0063	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Top Floor Cafeteria Kitchen Hand Wash, T232	OCC970	0.0230	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Top Floor Cafeteria Kitchen Sprayer, T233	OCC971	0.0006	Passed	0.0550	Passed	Remediation has been completed
Cobequid Educational Centre	Lower Floor - Custodial 155, T234	OCC972	0.0065	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Lower Floor - Mens Washroom Left, T235	OCC973	0.0015	Passed	0.3600	Passed	Remediation has been completed
Cobequid Educational Centre	Lower Floor - Mens Washroom Right, T236	OCC974	0.0012	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Lower Floor - Girls Washroom Left, T237	OCC975	0.0008	Passed	0.2400	Passed	Remediation has been completed
Cobequid Educational Centre	Lower Floor - Girls Washroom Right, T238	OCC976	0.0029	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Upper Floor - Mens Washroom Left, T239	OCC977	0.0028	Passed	0.2400	Passed	Remediation has been completed
Cobequid Educational Centre	Upper Floor - Mens Washroom Right, T240	OCC978	0.0010	Passed	0.2000	Passed	Remediation has been completed
Cobequid Educational Centre	Upper Floor - Custodial Room 257, T242	OCC979	0.0110	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Upper Floor - Girls Washroom Right, T244	OCC980	0.0017	Passed	0.2100	Passed	Remediation has been completed
Cobequid Educational Centre	Upper Floor - Staff Washroom Left, T245	OCC981	0.0085	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Upper Floor - Staff Washroom Right, T246	OCC982	0.0710	Exceeds Limit	0.4300	Passed	Remediation has been completed
Cobequid Educational Centre	Phase 2 Girls Washroom Left, T251	OCC983	0.0049	Passed	0.2500	Passed	Remediation has been completed
Cobequid Educational Centre	Phase 2 Girls Washroom Middle, T252	OCC984	0.0160	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Cobequid Educational Centre	Phase 2 Girls Washroom Right, T253	OCC985	0.0048	Passed	0.2300	Passed	Remediation has been completed
Cobequid Educational Centre	Phase 2 Girls 1st Floor Washroom Middle, T255	OCC986	0.0029	Passed	0.1400	Passed	Remediation has been completed
Cobequid Educational Centre	Phase 2 Girls 1st Floor Washroom Right, T256	OCC987	0.0017	Passed	0.1300	Passed	Remediation has been completed
Cobequid Educational Centre	Phase 2 Custodial Room 237, T250	OCC988	0.0033	Passed	0.1400	Passed	Remediation has been completed
Cumberland North Academy	Bottle Filler by Gym	MVZ174	0.0000	Passed	0.0001	Passed	Remediation has been completed
Cumberland North Academy	Library	MQE263	0.0017	Passed	0.5700	Passed	Remediation has been completed
Cumberland North Academy	Room 164 - Classroom	MQE264	0.0015	Passed	0.4200	Passed	Remediation has been completed
Cumberland North Academy	Room 166 - Classroom	MQE265	0.0034	Passed	0.5200	Passed	Remediation has been completed
Cumberland North Academy	Room 167 - Classroom	MQE266	0.0010	Passed	0.4800	Passed	Remediation has been completed
Cumberland North Academy	Room 169 - Classroom	MQE267	0.0011	Passed	0.5600	Passed	Remediation has been completed
Cumberland North Academy	Room 171 - Classroom	MQE268	0.0012	Passed	0.5200	Passed	Remediation has been completed
Cumberland North Academy	Room 173 - Classroom	MQE269	0.0012	Passed	0.3300	Passed	Remediation has been completed
Cumberland North Academy	Learning Centre #1 -	MQE270	0.0017	Passed	0.1000	Passed	Remediation has been completed
Cumberland North Academy	Learning Centre #2	MQE271	0.0012	Passed	0.5700	Passed	Remediation has been completed
Cumberland North Academy	Learning Centre #3	MQE272	0.0010	Passed	0.1600	Passed	Remediation has been completed
Cumberland North Academy	Staff Room	MQE273	0.0034	Passed	0.5700	Passed	Remediation has been completed
Cumberland North Academy	Bottle Filler by Library	MQE274	0.0015	Passed	0.2800	Passed	Remediation has been completed
Cumberland North Academy	Music Room	MQE275	0.0014	Passed	0.4400	Passed	Remediation has been completed
Cumberland North Academy	Stage	MQE276	0.0000	Passed	0.4900	Passed	Remediation has been completed
Cumberland North Academy	Cafeteria #1	MQE278	0.0023	Passed	0.5200	Passed	Remediation has been completed
Cumberland North Academy	Cafeteria #2	MQE279	0.0012	Passed	0.5500	Passed	Remediation has been completed
Cumberland North Academy	Recycle Room #133	MQE280	0.0010	Passed	0.6000	Passed	Remediation has been completed
Cumberland North Academy	Room 188 Classroom	NAU333	0.0006	Passed	0.3600	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Cumberland North Academy	Room 185 - Classroom	NAU331	0.0000	Passed	0.3200	Passed	Remediation has been completed
Cumberland North Academy	Room 184 Classroom	MQE284	0.0000	Passed	0.5000	Passed	Remediation has been completed
Cumberland North Academy	Room 182 Classroom	MQE285	0.0006	Passed	0.5300	Passed	Remediation has been completed
Cumberland North Academy	Room 180 Classroom	MQE286	0.0009	Passed	0.6000	Passed	Remediation has been completed
Cumberland North Academy	Room 178 Classroom	MQE287	0.0016	Passed	0.5000	Passed	Remediation has been completed
Cumberland North Academy	Room 177 Classroom	MQE288	0.0013	Passed	0.5900	Passed	Remediation has been completed
Cumberland North Academy	Room 175 Classroom	MQE289	0.0020	Passed	0.4600	Passed	Remediation has been completed
Cumberland North Academy	Cafeteria #4	MQE290	0.0018	Passed	0.1400	Passed	Remediation has been completed
Cumberland North Academy	Gym Office	NAU332	0.0005	Passed	0.2500	Passed	Remediation has been completed
Cumberland North Academy	Room 120 Sink 1 - Washroom	NAU334	0.0017	Passed	0.1500	Passed	Remediation has been completed
Cumberland North Academy	Room 120 Sink 4 - Washroom	NAU335	0.0013	Passed	0.0980	Passed	Remediation has been completed
Cumberland North Academy	Office Sink	NAU336	0.0000	Passed	0.0710	Passed	Remediation has been completed
Cumberland North Academy	Room 118 Custodial Kitchen Faucet	NAU337	0.0023	Passed	0.1600	Passed	Remediation has been completed
Cumberland North Academy	Room 119 Sink 1 Washroom	NAU338	0.0013	Passed	0.1100	Passed	Remediation has been completed
Cumberland North Academy	Room 163 Washroom	NAU339	0.0014	Passed	0.2400	Passed	Remediation has been completed
Cumberland North Academy	Room 110 Custodial Kitchen Faucet	NAU340	0.0009	Passed	0.1800	Passed	Remediation has been completed
Cumberland North Academy	Gym Boys Sink #1 - Washroom	NAU341	0.0010	Passed	0.2600	Passed	Remediation has been completed
Cumberland North Academy	Gym Boys Sink #2 - Washroom	NAU342	0.0007	Passed	0.2100	Passed	Remediation has been completed
Cumberland North Academy	Staff Washroom #1	NAU343	0.0009	Passed	0.2300	Passed	Remediation has been completed
Cumberland North Academy	Staff Washroom #2	NAU344	0.0015	Passed	0.2300	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Cafeteria Sink	MOP499	0.0041	Passed	0.0520	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Gym Bottle Filler	PYZ433	0.0015	Passed	0.1700	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Principal's Office	MOP501	0.0023	Passed	0.0480	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Bottle Filler by Washrooms	MOP502	0.0009	Passed	0.0700	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Staff Room	MOP503	0.0010	Passed	0.0390	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #14	MRN185	0.0007	Passed	0.0350	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #2	MOP505	0.0019	Passed	0.0550	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #3	MRN186	0.0006	Passed	0.0420	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #6	MOP507	0.0018	Passed	0.0480	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #7	MOP508	0.0014	Passed	0.0580	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Hallway Bottle Filler	PYZ435	0.0000	Passed	0.0990	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Girls Locker Room	NFC496	0.0041	Passed	0.0620	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Boys Locker Room	NFC497	0.0008	Passed	0.0390	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Kitchen	OLO855	0.0000	Passed	0.0750	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Custodial	NFC499	0.0000	Passed	0.0440	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Principals #1	NFC500	0.0014	Passed	0.0490	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #8 Sink #1	NFC501	0.0006	Passed	0.0460	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Boys #1	NFC502	0.0010	Passed	0.0480	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Boys #2	NFC503	0.0000	Passed	0.0410	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Girls #1	NFC504	0.0012	Passed	0.0690	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Girls #2	NFC505	0.0007	Passed	0.0430	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Staff Room	NFC506	0.0006	Passed	0.0430	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room #8 Sink #2	NFC507	0.0000	Passed	0.0410	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room 4	NFC508	0.0022	Passed	0.0600	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room 5	NFC509	0.0013	Passed	0.0550	Passed	Remediation has been completed
Cyrus Eaton Elementary School	Room 9	NFC510	0.0010	Passed	0.0550	Passed	Remediation has been completed
Debert Elementary School	Staff Room 2nd Floor	LDD577	0.0009	Passed	0.0590	Passed	Remediation has been completed
Debert Elementary School	Bottle Filler, F1	QTU283	0.0022	Passed	0.0000	Passed	Remediation has been completed
Debert Elementary School	Bottle Filler, F3	QTU284	0.0000	Passed	0.0000	Passed	Remediation has been completed
Debert Elementary School	Bottle Filler by Gym, F2	QTU284	0.00079	Passed	0.0013	Passed	Remediation has been completed
Debert Elementary School	Kitchen Handwashing Tap	LDD583	0.0680	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	Pre-Primary Kitchen Tap	MVZ210	0.0039	Passed	0.0130	Passed	Remediation has been completed
Debert Elementary School	M/L - Girls Washroom Left Tap, T1	NVA100	0.0063	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Girls Washroom Right Tap, T2	NVA101	0.0057	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Boys Washroom Left Tap, T3	NVA102	0.0150	Exceeds Limit	0.0720	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Boys Washroom Right Tap, T4	NVA103	0.0120	Exceeds Limit	0.0980	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	LL - Custodial Room, T5	NVA104	0.0087	Exceeds Limit	0.0810	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	Staff Washroom by Gym, T6	NVA105	0.0170	Exceeds Limit	0.0880	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Custodial Room off Gym, T7	NVA106	0.0093	Exceeds Limit	0.0800	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Main Kitchen Tap, T9	PMZ838	0.0050	Passed	0.0300	Passed	Remediation has been completed
Debert Elementary School	M/L - Main Kitchen Handwash Tap, T8	NVA108	0.0440	Exceeds Limit	0.0830	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Girls Change Room Tap, T10	NVA109	0.0560	Exceeds Limit	0.0600	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	M/L - Gym Office Washroom Tap, T11	NVA110	0.0960	Exceeds Limit	0.0600	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	LL - Boys Change Room Tap, T12	NVA111	0.0067	Exceeds Limit	0.0760	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	U/F - UF Staff Washroom Tap, T15	NVA112	0.0056	Exceeds Limit	0.0490	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	U/F - Pre-Primary Washroom Tap, T16	NVA113	0.0094	Exceeds Limit	0.0930	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	U/F - Grade 1 Left Washroom Tap, T17	NVA114	0.0110	Exceeds Limit	0.0370	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Debert Elementary School	U/F - Grade 1 Right Washroom Tap, T18	NVA115	0.0046	Passed	0.0520	Passed	Remediation has been completed
Debert Elementary School	U/F - Girls Washroom Left Tap, T19	NVA116	0.0036	Passed	0.1700	Passed	Remediation has been completed
Debert Elementary School	U/F - Girls Middle Tap, T20	NVA117	0.0230	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	U/F - Girls Right Tap, T21	NVA118	0.0022	Passed	0.1800	Passed	Remediation has been completed
Debert Elementary School	UF - Customer Room, T22	NVA119	0.0140	Exceeds Limit	0.0340	Passed	Signage to be added to instruct handwashing only
Debert Elementary School	U/F - Boys Washroom Left Tap, T24	NVA120	0.0026	Passed	0.1900	Passed	Remediation has been completed
Debert Elementary School	U/F - Boys Washroom Right Tap, T23	NVA121	0.0030	Passed	0.1300	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Room 104 Classroom Sink A	NWD803	0.0038	Passed	0.1300	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Room 104 Classroom Sink B	NWD804	0.0035	Passed	0.2400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Office Washroom	MOY851	0.0000	Passed	0.1200	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Kitchen Sprayer	RGX031	0.0085	Exceeds Limit	0.0250	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Kitchen Sink A	RGX030	0.0150	Exceeds Limit	0.4100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Kitchen Sink B	NWD806	0.0052	Passed	0.0740	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 107 Washroom Sink	MOY855	0.0000	Passed	0.1200	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 109 Washroom Sink A	NWD807	0.0000	Passed	0.0940	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 109 Washroom Sink B	MOY857	0.0000	Passed	0.2800	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Bottle Filler Room 109	PJB620	0.0014	Passed	0.0340	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 110 Washroom Sink	MOY858	0.0000	Passed	0.0750	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 110 Sink	MOY859	0.0000	Passed	0.0600	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Industrial Arts Rm	MOY860	0.0000	Passed	0.0750	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 215 Sink A	RGX033	0.0440	Exceeds Limit	0.0440	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Rm 215 Sink B	RGX032	0.0340	Exceeds Limit	0.0270	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Family Studies Sink A	MOY863	0.0000	Passed	0.0280	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink B	MOY864	0.0000	Passed	0.1000	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink C	MOY865	0.0000	Passed	0.1200	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink D	MOY866	0.0000	Passed	0.0930	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Family Studies Class Sink	MOY867	0.0000	Passed	0.0840	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 207 Sink	MOY868	0.0009	Passed	0.2700	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Staff Kitchen Sink	MOY869	0.0007	Passed	0.3000	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Staff Washroom Sink A	MOY870	0.0000	Passed	0.0810	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Staff Washroom Sink B	MOY871	0.0000	Passed	0.0860	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 204 Sink A	NWD810	0.0150	Exceeds Limit	0.1100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Rm 204 Sink B	RGX034	0.0370	Exceeds Limit	0.0200	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Dr. W.A. MacLeod Consolidated School	Rm 203 Sink A	NWD812	0.0038	Passed	0.1300	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Rm 203 Sink B	RGX035	0.0017	Passed	0.0240	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Counsel Rm Washroom	NWD814	0.0032	Passed	0.1500	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Gym Girls Locker Room A	NFD447	0.0015	Passed	0.3300	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Gym Girls Locker Room B	NFD448	0.0034	Passed	0.2900	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Gym Boys Locker Room A	NWD801	0.0240	Exceeds Limit	0.8500	Passed	Signage to be added to instruct handwashing only
Dr. W.A. MacLeod Consolidated School	Gym Boys Locker Room B	NWD802	0.0000	Passed	0.0005	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom A	NFD451	0.0000	Passed	0.0710	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom B	NFD452	0.0000	Passed	0.0690	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom C	NFD453	0.0000	Passed	0.0720	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom A	NFD454	0.0000	Passed	0.0700	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom B	NFD455	0.0000	Passed	0.0630	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom C	NFD456	0.0000	Passed	0.0730	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Custodial Closet	NFD457	0.0000	Passed	0.0740	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom A	NFD458	0.0000	Passed	0.0420	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom B	NFD459	0.0000	Passed	0.0390	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom C	NFD460	0.0000	Passed	0.0420	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom A	NFD461	0.0000	Passed	0.0340	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom B	NFD462	0.0000	Passed	0.0770	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom C	NFD463	0.0000	Passed	0.0460	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom D	NFD464	0.0000	Passed	0.0590	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Bottle Filler Across from Rm 104	PJB618	0.0000	Passed	0.0650	Passed	Remediation has been completed
Dr. W.A. MacLeod Consolidated School	Bottle Filler Top Floor Beside Staff Room	PJB619	0.0000	Passed	0.0690	Passed	Remediation has been completed
E. B. Chandler Junior High School	Wood Shop Sink #1	MPQ187	0.0000	Passed	0.4200	Passed	Remediation has been completed
E. B. Chandler Junior High School	Wood Shop Sink #2	NIN026	0.0000	Passed	0.0420	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #1	MPQ189	0.0020	Passed	0.5700	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #2	NIN027	0.0000	Passed	0.0390	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #3	MPQ191	0.0009	Passed	0.3700	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #4	NIN028	0.0000	Passed	0.0420	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #5	MPQ193	0.0006	Passed	0.4000	Passed	Remediation has been completed
E. B. Chandler Junior High School	Food Lab Sink #6	MPQ194	0.0000	Passed	0.5100	Passed	Remediation has been completed
E. B. Chandler Junior High School	Learning Centre	MPQ195	0.0000	Passed	0.2000	Passed	Remediation has been completed
E. B. Chandler Junior High School	Cafeteria Sink #1	MPQ196	0.0000	Passed	0.0450	Passed	Remediation has been completed
E. B. Chandler Junior High School	Cafeteria Sink #2	MPQ197	0.0008	Passed	0.0970	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
E. B. Chandler Junior High School	Staff Room	MPQ198	0.0006	Passed	0.3900	Passed	Remediation has been completed
E. B. Chandler Junior High School	Bottle Filler by Gym	NIN029	0.0000	Passed	0.0700	Passed	Remediation has been completed
E. B. Chandler Junior High School	Music Room (REMOVED)	MPQ200	0.0073	Exceeds Limit	0.4700	Passed	Remediation has been completed
E. B. Chandler Junior High School	Bottle Filler in Front Lobby	MPQ201	0.0042	Passed	0.3900	Passed	Remediation has been completed
E. B. Chandler Junior High School	Art Room #1	NIN030	0.0000	Passed	0.0440	Passed	Remediation has been completed
E. B. Chandler Junior High School	Art Room #2	NIN021	0.0000	Passed	0.0430	Passed	Remediation has been completed
E. B. Chandler Junior High School	Bottle Filler 2nd Floor	NIN032	0.0000	Passed	0.0890	Passed	Remediation has been completed
E. B. Chandler Junior High School	Boys Locker #1	NEF548	0.0011	Passed	0.0970	Passed	Remediation has been completed
E. B. Chandler Junior High School	Boys Locker #2	NEF549	0.0015	Passed	0.2100	Passed	Remediation has been completed
E. B. Chandler Junior High School	Gym Office	NEF550	0.0000	Passed	0.0240	Passed	Remediation has been completed
E. B. Chandler Junior High School	Girls Locker #1	NEF551	0.0000	Passed	0.0300	Passed	Remediation has been completed
E. B. Chandler Junior High School	Girls Locker #2	NEF552	0.0000	Passed	0.0290	Passed	Remediation has been completed
E. B. Chandler Junior High School	Room 122	NEF553	0.0043	Passed	0.0630	Passed	Remediation has been completed
E. B. Chandler Junior High School	Room 123	NEF554	0.0007	Passed	0.0930	Passed	Remediation has been completed
E. B. Chandler Junior High School	Learning Centre #1	NEF555	0.0000	Passed	0.0190	Passed	Remediation has been completed
E. B. Chandler Junior High School	Learning Centre #2	NEF556	0.0000	Passed	0.0230	Passed	Remediation has been completed
E. B. Chandler Junior High School	Staff #1	NEF557	0.0000	Passed	0.0240	Passed	Remediation has been completed
E. B. Chandler Junior High School	Staff #2	NEF558	0.0000	Passed	0.0210	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Boys #1	NEF559	0.0000	Passed	0.0330	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Boys #2	NEF560	0.0000	Passed	0.0330	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Boys #3	NEF561	0.0000	Passed	0.0320	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Girls #1	NEF562	0.0000	Passed	0.0400	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Girls #2	NEF563	0.0000	Passed	0.0380	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Girls #3	NEF564	0.0000	Passed	0.0370	Passed	Remediation has been completed
E. B. Chandler Junior High School	Lower Custodial	NEF565	0.0000	Passed	0.0290	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Boys #1	NEF566	0.0000	Passed	0.0330	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Boys #2	NEF567	0.0000	Passed	0.0620	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Boys #3	NEF568	0.0000	Passed	0.0340	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Girls #1	NEF569	0.0000	Passed	0.0370	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Girls #2	NEF570	0.0000	Passed	0.0370	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Girls #3	NEF571	0.0007	Passed	0.0500	Passed	Remediation has been completed
E. B. Chandler Junior High School	Upper Custodial	NEF572	0.0000	Passed	0.0280	Passed	Remediation has been completed
Elmsdale District Elementary School	Kitchen Sink Closer to Island	MSH296	0.0036	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Kitchen Sink in Corner, T3	QSB873	0.0018	Passed	0.0180	Passed	Remediation has been completed
Elmsdale District Elementary School	Recycle Rm 136, T9	MSH298	0.0000	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Bottle Filler by Recycle Room, F1	MSH299	0.0000	Passed	0.5400	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 1451 Kitchen Tap, T14	MSH300	0.0010	Passed	0.0960	Passed	Remediation has been completed
Elmsdale District Elementary School	Bottle Filler by Main Entrance, F2	PLM059	0.0000	Passed	0.0760	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 128 Kitchen Tap by Hall, T18	MSH302	0.0016	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 128 Tap in Kitchen, T19	MSH303	0.0012	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Music Rm 129 Kitchen Tap, T16	NFR999	0.0019	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 111 Kitchen Tap, T17	MSH305	0.0016	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 114, Kitchen Tap, T22	MSH306	0.0009	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 113, Kitchen Tap 121	MSH307	0.0014	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 116, Kitchen Tap, T25	MSH308	0.0007	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 115, Kitchen Tap, T26	PLM060	0.0000	Passed	0.0850	Passed	Remediation has been completed
Elmsdale District Elementary School	Bottle Filler Near Rm 115, F3	PLM061	0.0009	Passed	0.0690	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 117, Kitchen Tap, T27	MSH311	0.0009	Passed	0.0830	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 118, Kitchen Tap, T34	MSH312	0.0008	Passed	0.1800	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 119, Kitchen Tap, T35	MSH313	0.0012	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 133, Kitchen Tap, T36	NFR1009	0.0013	Passed	0.1500	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 112, Kitchen Tap, T37	MSH315	0.0000	Passed	0.0660	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 109, Kitchen Tap, T39	MSH316	0.0013	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 107, Kitchen Tap, T41	MSH317	0.0007	Passed	0.0790	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 110, Kitchen Tap, T43	MSH318	0.0000	Passed	0.0730	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 105, Kitchen Tap, T45	MSH319	0.0019	Passed	0.0920	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 108, Kitchen Tap, T46	MSH320	0.0012	Passed	0.0870	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 103, Kitchen Tap, T48	PLM063	0.0034	Passed	0.1200	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 106, Kitchen Tap, T47	MSH322	0.0013	Passed	0.0810	Passed	Remediation has been completed
Elmsdale District Elementary School	Bottle Filler Near 103, F4	PLM064	0.0000	Passed	0.0460	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 104, Kitchen Tap, T57	MSH324	0.0010	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 102, Kitchen Tap, T58	MSH325	0.0007	Passed	0.1500	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 101, Kitchen Tap, T59	MSH326	0.0019	Passed	0.2000	Passed	Remediation has been completed
Elmsdale District Elementary School	Learning Support Washroom 128.1, T20	NFR1000	0.0006	Passed	0.1200	Passed	Remediation has been completed
Elmsdale District Elementary School	Custodial 114.2 Cust Floor Sink, T23	NFR1001	0.1800	Exceeds Limit	3.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Everyone Washroom 150.5, T24	NFR1002	0.0028	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Left Tap, T28	NFR1003	0.0007	Passed	0.1500	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Mid Tap, T29	NFR1004	0.0007	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Right Tap, T30	NFR1005	0.0015	Passed	0.1500	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Left Tap, T31	NFR1006	0.0007	Passed	0.1300	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Mid Tap, T32	NFR1007	0.0006	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Right Tap, T33	NFR1008	0.0008	Passed	0.1400	Passed	Remediation has been completed
Elmsdale District Elementary School	Staff Washroom, T36A	NFR1010	0.0000	Passed	0.1600	Passed	Remediation has been completed
Elmsdale District Elementary School	Washroom 112.1, In Class 112 T38	NFR1011	0.0150	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Washroom 109.1 In Class 109, T40	NFR1012	0.0067	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Washroom 107.1 In Class 107, T42	NFR1013	0.0009	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Washroom 110.1 In Class 110, T44	NFR1014	0.0009	Passed	0.0570	Passed	Remediation has been completed
Elmsdale District Elementary School	Custodial Room by Class 103, T49	NFR1015	0.0013	Passed	0.1700	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Left Tap T50	NFR1016	0.0000	Passed	0.0950	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Left Tap T51	NFR1017	0.0005	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Right Tap, T52	NFR1018	0.0019	Passed	0.1900	Passed	Remediation has been completed
Elmsdale District Elementary School	Staff Washroom 157, T53	NFR1019	0.0000	Passed	0.1200	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Left Tap, T54	NFR1020	0.0012	Passed	0.1700	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Mid Tap, T55	NFR1021	0.0000	Passed	0.1300	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Right Tap, T56	NFR1022	0.0000	Passed	0.1100	Passed	Remediation has been completed
Elmsdale District Elementary School	Kitchen Sprayer Sink, T4	NFR989	0.0580	Exceeds Limit	0.8500	Passed	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Kitchen Handwash Sink, T5	NFR990	0.0098	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Gym Office 135.8 ER, T6	NFR991	0.0077	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Elmsdale District Elementary School	Girls Locker Room Washroom, T7	NFR992	0.0000	Passed	0.1300	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Locker Room Washroom T8	NFR993	0.0000	Passed	0.1500	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom by Recycle Room Left Tap, T10	NFR994	0.0007	Passed	0.0990	Passed	Remediation has been completed
Elmsdale District Elementary School	Girls Washroom by Recycle Room Right Tap, T11	NFR995	0.0012	Passed	0.1300	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom by Recycle Room Left Tap, T12	NFR996	0.0018	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Boys Washroom by Recycle Room Left Tap, T13	NFR997	0.0005	Passed	0.1000	Passed	Remediation has been completed
Elmsdale District Elementary School	Administrative 150 Washroom, T15	NFR998	0.0000	Passed	0.1800	Passed	Remediation has been completed
Elmsdale District Elementary School	Kitchen Sink in Island, T1	NSH295	0.0008	Passed	0.0870	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 160 Pre Primary Kitchen Tap, T60	PLM066	0.0028	Passed	0.0001	Passed	Remediation has been completed
Elmsdale District Elementary School	Rm 161 Pre Primary Kitchen Tap, T61	QSB874	0.0024	Passed	0.0160	Passed	Remediation has been completed
Elmsdale District Elementary School	Staff Room 133 Kitchen Tap, T36	PLM062	0.0018	Passed	0.0240	Passed	Remediation has been completed
Enfield District Elementary	Janitor Room 144, T1	NNA793	0.0140	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Staff Washroom, 142.3 - T2	NNA794	0.0081	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Washroom 142.4 - T3	NNA795	0.0081	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Staff Room Kitchen Tap, Room 142 - T4	NNA796	0.0000	Passed	0.1100	Passed	Remediation has been completed
Enfield District Elementary	Recycle Rm 147 - T5	PLL373	0.0034	Passed	0.1400	Passed	Remediation has been completed
Enfield District Elementary	Music Room 118 - T6	NNA798	0.0013	Passed	0.3800	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom off Gym Room 119.8 - T7	NNA799	0.7000	Exceeds Limit	6.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Enfield District Elementary	Gym Teachers Office Washroom 119.2 - T9	NNA800	0.0032	Passed	0.3300	Passed	Remediation has been completed
Enfield District Elementary	Classroom 116 Kitchen Tap, T10	QSB943	0.0018	Passed	0.0580	Passed	Remediation has been completed
Enfield District Elementary	Boys Washroom 145 Left Tap - T11	NNA803	0.0007	Passed	0.0820	Passed	Remediation has been completed
Enfield District Elementary	Girls Washroom 143 Left Tap - T13	NNA804	0.0012	Passed	0.0810	Passed	Remediation has been completed
Enfield District Elementary	Girls Washroom 143 Right Tap - T14	NNA805	0.0011	Passed	0.0760	Passed	Remediation has been completed
Enfield District Elementary	Kitchen Room 115.1 Kitchen Tap - T15	NNA806	0.0005	Passed	0.0570	Passed	Remediation has been completed
Enfield District Elementary	Kitchen Room 115.1 Handwash Tap - T16	NNA807	0.0038	Passed	0.3100	Passed	Remediation has been completed
Enfield District Elementary	Kitchen Room 115.1 Double Sink Tap - T17	QSB941	0.0011	Passed	0.0160	Passed	Remediation has been completed
Enfield District Elementary	Kitchen Room 115.1 Sprayer - T18	NNA809	0.6600	Exceeds Limit	1.1000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Enfield District Elementary	Bottle Filler in Cafeteria, F2	PLL419	0.0000	Passed	0.1700	Passed	Remediation has been completed
Enfield District Elementary	Custodian Room 135 Tap - T19	NNA811	0.0013	Passed	0.1600	Passed	Remediation has been completed
Enfield District Elementary	Sick Room Tap 130.3 - Tap - T20	NNA812	0.0024	Passed	0.3300	Passed	Remediation has been completed
Enfield District Elementary	Office Washroom 130.4 Tap - T22	NNA813	0.0025	Passed	0.4400	Passed	Remediation has been completed
Enfield District Elementary	Classroom 107 Kitchen Tap - T23	QSB942	0.0011	Passed	0.0160	Passed	Remediation has been completed
Enfield District Elementary	Classroom 108 Kitchen Tap - T24	NNA815	0.0026	Passed	0.2700	Passed	Remediation has been completed
Enfield District Elementary	Classroom 109 - T25	PLL379	0.0013	Passed	0.2600	Passed	Remediation has been completed
Enfield District Elementary	Classroom 110 - T26	NNA817	0.0019	Passed	0.4900	Passed	Remediation has been completed
Enfield District Elementary	Washroom 137 - T27	NNA818	0.0800	Exceeds Limit	0.7000	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Female Washroom 134 Left Tap - T28	NNA819	0.0011	Passed	0.1100	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom 134 Middle Tap - T29	NNA820	0.0000	Passed	0.0850	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom 134 Right Tap - T30	NNA821	0.0022	Passed	0.1300	Passed	Remediation has been completed
Enfield District Elementary	Male Washroom 135 Left Tap - T31	NNA822	0.0010	Passed	0.1400	Passed	Remediation has been completed
Enfield District Elementary	Male Washroom 135 Middle Tap - T32	NNA823	0.0059	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Male Washroom 135 Right Tap - T33	NNA824	0.0015	Passed	0.1300	Passed	Remediation has been completed
Enfield District Elementary	Classroom 112 Kitchen Tap - T34	QSB940	0.0500	Exceeds Limit	0.0170	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Classroom 114 Kitchen Tap - T35	PLL381	0.0041	Passed	0.2900	Passed	Remediation has been completed
Enfield District Elementary	Classroom 113 Kitchen Tap - T36	PLL382	0.0000	Passed	0.1900	Passed	Remediation has been completed
Enfield District Elementary	Classroom 111 Kitchen Tap - T37	PLL413	0.0038	Passed	0.0260	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Enfield District Elementary	Bottle Filler by Washroom 135, F3	PLL377	0.0000	Passed	0.1900	Passed	Remediation has been completed
Enfield District Elementary	Workroom 121.1 Off Library, T38	PLL414	0.0049	Passed	0.0980	Passed	Remediation has been completed
Enfield District Elementary	Special Needs Kitchen Tap Room 120 - T39	NNA831	0.0036	Passed	0.4400	Passed	Remediation has been completed
Enfield District Elementary	Washroom 122.2 Tap - T40	NNA832	0.0031	Passed	0.5300	Passed	Remediation has been completed
Enfield District Elementary	51 Room Classroom 122 Kitchen Tap - T41	PLL415	0.0041	Passed	0.0780	Passed	Remediation has been completed
Enfield District Elementary	Custodian Room 127 - Tap - 42	NNA834	0.0024	Passed	0.2700	Passed	Remediation has been completed
Enfield District Elementary	Classroom 101 Tap - T43	NNA835	0.0042	Passed	0.5500	Passed	Remediation has been completed
Enfield District Elementary	Classroom Washroom 101.1 Tap - T46	NNA836	0.0043	Passed	0.3600	Passed	Remediation has been completed
Enfield District Elementary	Classroom 102 Kitchen Tap - T44	NNA837	0.0029	Passed	0.3500	Passed	Remediation has been completed
Enfield District Elementary	Classroom Washroom 103.1 Tap - 45	NNA838	0.0032	Passed	0.5700	Passed	Remediation has been completed
Enfield District Elementary	Classroom 104 - Tap - T47	PLL416	0.0021	Passed	0.1100	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom 124 Left Tap - T48	NNA841	0.0010	Passed	0.1900	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom 124 Middle Tap - T49	NNA842	0.0031	Passed	0.1900	Passed	Remediation has been completed
Enfield District Elementary	Female Washroom Right Tap - T50	NNA843	0.0017	Passed	0.2000	Passed	Remediation has been completed
Enfield District Elementary	Male Washroom 126 Left Tap - T51	NNA844	0.0015	Passed	0.1500	Passed	Remediation has been completed
Enfield District Elementary	Male Washroom 126 Middle Tap - T52	NNA845	0.0022	Passed	0.1400	Passed	Remediation has been completed
Enfield District Elementary	Male Washroom 126 Right Tap - T53	NNA846	0.0018	Passed	0.1400	Passed	Remediation has been completed
Enfield District Elementary	Classroom 106 Kitchen Tap - T54	NNA847	0.0028	Passed	0.2900	Passed	Remediation has been completed
Enfield District Elementary	Classroom 105 Kitchen Tap - T55	QSB939	0.0034	Passed	0.0320	Passed	Remediation has been completed
Enfield District Elementary	Washroom 129 - T56	NNA849	0.0057	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Enfield District Elementary	Classroom 103 Kitchen - T57	NNA850	0.0024	Passed	0.3300	Passed	Remediation has been completed
Enfield District Elementary	Bottle Filler by Gym, F1	PLL374	0.0000	Passed	0.0970	Passed	Remediation has been completed
Enfield District Elementary	Bottle Filler by Washroom , F4	PLL417	0.0010	Passed	0.1700	Passed	Remediation has been completed
F.H. MacDonald Academy	007 Bottle Filler A	MYX915	0.0006	Passed	0.3000	Passed	Remediation has been completed
F.H. MacDonald Academy	008 Room 112	MYX916	0.0180	Exceeds Limit	0.0290	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	010 Room 116	MYX917	0.0240	Exceeds Limit	0.0430	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	012 Room 118	MYX918	0.0120	Exceeds Limit	0.0300	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	014 Room 120	MYX919	0.0160	Exceeds Limit	0.0420	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	015 Room 121	MYX920	0.0120	Exceeds Limit	0.0180	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	017 Room 150 Left Sink	MYX921	0.0160	Exceeds Limit	0.3200	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	018 Room 150 Right Sink	MYX922	0.0300	Exceeds Limit	0.5500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	019 Kitchen Handwash Sink	MYX923	0.0140	Exceeds Limit	0.2400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	021 Kitchen Dish Spray Sink	MYX924	0.0200	Exceeds Limit	1.0000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	028 Bottle Filler B	MYX925	0.0000	Passed	0.2800	Passed	Remediation has been completed
F.H. MacDonald Academy	030 Room 159	MYX926	0.0400	Exceeds Limit	0.0086	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	032 Family Studies Sink B	MYX927	0.0350	Exceeds Limit	0.1100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	033 Family Studies Sink C	MYX928	0.0190	Exceeds Limit	0.0610	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	034 Family Studies Sink D	MYX929	0.0230	Exceeds Limit	0.3000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	035 Family Studies Sink E	MYX930	0.0250	Exceeds Limit	0.2500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	036 Family Studies Sink F	MYX931	0.0440	Exceeds Limit	0.0160	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	037 Family Studies Sink G	MYX932	0.0390	Exceeds Limit	0.0320	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	041 Arts/Science Sink A	MYX933	0.0057	Exceeds Limit	0.0210	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	042 Arts/Science Sink B	MYX934	0.0500	Exceeds Limit	0.0110	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	043 Arts/Science Sink C	MYX935	0.0430	Exceeds Limit	0.0360	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	044 Arts/Science Sink D	MYX936	0.0340	Exceeds Limit	0.0460	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	045 Room 212	MYX937	0.0230	Exceeds Limit	0.0150	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	046 Room 204	MYX938	0.0220	Exceeds Limit	0.0240	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	047 Room 204A	MYX939	0.0260	Exceeds Limit	0.0170	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	048 Room 204B	MYX940	0.0210	Exceeds Limit	0.0100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	049 Bottle Filler C	MYX941	0.0000	Passed	0.3500	Passed	Remediation has been completed
F.H. MacDonald Academy	053 Room 208	MYX942	0.0210	Exceeds Limit	0.0530	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	054 Room 208A	MYX943	0.0290	Exceeds Limit	0.0150	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	055 Room 208B	MYX944	0.0180	Exceeds Limit	0.0100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	056 Room 227	MYX945	0.0230	Exceeds Limit	0.0310	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	058 Room 225	MYX946	0.0460	Exceeds Limit	0.0120	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	060 Room 237	MYX947	0.0270	Exceeds Limit	0.0460	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	061 Room 237A	MYX948	0.0220	Exceeds Limit	0.0220	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	062 Room 215	MYX949	0.0280	Exceeds Limit	0.0360	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	065 Bottle Filler D	MYX950	0.0016	Passed	0.7400	Passed	Remediation has been completed
F.H. MacDonald Academy	066 Room 237B	MYX951	0.0170	Exceeds Limit	0.0120	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	071 Room 231	MYX952	0.0400	Exceeds Limit	0.0320	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	072 Room 240	MYX953	0.0360	Exceeds Limit	0.0360	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	073 Room 240A	MYX954	0.0210	Exceeds Limit	0.0360	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	074 Room 241	MYX955	0.0360	Exceeds Limit	0.0073	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	Back Water Room, T1	NFK561	0.0090	Exceeds Limit	0.0510	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
F.H. MacDonald Academy	Back Water Room 2nd Test, T1A	NFK562	0.0093	Exceeds Limit	0.0290	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
G.R. Saunders Elementary School	Bottle Filler Main Entry	LDE229	0.0000	Passed	0.0120	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
G.R. Saunders Elementary School	Kitchen Rm 126	LDE230	0.0000	Passed	0.0150	Passed	Remediation has been completed
G.R. Saunders Elementary School	Kitchen Sink	LDE231	0.0000	Passed	0.0190	Passed	Remediation has been completed
G.R. Saunders Elementary School	Bottle Filler 1st Floor	LDE232	0.0000	Passed	0.0330	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 007	LDE233	0.0000	Passed	0.1100	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 114	LDE234	0.0034	Passed	0.4000	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 006	LDE235	0.0006	Passed	0.2000	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 004 First Floor Hall Bottle Filler	OZH105	0.0014	Passed	0.0780	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 003	LDE237	0.0005	Passed	0.1500	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 005	LIQ313	0.0012	Passed	0.0820	Passed	Remediation has been completed
G.R. Saunders Elementary School	Bottle Filler 2nd Floor	OZH106	0.0013	Passed	0.2000	Passed	Remediation has been completed
G.R. Saunders Elementary School	Rm 215	LDE240	0.0000	Passed	0.0370	Passed	Remediation has been completed
G.R. Saunders Elementary School	Source Sample	LDE241	0.0011	Passed	0.0630	Passed	Remediation has been completed
G.R. Saunders Elementary School	Gym Room 116 Girls Bathroom Sink	NFD706	0.0013	Passed	0.0750	Passed	Remediation has been completed
G.R. Saunders Elementary School	Gym Room 116 Boys Bathroom Sink	NFD707	0.0000	Passed	0.0090	Passed	Remediation has been completed
G.R. Saunders Elementary School	Office Sink	NFD708	0.0000	Passed	0.0620	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Girls Bathroom A	NFD709	0.0000	Passed	0.0310	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Girls Bathroom B	NFD710	0.0000	Passed	0.0370	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Girls Bathroom C	NFD711	0.0010	Passed	0.0790	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Boys Bathroom A	NFD712	0.0000	Passed	0.0390	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Boys Bathroom B	NFD713	0.0000	Passed	0.0240	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Boys Bathroom C	NFD714	0.0032	Passed	0.2100	Passed	Remediation has been completed
G.R. Saunders Elementary School	Downstairs Boys Bathroom D	NFD715	0.0000	Passed	0.0930	Passed	Remediation has been completed
G.R. Saunders Elementary School	Custodial Closet Sink	NFD716	0.0006	Passed	0.0380	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Girls Bathroom A	NFD717	0.0006	Passed	0.0960	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Girls Bathroom B	NFD718	0.0000	Passed	0.0220	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Girls Bathroom C	NFD719	0.0010	Passed	0.0360	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Girls Bathroom D	NFD720	0.0000	Passed	0.0100	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink A	NFD721	0.0000	Passed	0.0270	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink B	NFD722	0.0000	Passed	0.0140	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink C	NFD723	0.0000	Passed	0.0110	Passed	Remediation has been completed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink D	NFD724	0.0000	Passed	0.0099	Passed	Remediation has been completed
G.R. Saunders Elementary School	Mechanical Room Sink	NFD725	0.0000	Passed	0.0083	Passed	Remediation has been completed
G.R. Saunders Elementary School	Custodial Closet Sink	NFD726	0.0000	Passed	0.0120	Passed	Remediation has been completed
Great Village Elementary School	Bottle Filler Main Floor	QEW135	0.0000	Passed	0.0025	Passed	Remediation has been completed
Great Village Elementary School	Bottle Filler Second Floor - Removed	LCP292	0.0780	Exceeds Limit	0.3100	Passed	Remediation has been completed
Great Village Elementary School	Kitchen Tap Staff Room	LCP293	0.0022	Passed	0.0920	Passed	Remediation has been completed
Great Village Elementary School	Bottle Filler by Gym	QEW136	0.0000	Passed	0.0041	Passed	Remediation has been completed
Great Village Elementary School	Tap Gym Kitchen	LCP295	0.0032	Passed	0.0010	Passed	Remediation has been completed
Great Village Elementary School	Raw Water Basement	LCP296	0.0009	Passed	0.0037	Passed	Remediation has been completed
Great Village Elementary School	Main boys washroom left, T1	NNA065	0.0000	Passed	0.0270	Passed	Remediation has been completed
Great Village Elementary School	Main Boys Washroom Mid, T2	NNA066	0.0082	Exceeds Limit	0.0260	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Main Boys Washroom Right, T3	NNA067	0.0110	Exceeds Limit	0.0260	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Custodial Sink, Rm 109, T4	NNA068	0.0018	Passed	0.0290	Passed	Remediation has been completed
Great Village Elementary School	Main Girls Washroom Left, T5	NNA069	0.0045	Passed	0.0300	Passed	Remediation has been completed
Great Village Elementary School	Main Girls Washroom Mid, T6	NNA070	0.0027	Passed	0.0022	Passed	Remediation has been completed
Great Village Elementary School	Main Girls Washroom Right, T7	NNA071	0.0120	Exceeds Limit	0.0260	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Staff Room Washroom Rm 205, T9	NNA072	0.0390	Exceeds Limit	0.0250	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Custodial Room 100, Gym Area, T10	NNA073	1.4000	Exceeds Limit	0.0260	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Boys Gym Washroom, left T11	NNA074	0.0320	Exceeds Limit	0.0460	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Boys Gym Washroom Mid left, T12	NNA075	0.0590	Exceeds Limit	0.0380	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Boys Gym Washroom Mid Right, T13	NNA076	0.0500	Exceeds Limit	0.0410	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Boys Gym Washroom Right, T14	NNA077	0.0400	Exceeds Limit	0.0240	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom Left, T15	NNA078	1.1000	Exceeds Limit	0.0270	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom, 2nd left, T16	NNA079	0.5100	Exceeds Limit	0.0230	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom, 3rd left, T17	NNA080	0.3400	Exceeds Limit	0.0250	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom, 3rd Right, T18	NNA081	0.3800	Exceeds Limit	0.0290	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom 2nd Right, T19	NNA082	0.1500	Exceeds Limit	0.0290	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Girls Gym Washroom Right, T20	NNA083	0.4100	Exceeds Limit	0.0270	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Hand Washing Tap, Gym Kitchen T22	NNA084	0.0640	Exceeds Limit	0.0180	Passed	Signage to be added to instruct handwashing only
Great Village Elementary School	Gym Office Washroom, T23	NNA085	0.5100	Exceeds Limit	0.0590	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Room 205 (Old Music Room) Kit. Tap T9	MUL956	0.0420	Exceeds Limit	0.1100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Hants East Rural High School	Cafeteria Main Kitchen Tap, T11	MUL957	0.0037	Passed	0.0580	Passed	Remediation has been completed
Hants East Rural High School	Room 211 Special Needs Kit. Tap, T21	MUL958	0.0063	Exceeds Limit	0.1100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Hants East Rural High School	Bottle Filler by Health Room 213, F1	POR995	0.0024	Passed	0.00055	Passed	Remediation has been completed
Hants East Rural High School	Art Room 225 Kit. Tap on Right, T41	MUL960	0.0750	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Art Room 225 Kit. Tap on Left, T42	MUL961	0.0100	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Art Room 227 Kit. Tap, T44	RDF184	0.0037	Passed	0.0530	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Hants East Rural High School	Bottle Filler Across from Room 227, F2	POR997	0.0024	Passed	0.00087	Passed	Remediation has been completed
Hants East Rural High School	CEP Kit. First Row Tap on Left, T46	POR998	0.0003	Passed	0.0950	Passed	Remediation has been completed
Hants East Rural High School	CEP Kit. First Row Tap on Right, T47	OFM989	0.0035	Passed	0.0410	Passed	Remediation has been completed
Hants East Rural High School	CEP Kit. 2nd Row Tap by Window, T48	OFM099	0.0034	Passed	0.2500	Passed	Remediation has been completed
Hants East Rural High School	Staff Room Kitchen Tap, T70	MUL967	0.0028	Passed	0.0490	Passed	Remediation has been completed
Hants East Rural High School	Bottle Filler by Room 317, F4	RDF187	0.0033	Passed	0.0850	Passed	Remediation has been completed
Hants East Rural High School	Bottle Filler in Upstairs Foyer, F5	POS001	0.0014	Passed	0.0790	Passed	Remediation has been completed
Hants East Rural High School	Schools Plus Kitchen Tap, T92	MUL970	0.0120	Exceeds Limit	0.0950	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Hants East Rural High School	L/F Girls Washroom, T1	NVG516	0.0018	Passed	0.0600	Passed	Remediation has been completed
Hants East Rural High School	L/F Trans Washroom, T2	NVG517	0.0032	Passed	0.1900	Passed	Remediation has been completed
Hants East Rural High School	M/F Girls by 204, Left, T4	NVG518	0.0800	Exceeds Limit	0.0910	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Girls by 204 Right, T5	NVG519	0.0063	Exceeds Limit	0.0590	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Main Floor Boys by Office Left, T6	NVG520	0.0046	Passed	0.0740	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Boys by Office Right, T7	NVG521	0.0031	Passed	0.0620	Passed	Remediation has been completed
Hants East Rural High School	Custodial by 203, T3	NVG522	0.0080	Exceeds Limit	0.0820	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Main Office Washroom, T8	NVG523	1.900	Exceeds Limit	0.0560	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Board Room Washroom by Front Entrance, T10	NVG524	0.0020	Passed	0.0600	Passed	Remediation has been completed
Hants East Rural High School	Cafeteria Kitchen Hand Wash Sink, T12	NVG525	0.0200	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Cafeteria Kitchen Washroom, T13	NVG526	0.0070	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Cafeteria Kitchen Dishwasher Sprayer, T14	NVG527	0.0030	Passed	0.2600	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Boys Washroom by 212 Left, T15	NVG528	0.0000	Passed	0.0850	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Boys Washroom by 212 Right, T16	NVG529	0.0038	Passed	0.0740	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Girls Trans by 212 Left, T17	NVG530	0.0017	Passed	0.0660	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Girls Trans by 212 Mid, T18	NVG531	0.0023	Passed	0.0700	Passed	Remediation has been completed
Hants East Rural High School	Main Floor Girls Trans by 212 Right, T19	NVG532	0.0026	Passed	0.0600	Passed	Remediation has been completed
Hants East Rural High School	Special Needs 211 Washroom, T20	NVG533	0.0032	Passed	0.0940	Passed	Remediation has been completed
Hants East Rural High School	Special Needs 211 Kitchen, T21	NVG534	0.0000	Passed	0.0700	Passed	Remediation has been completed
Hants East Rural High School	M/F Boys Washroom Past Special Needs LM, T23	NVG536	0.0170	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Boys Washroom Past Special Needs RM, T24	NVG537	0.0110	Exceeds Limit	0.0920	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Boys Washroom Past Needs Right, T25	NVG538	0.0210	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Girls Washroom Past Special Needs Left, T26	NVG539	0.0095	Exceeds Limit	0.0870	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Girls Washroom Past Needs Left Middle, T27	NVG540	0.0024	Passed	0.0820	Passed	Remediation has been completed
Hants East Rural High School	M/F Girls Washroom Past Special Needs Right Middle, T28	NVG541	0.0100	Exceeds Limit	0.0890	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	M/F Girls Washroom Past Special Needs Right, T29	NVG542	0.0140	Exceeds Limit	0.0880	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Custodial by Health Room, T30	NVG543	0.1400	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Health Room, T31	NVG544	0.0170	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Girls Washroom Left, T32	NVG545	0.0130	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Washroom Tap, T32B	POR996	0.0015	Passed	0.00036	Passed	Remediation has been completed
Hants East Rural High School	Foyer Girls Washroom Left Middle, T33	NVG546	0.0240	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Girls Washroom Right Middle, T34	NVG547	0.0140	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Girls Washroom Right, T35	NVG548	0.0170	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Girls Washroom Left, T36	NVG549	0.0083	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Boys Washroom Middle, T37	NVG550	0.0093	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Foyer Boys Washroom Right, T38	NVG551	0.0081	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Stage Sink, T39	NVG552	0.0540	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Custodial by 225, T40	NVG553	0.0610	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Girls Locker 228 Left, T49	NVG557	0.0046	Passed	0.1400	Passed	Remediation has been completed
Hants East Rural High School	Girls Locker 228 Right, T50	NVG558	0.0049	Passed	0.1200	Passed	Remediation has been completed
Hants East Rural High School	Boys Locker 233 Left, T51	NVG559	0.0110	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Boys Locker 233 Right, T52	NVG560	0.0046	Passed	0.1300	Passed	Remediation has been completed
Hants East Rural High School	Gym Office S. Wolfe Right, T53	NVG561	0.0110	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Gym Office R. Devries Left, T54	NVG562	0.0140	Exceeds Limit	0.0940	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Girls Washroom Left, T55	NVG563	0.0620	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Girls Washroom Right, T56	NVG564	0.0300	Exceeds Limit	0.0850	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Custodial, T57	NVG565	0.0270	Exceeds Limit	0.0920	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Boys Washroom Left, T58	NVG566	0.0023	Passed	0.0360	Passed	Remediation has been completed
Hants East Rural High School	Basement Boys Washroom Right, T59	NVG567	0.0094	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Room 107 Working, T60	POR999	0.0150	Exceeds Limit	0.0061	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Room 111, T63	NVG569	0.0400	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Room 113, T64	NVG570	0.1500	Exceeds Limit	0.3700	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Top Floor Girls by Room 304 Left, T65	NVG571	0.0092	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Top Floor Girls by Room 304 Right, T66	NVG572	0.0240	Exceeds Limit	0.0900	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Top Floor Boys by Room 304 Left, T67	NVG573	0.0089	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Top Floor Boys by Room 304 Right, T68	NVG574	0.0440	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Staff Room by Girls Washroom, T69	NVG575	0.0010	Passed	0.0870	Passed	Remediation has been completed
Hants East Rural High School	Staff Room Mens Washroom, T71	NVG576	0.0069	Exceeds Limit	0.0820	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Hall Staff Washroom Mens Washroom Right, T72	NVG577	0.0022	Passed	0.0800	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Hants East Rural High School	Hall Staff Washroom Mens Washroom Left, T73	NVG578	0.0032	Passed	0.0720	Passed	Remediation has been completed
Hants East Rural High School	Custodial by Mens Washroom not working, T74	NVG579	0.2200	Exceeds Limit	0.6800	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Hall Staff Washroom Girls Washroom Left, T75	NVG580	0.0023	Passed	0.0760	Passed	Remediation has been completed
Hants East Rural High School	Hall Staff Washroom Girls Washroom Middle, T76	NVG581	0.0027	Passed	0.0910	Passed	Remediation has been completed
Hants East Rural High School	Hall Staff Washroom Girls Washroom Right, T77	NVG582	0.0040	Passed	0.0830	Passed	Remediation has been completed
Hants East Rural High School	Top Floor Boys Washroom by Custodial Right, T78	NVG583	0.0410	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Boys Washroom by Custodial Middle, T79	NVG584	0.0033	Passed	0.0910	Passed	Remediation has been completed
Hants East Rural High School	Top Floor Boys Washroom by Custodial Left, T80	NVG585	0.0098	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Custodial, T81	NVG586	0.0200	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Girls Washroom around corner Left, T82	NVG587	0.0430	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Girls Washroom around corner Middle, T83	NVG588	0.0240	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Top Floor Girls Washroom around corner Right, T84	NVG589	0.0180	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Girls Washroom by Labs Left, T85	NVG590	0.0410	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Girls Washroom by Labs Middle, T86	NVG591	0.0310	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Girls Washroom by Labs Right, T87	NVG592	0.0170	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Boys Washroom by Labs Left, T88	NVG593	0.0110	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Boys Washroom by Labs Middle, T89	NVG594	0.0340	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Boys Washroom by Labs Left, T90	NVG595	0.0130	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Custodial Brian, T91	NVG596	0.0150	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Schools Plus Kitchen Sink, T92	OFM991	0.0044	Passed	0.0360	Passed	Remediation has been completed
Hants East Rural High School	Schools Plus Washroom Right, T93	NVG598	0.0180	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Schools Plus Washroom Left, T94	NVG599	0.0097	Exceeds Limit	0.0940	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 323 Front Sink, T114	NVG600	0.0290	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 325 in Front, T115	NVG601	0.1700	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 327 Front Island, T116	NVG602	0.0480	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 329 in Front Island, T129	NVG603	0.0440	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 329 in Row 3 Right, T142	NVG604	0.0100	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Lab 329 in Row 3 Left, T143	NVG605	0.0580	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	CEP Kitchen T45	NVG606	0.0082	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Hants East Rural High School	Basement Room 109, T62	POS000	0.0370	Exceeds Limit	0.0120	Passed	Remediation has been completed
Hants East Rural High School	Room 229 New Laundry Tap, T229	RDF185	0.0017	Passed	0.7500	Passed	Remediation has been completed
Hants East Rural High School	New Bottle Fille in AV Foyer, F3	RNL332	0.0006	Passed	0.6600	Passed	Remediation has been completed
Hants East Rural High School	Room 237 Skilled Trades New Laundry Tap, T237	QND352	0.0120	Exceeds Limit	0.0067	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	New Bottle Filler Main Gym, F7	OLP027	0.0000	Passed	0.1200	Passed	Remediation has been completed
Hants North Rural High School	Large Sink by Door in HE Rm 123, T72	LEK493	0.0190	Exceeds Limit	0.3800	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Hants North Rural High School	Sink on Left in HE Room 123, T73	LEK494	0.0027	Passed	0.1800	Passed	Remediation has been completed
Hants North Rural High School	Sink on Left Centre in HE Rm 123, T74	LEK495	0.0045	Passed	0.2800	Passed	Remediation has been completed
Hants North Rural High School	Sink on Right Centre in HE Rm 123, T75	OLP028	0.0022	Passed	0.0480	Passed	Remediation has been completed
Hants North Rural High School	Sink on Right in HE Rm 123, T76	OLP029	0.0024	Passed	0.0480	Passed	Remediation has been completed
Hants North Rural High School	Main Kitchen Sink Room 124, T77	OLP030	0.0043	Passed	0.3600	Passed	Remediation has been completed
Hants North Rural High School	Kitchen Hand Washing Sink Rm 124, T78	OLP031	0.0038	Passed	0.0300	Passed	Remediation has been completed
Hants North Rural High School	Kitchen Sink Rm 121, T43	OLP032	0.0010	Passed	0.0210	Passed	Remediation has been completed
Hants North Rural High School	Bottle Filler by Sprinkler Room 119, Rm F6	LEK552	0.0040	Passed	0.1100	Passed	Remediation has been completed
Hants North Rural High School	Sink in Primary Room 109, T36	LEK553	0.0027	Passed	0.1800	Passed	Remediation has been completed
Hants North Rural High School	Sink in Lunch Room 116, T35	LEK554	0.0100	Exceeds Limit	0.1800	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Hants North Rural High School	Sink in Room 110, T34	OLP33	0.0019	Passed	0.0290	Passed	Remediation has been completed
Hants North Rural High School	Sink in Room 115, T38	LEK556	0.0044	Passed	0.1300	Passed	Remediation has been completed
Hants North Rural High School	Bottle Filler Outside Staff Room 114, F4	LEK558	0.0035	Passed	0.2100	Passed	Remediation has been completed
Hants North Rural High School	Staff Room Elementary 114, T33	OLP034	0.0017	Passed	0.0230	Passed	Remediation has been completed
Hants North Rural High School	Staff Room Upstairs 230, T9	OLP035	0.0009	Passed	0.0240	Passed	Remediation has been completed
Hants North Rural High School	Bottle Filler Upstairs by Room 235, F1	LEK563	0.0051	Passed	0.1200	Passed	Remediation has been completed
Hants North Rural High School	Bottle Filler Upstairs by GW Rm 222, F2	LEK564	0.0019	Passed	0.0640	Passed	Remediation has been completed
Hants North Rural High School	New Bottle Filler by Room 212, F3	LEK565	0.0000	Passed	0.0580	Passed	Remediation has been completed
Hants North Rural High School	Raw Water Boiler Rm Old Well	NWL486	0.0000	Passed	0.0044	Passed	Remediation has been completed
Hants North Rural High School	Lower Floor Woodworking Shop 100, T66	NWL487	0.0042	Passed	0.0390	Passed	Remediation has been completed
Hants North Rural High School	LF, Custodial Room by Computer Lab, Room 141, T65	NWL488	0.0250	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 1, by DR1, T48	NWL489	0.1600	Exceeds Limit	0.8900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 1, by DR2, T49	NWL490	0.0680	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 1 by DR3, T50	NWL491	0.0910	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row by DR4, T51	NWL492	0.1200	Exceeds Limit	0.4500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row by DR5, T52	NWL493	0.0790	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row by DR6, T53	NWL494	0.0970	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row by DR7, T54	NWL495	0.2200	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row by DR8, T55	NWL496	0.3200	Exceeds Limit	0.9000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Back Island, T56	NWL497	0.0930	Exceeds Limit	0.7300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR1, T57	NWL498	0.0360	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR2, T58	NWL499	0.0600	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR3, T59	NWL500	0.2500	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR4, T60	NWL501	0.1200	Exceeds Limit	0.5100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR5, T61	NWL502	0.0590	Exceeds Limit	0.3600	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR6, T62	NWL503	0.0320	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR7, T63	NWL504	0.0760	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Chem Lab, 103, Row 2, by DR8, T64	NWL505	0.3000	Exceeds Limit	1.2000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Hallway Bottle Filler, By Room 130, F8	NWL829	0.0041	Passed	0.0500	Passed	Remediation has been completed
Hants North Rural High School	LF, Physics Lab, 105, Counter Sinks Left, T44	NWL830	0.0340	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Physics Lab, 105, Counter Sinks Left Mid, T45	NWL831	0.0070	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Physics Lab, 105, Counter Sinks Right, T46	NWL832	0.0180	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Physics Lab, 105 Island Sink, T47	NWL833	0.0150	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Custodial Room T38	NWL834	0.0220	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Left, T39	NWL835	0.0098	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Mid Left, T40	NWL836	0.0140	Exceeds Limit	0.7500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Mid Right, T41	NWL837	0.0094	Exceeds Limit	0.5400	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Right, T42	NWL838	0.0150	Exceeds Limit	0.8300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Staff Washroom, T32	NWL839	0.0220	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Left, T34	NWL506	0.0180	Exceeds Limit	0.6300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Mid Left, T35	NWL507	0.0230	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Mid Right, T36	NWL508	0.0410	Exceeds Limit	0.5500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Girls Washroom, Right, T37	NWL509	0.0120	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF, Custodial Room, Understairs, T31	NWL510	0.0300	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Custodial Room, by Office, T2	NWL511	0.0430	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Mens Washroom 228, by Staff Room, T7	NWL512	0.0180	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Womens Washroom 229 by Staff Room, T8	NWL513	0.0190	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom 225, Left T15	NWL514	0.0250	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom 225, Mid Left T16	NWL515	0.0260	Exceeds Limit	0.9500	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom 225, Mid Right T17	NWL516	0.0200	Exceeds Limit	0.7000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom 225, Right, T18	NWL517	0.0120	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Girls Washroom 222, Left, T19	NWL518	0.0230	Exceeds Limit	0.8400	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Girls Washroom 222, Mid Left, T20	NWL519	0.0067	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Girls Washroom 222, Mid Right, T21	NWL520	0.0065	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Girls Washroom 222, Right, T22	NWL521	0.0082	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Custodial Room, Girls 222, T23	NWL522	0.0230	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Custodial Room, 212, T26	NWL523	0.0770	Exceeds Limit	0.0900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom Left, T27	NWL524	0.0098	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom Mid Left, T28	NWL525	0.0110	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom Mid Right, T29	NWL526	0.0140	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF, Boys Washroom Right, T30	NWL527	0.0097	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	Well Source Kennebec # 2010- 071438	NWL528	0.0000	Passed	0.0000	Passed	n/a
Hants North Rural High School	LF Computer Lab 141, T67	NWL395	0.0530	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Girls Locker Room, WR T70	NWL449	0.0076	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Boys Locker Room, WR T71	NWL450	0.0300	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Boys Washroom 133, Left, T79	NWL451	0.0047	Passed	0.2700	Passed	Remediation has been completed
Hants North Rural High School	LF Boys Washroom 133 Right, T80	NWL452	0.0032	Passed	0.2900	Passed	Remediation has been completed
Hants North Rural High School	LF Custodial Room 132, T81	NWL453	0.0049	Passed	0.2300	Passed	Remediation has been completed
Hants North Rural High School	LF Girls Washroom 131, Left, T82	NWL454	0.0100	Exceeds Limit	0.4800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Girls Washroom 131, right, T83	NWL455	0.0120	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	LF Student Support, 118, T37A	NWL456	0.0070	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Office WR, T1	NWL457	0.0085	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Girls Washroom by Office, Left, T3	NWL458	0.0049	Passed	0.4500	Passed	Remediation has been completed
Hants North Rural High School	UF Girls Washroom by Office, Mid Left, T4	NWL459	0.0050	Passed	0.5800	Passed	Remediation has been completed
Hants North Rural High School	UF Girls Washroom by Office, Mid Right T5	NWL460	0.0150	Exceeds Limit	0.9300	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Girls Washroom by Office, Right, T6	NWL461	0.0140	Exceeds Limit	0.6600	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Boys Washroom Across from 231, Left, T10	NWL462	0.0084	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Boys Washroom Across from 231, Right, T11	NWL463	0.0110	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Custodial Room 237, T12	NWL464	0.0140	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Girls Washroom Across from 231, Left, T13	NWL465	0.0093	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Girls Washroom Across from 231, Right, T14	NWL466	0.0110	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	UF Custodial Room 219, WR, T25	NWL467	0.0160	Exceeds Limit	1.6000	Passed	Signage to be added to instruct handwashing only
Hants North Rural High School	Raw Water Boil Room	NWL468	0.1300	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Harmony Heights Elementary School	Music Room 129, T2	MQE345	0.0032	Passed	0.1600	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 127 First Tap on Right, T3	MQE346	0.0010	Passed	0.1600	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 127 Second Tap on Right, T4	MQE347	0.0000	Passed	0.1400	Passed	Remediation has been completed
Harmony Heights Elementary School	Staff Room Kitchen Tap on Left, T22	MQE348	0.0000	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	New Bottle Filler Replaced Bottle Filler Near Staff Room, F2	PCS370	0.0000	Passed	0.1300	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 117 Tap Behind Sliding Wall, T24	MQE350	0.0010	Passed	0.1600	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Harmony Heights Elementary School	Room 117 Kitchen Tap on Left, T25	PCS371	0.0019	Passed	0.4200	Passed	Remediation has been completed
Harmony Heights Elementary School	Library Room 105 Kitchen Tap, T12	MQE352	0.0046	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	New Bottle Filler Replaced Bottle Filler by Gym Entrance, F1	PCS372	0.0020	Passed	0.3700	Passed	Remediation has been completed
Harmony Heights Elementary School	Recycle Room 136 Tap, T26	MQE354	0.0007	Passed	0.2000	Passed	Remediation has been completed
Harmony Heights Elementary School	Main Kitchen Sink on Right, T28	MQE355	0.0006	Passed	0.1900	Passed	Remediation has been completed
Harmony Heights Elementary School	Main Kitchen Sink in Island, T29	NVA046	0.0000	Passed	0.1700	Passed	Remediation has been completed
Harmony Heights Elementary School	New Bottle Filler Bottle Filler Near Office North Wing, F3	PC381	0.0008	Passed	0.2900	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 147, Kitchen Sink, T41	MQE358	0.0000	Passed	0.1000	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 159, Kitchen Sink, T39	MQE359	0.0010	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 148, Kitchen Sink, T42	MQE360	0.0044	Passed	0.1000	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 158, Kitchen Sink, T43	MQE361	0.0009	Passed	0.1400	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 150, Kitchen Sink, T45	MQE362	0.0008	Passed	0.1000	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 155, Kitchen Sink, T47	MQE363	0.0007	Passed	0.1200	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 152, Kitchen Sink, T48	MQE364	0.0010	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Room 153, Kitchen Sink, T49	MQE365	0.0006	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	Boiler Room, T1	NVA028	0.0007	Passed	0.1300	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Locker Room, 1st Sink, T5	NVA029	0.0017	Passed	0.1700	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Locker Room 2nd Sink, T56	NVA030	0.0016	Passed	0.1700	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Locker Accessible Washroom, T7	NVA031	0.0710	Exceeds Limit	0.7400	Passed	Signage to be added to instruct handwashing only
Harmony Heights Elementary School	Gym Office by Girls Locker, T8	NVA032	0.0005	Passed	0.3100	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Locker Sink, T9	NVA033	0.0012	Passed	0.2400	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Left, T13	NVA034	0.0005	Passed	0.1800	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Middle, T14	NVA035	0.0000	Passed	0.2400	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Right, T15	NVA036	0.0008	Passed	0.2000	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Right, T16	NVA037	0.0006	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Middle, T17	NVA038	0.0012	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Left, T18	NVA039	0.0008	Passed	0.1400	Passed	Remediation has been completed
Harmony Heights Elementary School	Custodial South Floor Sink Left, T19	NVA040	0.0035	Passed	0.2300	Passed	Remediation has been completed
Harmony Heights Elementary School	Custodial South Floor Sink Right, T19A	NVA041	0.0013	Passed	0.1900	Passed	Remediation has been completed
Harmony Heights Elementary School	Staff Washroom Mens, T20	NVA042	0.0000	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Staff Washroom Female, T21	NVA043	0.0000	Passed	0.1100	Passed	Remediation has been completed
Harmony Heights Elementary School	Handicap Washroom, T23	NVA044	0.0000	Passed	0.1300	Passed	Remediation has been completed
Harmony Heights Elementary School	Handicap Handwash Sink, T29A	NVA045	0.0023	Passed	0.2900	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Cafeteria Hall Left, T30	NVA047	0.0006	Passed	0.1600	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Cafeteria Hall Middle, T31	NVA048	0.0010	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	Boys Washroom Cafeteria Hall Right, T32	NVA049	0.0008	Passed	0.1700	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Cafeteria Hall Left, T33	NVA050	0.0010	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Cafeteria Hall Middle, T34	NVA051	0.0009	Passed	0.1400	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Cafeteria Hall Right, T35	NVA052	0.0014	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	Girls Washroom Cafeteria Hall Far Right, T35B	NVA053	0.0012	Passed	0.1700	Passed	Remediation has been completed
Harmony Heights Elementary School	Sick Room Washroom Office Area, T36	NVA054	0.0000	Passed	0.1500	Passed	Remediation has been completed
Harmony Heights Elementary School	Handicap Washroom by Office, T37	NVA055	0.0000	Passed	0.1400	Passed	Remediation has been completed
Harmony Heights Elementary School	Classroom 159 Washroom, T38	NVA056	0.0000	Passed	0.1200	Passed	Remediation has been completed
Harmony Heights Elementary School	Classroom 147 Washroom, T40	NVA057	0.0000	Passed	0.1300	Passed	Remediation has been completed
Harmony Heights Elementary School	Classroom Washroom 149, T40B	NVA058	0.0000	Passed	0.1800	Passed	Remediation has been completed
Harmony Heights Elementary School	Custodial Closet by Room 149 Left, T44	NVA059	0.0010	Passed	0.1800	Passed	Remediation has been completed
Harmony Heights Elementary School	Custodial Closet by Room 149 Right, T44B	NVA060	0.0058	Exceeds Limit	0.3900	Passed	Signage to be added to instruct handwashing only
Harmony Heights Elementary School	Penthouse Laundry Sink Left, T50	NVA061	0.0007	Passed	0.2200	Passed	Remediation has been completed
Harmony Heights Elementary School	Penthouse Laundry Sink Right, T50B	NVA062	0.0005	Passed	0.1900	Passed	Remediation has been completed
Hilden Elementary School	Staff Rm Kitchen Sink, T1	NZB522	0.0039	Passed	0.0180	Passed	Remediation has been completed
Hilden Elementary School	Learning Centre Sink, T17	QEV958	0.0021	Passed	0.0014	Passed	Remediation has been completed
Hilden Elementary School	Bottle Filler Replaced Bottle Filler by LC, F1	OYM669	0.0013	Passed	0.0550	Passed	Remediation has been completed
Hilden Elementary School	Sink in Room 107, T9	NZB523	0.0029	Passed	0.0013	Passed	Remediation has been completed
Hilden Elementary School	Sink in Room 106, T10	QEV960	0.0012	Passed	0.0008	Passed	Remediation has been completed
Hilden Elementary School	Sink in Room 105, T11	QEV961	0.00093	Passed	0.0014	Passed	Remediation has been completed
Hilden Elementary School	Bottle Filler Replaced Bottle Filler by Room 135, F2	PIJ404	0.0026	Passed	0.0260	Passed	Remediation has been completed
Hilden Elementary School	Kitchen Sink, T13	MQS985	0.0034	Passed	0.0850	Passed	Remediation has been completed
Hilden Elementary School	Staff Washroom Tap, T2	NPL473	0.0049	Passed	0.0520	Passed	Remediation has been completed
Hilden Elementary School	Boys Washroom Tap Left, T5	NPL475	0.1100	Exceeds Limit	0.0390	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Boys Washroom Tap Middle, T4	NPL476	0.0043	Passed	0.0510	Passed	Remediation has been completed
Hilden Elementary School	Boys Washroom Tap Right, T3	NPL477	0.0420	Exceeds Limit	0.0970	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Custodial Room Tap, T6	NPL478	0.0110	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Room 107 Washroom Tap, T8A	NPL479	0.0160	Exceeds Limit	0.0460	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Room 107 Kitchen Tap, T9A	QEV959	0.00087	Passed	0.0011	Passed	Remediation has been completed
Hilden Elementary School	Girls Washroom Tap Left, T7	NPL481	0.0039	Passed	0.0730	Passed	Remediation has been completed
Hilden Elementary School	Girls Washroom Tap Middle, T8	NPL482	0.0021	Passed	0.0330	Passed	Remediation has been completed
Hilden Elementary School	Main Kitchen Handwash Tap, T12	NPL486	0.0500	Exceeds Limit	0.0230	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Hilden Elementary School	Boys Changing Room Tap, T16	NPL487	0.0170	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Gym Office Washroom Tap, T15	NPL488	0.0200	Exceeds Limit	0.0370	Passed	Signage to be added to instruct handwashing only
Hilden Elementary School	Girls Changing Room Tap, T14	NPL489	0.0190	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Junction Road Elementary School	Bottle Filler	PJY785	0.0015	Passed	0.1400	Passed	Remediation has been completed
Junction Road Elementary School	Raw Water Source	LIA065	0.0006	Passed	0.0230	Passed	Remediation has been completed
Junction Road Elementary School	Staff Room Tap	LEU321	0.0014	Passed	0.4000	Passed	Remediation has been completed
Junction Road Elementary School	Girls #1	NEE675	0.0000	Passed	0.0270	Passed	Remediation has been completed
Junction Road Elementary School	Girls #2	NEE676	0.0000	Passed	0.0290	Passed	Remediation has been completed
Junction Road Elementary School	Girls #3	NEE677	0.0000	Passed	0.0270	Passed	Remediation has been completed
Junction Road Elementary School	Custodial by Office	NEE678	0.0000	Passed	0.0270	Passed	Remediation has been completed
Junction Road Elementary School	Boys #1	NEE679	0.0000	Passed	0.0370	Passed	Remediation has been completed
Junction Road Elementary School	Boys #2	NEE680	0.0000	Passed	0.0360	Passed	Remediation has been completed
Junction Road Elementary School	Boys #3	NEE681	0.0000	Passed	0.0330	Passed	Remediation has been completed
Junction Road Elementary School	Boys #4	NEE682	0.0000	Passed	0.0320	Passed	Remediation has been completed
Junction Road Elementary School	Staff #1	NEE683	0.0011	Passed	0.0300	Passed	Remediation has been completed
Junction Road Elementary School	Staff #2	NEE684	0.0000	Passed	0.0330	Passed	Remediation has been completed
Junction Road Elementary School	Washroom #1	NEE685	0.0000	Passed	0.1500	Passed	Remediation has been completed
Junction Road Elementary School	Washroom #2	NEE686	0.0000	Passed	0.1500	Passed	Remediation has been completed
Junction Road Elementary School	Custodial by Library	NEE687	0.0000	Passed	0.1300	Passed	Remediation has been completed
Kennetcook District Elementary School	Resource Room 118, T37	LEK666	0.0052	Passed	0.3200	Passed	Remediation has been completed
Kennetcook District Elementary School	Janitor Washroom Rm 219 T25	LEK667	0.0099	Exceeds Limit	0.8100	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Raw Water Boiler Rm New Well	LEK668	0.9100	Exceeds Limit	0.0001	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Kennetcook District Elementary School	Computer Lab 141, T67	NWL395	0.0530	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Locker Room Washroom, T70	NWL449	0.0076	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Boys Locker Room Washroom, T71	NWL450	0.0300	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Boys Washroom 133 Left, T79	NWL451	0.0047	Passed	0.2700	Passed	Remediation has been completed
Kennetcook District Elementary School	Boys Washroom 133 Right, T80	NWL452	0.0032	Passed	0.2900	Passed	Remediation has been completed
Kennetcook District Elementary School	Custodial Room 132, T81	NWL453	0.0049	Passed	0.2300	Passed	Remediation has been completed
Kennetcook District Elementary School	Girls Washroom 131 Left, T82	NWL454	0.0100	Exceeds Limit	0.4800	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Washroom 131 Right, T83	NWL455	0.0120	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Student Support 118, T37A	NWL456	0.0070	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Office, T1	NWL457	0.0085	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Washroom by Office Left, T3	NWL458	0.0049	Passed	0.4500	Passed	Remediation has been completed
Kennetcook District Elementary School	Girls Washroom by Office Left Middle, T4	NWL459	0.0050	Passed	0.5800	Passed	Remediation has been completed
Kennetcook District Elementary School	Girls Washroom by Office Right Middle, T5	NWL460	0.0150	Exceeds Limit	0.9300	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Washroom by Office Right, T6	NWL461	0.0140	Exceeds Limit	0.6600	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Boys Washroom Across from 231 Left, T10	NWL462	0.0084	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Boys Washroom Across from 231 Right, T11	NWL463	0.0110	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Custodial Room 237, T12	NWL464	0.0140	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Washroom Across from 231 Left, T13	NWL465	0.0093	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Girls Washroom Across from 231 Right, T14	NWL466	0.0110	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Custodial Room 219 Washroom, T25	NWL467	0.0160	Exceeds Limit	1.6000	Passed	Signage to be added to instruct handwashing only
Kennetcook District Elementary School	Raw Water in Boiler Room	NWL468	0.1300	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Rm 152 Kitchen Tap, T1	MRG529	0.0097	Exceeds Limit	0.0740	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Maple Ridge Elementary School	Bottle Filler Outside Music Room, F1	PEJ134	0.0023	Passed	0.0710	Passed	Remediation has been completed
Maple Ridge Elementary School	Music Rm 148, Kitchen Tap, T12	PEJ135	0.0098	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Art Room 145, T14	MRG532	0.0043	Passed	0.2700	Passed	Remediation has been completed
Maple Ridge Elementary School	Kitchen Dishwashing Tap, T15	PEJ136	0.0071	Exceeds Limit	0.0900	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Kitchen Handwashing Tap, T16	MRG534	0.0049	Passed	0.0930	Passed	Remediation has been completed
Maple Ridge Elementary School	Kitchen Main Tap, T17	MRG535	0.0026	Passed	0.0610	Passed	Remediation has been completed
Maple Ridge Elementary School	Staff Room, Kitchen Tap, T23	MRG536	0.0025	Passed	0.1200	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-1/206 Kitchen Tap, T33	PEJ138	0.0013	Passed	0.0950	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-2/203 Kitchen Tap, T36	MRG538	0.0035	Passed	0.1700	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-3/201 Kitchen Tap, T42	MRG539	0.0029	Passed	0.1800	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-4/198 Kitchen Tap, T44	MRG540	0.0048	Passed	0.1800	Passed	Remediation has been completed
Maple Ridge Elementary School	LC Room A-8/189, Kitchen Tap, T37	MRG541	0.0048	Passed	0.2000	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-7/191 Kitchen Tap T38	PEJ139	0.0013	Passed	0.0740	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-6/193 Kitchen Tap, T40	MRG543	0.0013	Passed	0.0920	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-5/196 Kitchen Tap, T41	MRG544	0.0065	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Bottle Filler By Girls Washroom, 142, F2	PEJ137	0.0010	Passed	0.1600	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-1/206 F3	MSH256	0.0000	Passed	0.1100	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-2/203 F4	MSH257	0.0000	Passed	0.0930	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-3/201, F8	MSH258	0.0005	Passed	0.0910	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-4/198, F6	MSH259	0.0000	Passed	0.1100	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-8/189 F5	MSH260	0.0008	Passed	0.2000	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-7/191, F6	MSH261	0.0000	Passed	0.0600	Passed	Remediation has been completed
Maple Ridge Elementary School	Room A-6/193 F7	MSH262	0.0000	Passed	0.0580	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Maple Ridge Elementary School	Room A-5/196 F10	MSH263	0.0007	Passed	0.1900	Passed	Remediation has been completed
Maple Ridge Elementary School	North Change Room 156 Left Tap, T2	NGT279	0.0380	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	North Change Room 156 Right Tap, T3	NGT280	0.0490	Exceeds Limit	0.4700	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	South Change Room 157, Left Tap, T4	NGT281	0.0350	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	South Change Room 157, Right Tap, T5	NGT282	0.0340	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Maintenance Storage 158, T6	NGT283	0.0022	Passed	0.1700	Passed	Remediation has been completed
Maple Ridge Elementary School	Boy's Change Room 160, Left Tap, T7	NGT284	0.0048	Passed	0.1900	Passed	Remediation has been completed
Maple Ridge Elementary School	Boy's Change Room 160, Right Tap, T8	NGT285	0.0150	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Girl's Change Room 161, Left Tap, T9	NGT286	0.0051	Passed	0.1900	Passed	Remediation has been completed
Maple Ridge Elementary School	Girl's Change Room 161, Right Tap, T10	NGT287	0.0180	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Gym Office 162, T11	NGT288	0.0039	Passed	0.1900	Passed	Remediation has been completed
Maple Ridge Elementary School	Janitors Closet 147 Cust. Floor Sink, T13	NGT289	0.0018	Passed	0.1000	Passed	Remediation has been completed
Maple Ridge Elementary School	Boys Washroom 143 Left Tap, T18	NGT290	0.0023	Passed	0.1700	Passed	Remediation has been completed
Maple Ridge Elementary School	Boys Washroom 143 Right Tap, T19	NGT291	0.0100	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Girls Washroom 142 Left Tap, T20	NGT292	0.0061	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Girls Washroom 142 Right Tap, T20A	NGT293	0.0037	Passed	0.1700	Passed	Remediation has been completed
Maple Ridge Elementary School	Staff Room Washroom 116, T21	NGT294	0.0075	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Staff Room Washroom 115, T22	NGT295	0.0062	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Washroom 109 Main Office T24	NGT296	0.0060	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Sick Room Main Office, T25	NGT297	0.0091	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Wash Up Room 118, T26	NGT298	0.0370	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Girls Washroom 179 Left Tap, T27	NGT299	0.0110	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Girls Washroom 179 Right Tap, T28	NGT300	0.0081	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Boys Washroom 180 Left Tap, T29	NGT301	0.0035	Passed	0.1100	Passed	Remediation has been completed
Maple Ridge Elementary School	Boys Washroom 180 Right Tap, T30	NGT302	0.0019	Passed	0.1300	Passed	Remediation has been completed
Maple Ridge Elementary School	Everyone Washroom 183, T31	NGT303	0.0077	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Janitors Closet 182, T32	NGT304	0.0037	Passed	0.0970	Passed	Remediation has been completed
Maple Ridge Elementary School	Washroom 207 Classroom A-1/206, T34	NGT305	0.0065	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Washroom 204 Classroom A-2/203, T35	NGT306	0.0037	Passed	0.1300	Passed	Remediation has been completed
Maple Ridge Elementary School	Washroom 192 Classroom A-7/191, T39	NGT307	0.0033	Passed	0.1200	Passed	Remediation has been completed
Maple Ridge Elementary School	Washroom 194 Classroom A-6/193, T40A	NGT308	0.0026	Passed	0.1200	Passed	Remediation has been completed
Maple Ridge Elementary School	Washroom 202 Classroom A-3/201, T43	NGT309	0.0013	Passed	0.0730	Passed	Remediation has been completed
Maple Ridge Elementary School	Washroom 199 Classroom A-4/198, T45	NGT310	0.0059	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Maple Ridge Elementary School	Wash Up/Storage 197, T46	NGT311	0.0390	Exceeds Limit	0.0870	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1016 Sick Rm Sink	NNH543	0.0410	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1019 Admin Washroom Sink	NNH544	0.0230	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Kitchen Double Sink	NNH545	0.0250	Exceeds Limit	0.1800	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Kitchen Sprayer	NNH546	0.0031	Passed	0.1000	Passed	Remediation has been completed
McCulloch Education Centre	Kitchen Handwash Sink	NNH547	0.0150	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Boys Washroom Sink A	NNH548	0.0190	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Boys Washroom Sink B	NNH549	0.0160	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Boys Washroom Sink C	NNH550	0.0270	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1025 Girls Washroom Sink A	NNH551	0.0430	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1025 Girls Washroom Sink B	NNH552	0.0360	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1025 Girls Washroom Sink C	NNH553	0.0360	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Library Sink	NNH554	0.0370	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1028 Boys Washroom Sink A	NNH555	0.0210	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1028 Boys Washroom Sink B	NNH556	0.0250	Exceeds Limit	0.4500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Gym Office Sink	NNH557	0.0820	Exceeds Limit	0.4900	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Male Change Rm Sink	NNH558	0.0260	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Female Change Rm Sink	NNH559	0.0480	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1037 Custodial Closet Sink	NNH560	0.2700	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1038 Recycle Rm Sink	NNH561	0.0025	Passed	0.1900	Passed	Remediation has been completed
McCulloch Education Centre	Rm 1047 Music Rm Sink	NNH562	0.0610	Exceeds Limit	0.2100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1050 Staff Rm Kitchen Sink	NNH563	0.0040	Passed	0.1700	Passed	Remediation has been completed
McCulloch Education Centre	Rm 1052 Staff Washroom Sink	NNH564	0.0077	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1053 Staff Washroom Sink	NNH565	0.0055	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1054 Classroom Sink	NNH566	0.0083	Exceeds Limit	0.2200	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1057 Classroom Sink	NNH567	0.0200	Exceeds Limit	0.1700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1061 Classroom Sink	NNH568	0.0045	Passed	0.1900	Passed	Remediation has been completed
McCulloch Education Centre	Rm 1062 Classroom Sink	NNH569	0.0930	Exceeds Limit	1.2000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1063 Lab Sink	NNH570	0.0150	Exceeds Limit	0.5200	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1064 Classroom Sink	NNH571	0.0240	Exceeds Limit	0.5200	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1065 Learning Ctr Kitchen Sink	NNH572	0.0250	Exceeds Limit	0.1800	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1069 Learning Ctr Bathroom Sink	NNH573	0.0290	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1070 Comm Rm Sink	NNH574	0.0310	Exceeds Limit	0.3600	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1071 Vestibule Sink	NNH575	0.0060	Exceeds Limit	0.1500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
McCulloch Education Centre	Rm 1072 Classroom Sink	NNH576	0.0330	Exceeds Limit	0.5100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1073 Classroom Sink	NNH577	0.0320	Exceeds Limit	0.3500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1080 Classroom Sink	NNH578	0.0088	Exceeds Limit	0.1400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
McCulloch Education Centre	Rm 1081 Washroom Sink A	NNH579	0.0110	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1081 Washroom Sink B	NNH580	0.0390	Exceeds Limit	0.9500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1082 Classroom Lab1 Handwash Sink	NNH581	0.0220	Exceeds Limit	0.6800	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1082 Classroom CS1 Utility Sink	NNH582	0.0082	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
McCulloch Education Centre	Rm 1090 Mechanical Rm Sink	NNH583	0.0200	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
New Glasgow Academy	Room 112 Sink A	MYY893	0.0000	Passed	0.0890	Passed	Remediation has been completed
New Glasgow Academy	Room 113 Sink A	MYY894	0.0000	Passed	0.0630	Passed	Remediation has been completed
New Glasgow Academy	Room 115 PP Sink A	MYY895	0.0000	Passed	0.0330	Passed	Remediation has been completed
New Glasgow Academy	Room 124 Sink A	MYY896	0.0000	Passed	0.3500	Passed	Remediation has been completed
New Glasgow Academy	Room 124 Sink B	MYY897	0.0053	Passed	0.5700	Passed	Remediation has been completed
New Glasgow Academy	Room 125 Sink A	MYY898	0.0000	Passed	0.0920	Passed	Remediation has been completed
New Glasgow Academy	Room 126 Sink A	MYY899	0.0000	Passed	0.0610	Passed	Remediation has been completed
New Glasgow Academy	Kitchen Sink	MYY900	0.0031	Passed	0.1000	Passed	Remediation has been completed
New Glasgow Academy	Hand Sink 2	MYY901	0.0007	Passed	0.1600	Passed	Remediation has been completed
New Glasgow Academy	Family Studies Sink	MYY902	0.0000	Passed	0.1000	Passed	Remediation has been completed
New Glasgow Academy	Nutrition Lab Sink A	MYY903	0.0000	Passed	0.1200	Passed	Remediation has been completed
New Glasgow Academy	Nutrition Lab Sink B	MYY904	0.0000	Passed	0.0700	Passed	Remediation has been completed
New Glasgow Academy	Nutrition Lab Sink C	MYY905	0.0000	Passed	0.0410	Passed	Remediation has been completed
New Glasgow Academy	Nutrition Lab Sink D	MYY906	0.0000	Passed	0.3200	Passed	Remediation has been completed
New Glasgow Academy	Nutrition Lab Sink E	MYY907	0.0000	Passed	0.3100	Passed	Remediation has been completed
New Glasgow Academy	Staff Room Kitchen Sink	MYY908	0.0000	Passed	0.1300	Passed	Remediation has been completed
New Glasgow Academy	Bottle Filler A	MYY909	0.0000	Passed	0.2300	Passed	Remediation has been completed
New Glasgow Academy	Bottle Filler B	MYY910	0.0000	Passed	0.3900	Passed	Remediation has been completed
New Glasgow Academy	Dish Sink	MYY911	0.0007	Passed	0.6100	Passed	Remediation has been completed
New Glasgow Academy	Cafeteria Sink	MYY912	0.0000	Passed	0.1100	Passed	Remediation has been completed
New Glasgow Academy	Cafeteria Kitchen Sink	MYY913	0.0000	Passed	0.3200	Passed	Remediation has been completed
New Glasgow Academy	Music Room Sink	MYY914	0.0000	Passed	0.1400	Passed	Remediation has been completed
New Glasgow Academy	Room 230 Sink A	MYY915	0.0013	Passed	0.1400	Passed	Remediation has been completed
New Glasgow Academy	Room 230 Sink B	MYY916	0.0010	Passed	0.1700	Passed	Remediation has been completed
New Glasgow Academy	Room 231 Sink A	MYY917	0.0000	Passed	0.6900	Passed	Remediation has been completed
New Glasgow Academy	Room 238 Sink	MYY918	0.0013	Passed	0.0910	Passed	Remediation has been completed
New Glasgow Academy	Room 239 Sink	MYY919	0.0000	Passed	0.0850	Passed	Remediation has been completed
New Glasgow Academy	Bottle Filler C	MYY920	0.0000	Passed	0.5700	Passed	Remediation has been completed
New Glasgow Academy	Room 303 Sink	MYY921	0.0000	Passed	0.2900	Passed	Remediation has been completed
New Glasgow Academy	Room 304 Sink	MYY922	0.0000	Passed	0.1900	Passed	Remediation has been completed
New Glasgow Academy	Bottle Filler E	MYY923	0.0000	Passed	0.3400	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Staff Room Washroom Sink	NU503	0.0000	Passed	0.0600	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Boys Washroom Sink A	NU504	0.0000	Passed	0.4100	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Boys Washroom Sink B	NU505	0.0000	Passed	0.5200	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Girls Washroom Sink A	NU506	0.0017	Passed	0.2100	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Girls Washroom Sink B	NU507	0.0012	Passed	0.1600	Passed	Remediation has been completed
New Glasgow Academy	1st Floor Custodial Closet Sink	NU508	0.0011	Passed	0.0530	Passed	Remediation has been completed
New Glasgow Academy	Boiler Room Sink	OPX664	0.0600	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
New Glasgow Academy	2nd Floor Boys Washroom Sink A	NU510	0.0000	Passed	0.0570	Passed	Remediation has been completed
New Glasgow Academy	2nd Floor Boys Washroom Sink B	NU511	0.0000	Passed	0.0580	Passed	Remediation has been completed
New Glasgow Academy	2nd Floor Girls Washroom Sink A	NU512	0.0000	Passed	0.0690	Passed	Remediation has been completed
New Glasgow Academy	2nd Floor Girls Washroom Sink B	NU513	0.0000	Passed	0.0580	Passed	Remediation has been completed
New Glasgow Academy	2nd Floor Custodial Closet Sink	NU514	0.0010	Passed	0.1100	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Staff Washroom Sink	NU515	0.0000	Passed	0.0880	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Boys Washroom Sink A	NU516	0.0000	Passed	0.0730	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Boys Washroom Sink B	NU517	0.0000	Passed	0.0680	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Girls Washroom Sink A	NU518	0.0000	Passed	0.0540	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Girls Washroom Sink B	NU519	0.0010	Passed	0.1100	Passed	Remediation has been completed
New Glasgow Academy	3rd Floor Custodial Closet Sink	NU520	0.0005	Passed	0.0590	Passed	Remediation has been completed
New Glasgow Academy	Mechanical Room Sink	NU521	0.0000	Passed	0.0780	Passed	Remediation has been completed
New Glasgow Academy	Room 116 Washroom Sink	NU522	0.0000	Passed	0.0750	Passed	Remediation has been completed
New Glasgow Academy	Room 119 Washroom Sink	NU523	0.0008	Passed	0.1300	Passed	Remediation has been completed
New Glasgow Academy	Room 241 Staff Room Sink A	NU524	0.0000	Passed	0.0920	Passed	Remediation has been completed
New Glasgow Academy	Room 241 Staff Room Sink B	NU525	0.0000	Passed	0.0890	Passed	Remediation has been completed
New Glasgow Academy	Gym Locker Room Girls Sink A	NU526	0.0006	Passed	0.1300	Passed	Remediation has been completed
New Glasgow Academy	Gym Locker Room Girls Sink B	NU527	0.0017	Passed	0.2800	Passed	Remediation has been completed
New Glasgow Academy	Gym Locker Room Boys Sink A	NU528	0.0007	Passed	0.1000	Passed	Remediation has been completed
New Glasgow Academy	Gym Locker Room Boys Sink B	NU529	0.0000	Passed	0.0580	Passed	Remediation has been completed
New Glasgow Academy	Girls Washroom Sink C	NU530	0.0009	Passed	0.1300	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
North Nova Education Centre	C2006 Staff Room Sink	MXT540	0.0000	Passed	0.2700	Passed	Remediation has been completed
North Nova Education Centre	C2007 Kitchen Class (Sink A)	MXT541	0.0016	Passed	0.4500	Passed	Remediation has been completed
North Nova Education Centre	C2007 Kitchen Class (Sink B)	MXT542	0.0024	Passed	0.3100	Passed	Remediation has been completed
North Nova Education Centre	C2007 Kitchen Class (Sink C)	MXT543	0.0009	Passed	0.2300	Passed	Remediation has been completed
North Nova Education Centre	C2010 Tentile Class (Sink D)	MXT544	0.0006	Passed	0.2600	Passed	Remediation has been completed
North Nova Education Centre	C2010 Tentile Class (Sink)	MXT545	0.0006	Passed	0.1800	Passed	Remediation has been completed
North Nova Education Centre	A2180 Classroom (Sink)	MXT546	0.0029	Passed	1.0000	Passed	Remediation has been completed
North Nova Education Centre	083 Bottle Filler A-2nd FL SW	MXT547	0.0000	Passed	1.2000	Passed	Remediation has been completed
North Nova Education Centre	084 Bottle Filler C-2nd FL NW	QOP329	0.0013	Passed	0.0160	Passed	Remediation has been completed
North Nova Education Centre	085 Bottle Filler D-2nd FL NE	QOP330	0.0022	Passed	0.0390	Passed	Remediation has been completed
North Nova Education Centre	086 Bottle Filler E-1st FL SW	OZH113	0.0016	Passed	0.2600	Passed	Remediation has been completed
North Nova Education Centre	086A 1st Floor SW Bottle Filler E Bypass	OZH114	0.0038	Passed	0.1500	Passed	Remediation has been completed
North Nova Education Centre	087 Bottle Filler F-1st FL SE	MXT551	0.0000	Passed	0.9300	Passed	Remediation has been completed
North Nova Education Centre	088 Bottle Filler G - 1st FL NW	MXT552	0.0000	Passed	0.4200	Passed	Remediation has been completed
North Nova Education Centre	089 Bottle Filler H-1st FL NE	MXT553	0.0000	Passed	0.3300	Passed	Remediation has been completed
North Nova Education Centre	090 Bottle Filler 1-1st FL by Gym	MXT554	0.0000	Passed	1.2000	Passed	Remediation has been completed
North Nova Education Centre	091 Library (Sink)	MXT555	0.0011	Passed	0.1900	Passed	Remediation has been completed
North Nova Education Centre	092 1052 Learning CTR (Sink)	MXT556	0.0006	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	095 C1005 Main Office	MXT557	0.0000	Passed	0.1100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
North Nova Education Centre	098 B1112 CAF Kitchen (Prep Sink A)	NIU619	0.0190	Exceeds Limit	0.0590	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	099 B1112 CAF Kitchen (Prep Sink B)	MXT559	0.0000	Passed	0.0860	Passed	Remediation has been completed
North Nova Education Centre	100 B1112 CAF Kitchen (Hand Sink)	MXT560	0.0059	Exceeds Limit	0.6400	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	101 B1112 CAF Kitchen (Sprayer)	NIU620	0.0019	Passed	0.1300	Passed	Remediation has been completed
North Nova Education Centre	103 B1111 Music Room (Sink)	MXT562	0.0007	Passed	0.1700	Passed	Remediation has been completed
North Nova Education Centre	104 B1117 FS Kitchen (Hand Sink)	MXT563	0.0000	Passed	0.0860	Passed	Remediation has been completed
North Nova Education Centre	105 B1117 FS Kitchen (Sprayer)	MXT564	0.0000	Passed	0.0620	Passed	Remediation has been completed
North Nova Education Centre	123 Gym Office #1 (Sink)	MXT565	0.0000	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	125 Gym Office #2 (Sink)	MXT566	0.0000	Passed	0.1300	Passed	Remediation has been completed
North Nova Education Centre	135 C1065 Visual Arts (Sink A)	MXT567	0.0006	Passed	0.0980	Passed	Remediation has been completed
North Nova Education Centre	136 C1065 Visual Arts (Sink B)	NIU621	0.0044	Passed	0.1300	Passed	Remediation has been completed
North Nova Education Centre	137 C1067 Visual Arts (Sink A)	MXT569	0.0006	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	138 C1067 Visual Arts (Sink B)	MXT570	0.0012	Passed	0.0930	Passed	Remediation has been completed
North Nova Education Centre	A1194 Boys Washroom A	NHC555	0.0007	Passed	0.1200	Passed	Remediation has been completed
North Nova Education Centre	A1194 Boys Washroom B	NHC556	0.0011	Passed	0.0910	Passed	Remediation has been completed
North Nova Education Centre	A1194 Boys Washroom C	NHC557	0.0056	Exceeds Limit	0.7900	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	A1196 Girls Washroom A	NHC558	0.0057	Exceeds Limit	0.7900	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	A1196 Girls Washroom B	NHC559	0.0024	Passed	0.2100	Passed	Remediation has been completed
North Nova Education Centre	A1196 Girls Washroom C	NHC560	0.0040	Passed	0.7600	Passed	Remediation has been completed
North Nova Education Centre	Custodial Closet Floor Sink	NHC561	0.0000	Passed	0.0810	Passed	Remediation has been completed
North Nova Education Centre	C2006 Staff Washroom A	NHC562	0.0016	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	C2006 Staff Washroom B	NHC563	0.0030	Passed	0.3500	Passed	Remediation has been completed
North Nova Education Centre	C2012 Biology Lab A	NHC564	0.0150	Exceeds Limit	0.4900	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2012 Biology Lab B	NHC565	0.0140	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2012 Biology Lab C	NHC566	0.0180	Exceeds Limit	0.6300	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2012 Biology Lab D	NHC567	0.0110	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2012 Biology Lab E	NHC568	0.0200	Exceeds Limit	0.5400	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2021 Science Lab A	NHC569	0.0058	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2021 Science Lab B	NHC570	0.0053	Passed	0.1100	Passed	Remediation has been completed
North Nova Education Centre	C2021 Science Lab C	NHC571	0.0076	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2021 Science Lab D	NHC572	0.0041	Passed	0.2000	Passed	Remediation has been completed
North Nova Education Centre	C2022 Science Lab A	NHC573	0.0180	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2022 Science Lab B	NHC574	0.0130	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2022 Science Lab C	NHC575	0.0160	Exceeds Limit	0.9100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2022 Science Lab D	NHC576	0.0110	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2022 Science Lab E	NHC577	0.0092	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2013 Science Lab A	NHC578	0.0022	Passed	0.2700	Passed	Remediation has been completed
North Nova Education Centre	C2013 Science Lab B	NHC579	0.0130	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2013 Science Lab C	NHC580	0.0063	Exceeds Limit	0.4500	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2013 Science Lab D	NHC581	0.0120	Exceeds Limit	0.5700	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2020 Science Lab A	NHC582	0.0024	Passed	0.1700	Passed	Remediation has been completed
North Nova Education Centre	C2020 Science Lab B	NHC583	0.0074	Exceeds Limit	0.9100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2020 Science Lab C	NHC584	0.0058	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2020 Science Lab D	NHC585	0.0140	Exceeds Limit	0.6500	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2019 Science Lab A	NHC586	0.0019	Passed	0.1800	Passed	Remediation has been completed
North Nova Education Centre	C2019 Science Lab B	NHC587	0.0099	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2019 Science Lab C	NHC588	0.0180	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2019 Science Lab D	NHC589	0.0140	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
North Nova Education Centre	C2019 Science Lab E	NHC590	0.0090	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab A	NHC591	0.0042	Passed	0.1000	Passed	Remediation has been completed
North Nova Education Centre	C2017 Science Lab B	NHC592	0.0064	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab C	NHC593	0.0089	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab D	NHC594	0.0094	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab E	NHC595	0.0037	Passed	0.0830	Passed	Remediation has been completed
North Nova Education Centre	C2017 Science Lab F	NHC596	0.0063	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab G	NHC597	0.0084	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab H	NHC598	0.0055	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C2017 Science Lab 1	NHC599	0.0017	Passed	0.2500	Passed	Remediation has been completed
North Nova Education Centre	A2194 Boys Washroom A	NHC600	0.0034	Passed	0.3500	Passed	Remediation has been completed
North Nova Education Centre	A2194 Boys Washroom B	NHC601	0.0036	Passed	0.4300	Passed	Remediation has been completed
North Nova Education Centre	A2194 Boys Washroom C	NHC602	0.0025	Passed	0.4400	Passed	Remediation has been completed
North Nova Education Centre	A2196 Girls Washroom A	NHC603	0.0018	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	Custodial Closet Science Pod	NHC604	0.0020	Passed	0.1100	Passed	Remediation has been completed
North Nova Education Centre	Staff Washroom Science Pod	NHC605	0.0022	Passed	0.4500	Passed	Remediation has been completed
North Nova Education Centre	A2174 Boys Washroom A	NHC606	0.0029	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	A2174 Boys Washroom B	NHC607	0.0000	Passed	0.1400	Passed	Remediation has been completed
North Nova Education Centre	A2176 Girls Washroom A	NHC608	0.0012	Passed	0.1800	Passed	Remediation has been completed
North Nova Education Centre	A2176 Girls Washroom B	NHC609	0.0015	Passed	0.2400	Passed	Remediation has been completed
North Nova Education Centre	A2176 Girls Washroom C	NHC610	0.0017	Passed	0.2500	Passed	Remediation has been completed
North Nova Education Centre	2014 Biology Storage	NHC611	0.0010	Passed	0.2200	Passed	Remediation has been completed
North Nova Education Centre	2023 Chemistry Storage	NHC612	0.0017	Passed	0.2300	Passed	Remediation has been completed
North Nova Education Centre	Custodial Closet SS Pod Floor	NHC613	0.0007	Passed	0.0710	Passed	Remediation has been completed
North Nova Education Centre	Custodial Closet FR Pod Floor	NHC614	0.0012	Passed	0.2400	Passed	Remediation has been completed
North Nova Education Centre	Staff Washroom SS Pod	NHC615	0.0008	Passed	0.1700	Passed	Remediation has been completed
North Nova Education Centre	B2040 Ventilation Room	NHC616	0.0021	Passed	0.1000	Passed	Remediation has been completed
North Nova Education Centre	Boys Washroom FR Pod 8	NHC617	0.0011	Passed	0.1400	Passed	Remediation has been completed
North Nova Education Centre	Boys Washroom FR Pod C	NHC618	0.0022	Passed	0.1100	Passed	Remediation has been completed
North Nova Education Centre	Girls Washroom FR Pod A	NHC619	0.0010	Passed	0.1500	Passed	Remediation has been completed
North Nova Education Centre	Girls Washroom FR Pod B	NHC620	0.0027	Passed	0.4100	Passed	Remediation has been completed
North Nova Education Centre	Girls Washroom FR Pod C	NHC621	0.0019	Passed	0.1800	Passed	Remediation has been completed
North Nova Education Centre	Girls Washroom FR Pod D	NHC622	0.0027	Passed	0.1700	Passed	Remediation has been completed
North Nova Education Centre	2nd Floor Custodial Closet Utility	NHC623	0.0010	Passed	0.0580	Passed	Remediation has been completed
North Nova Education Centre	1052 Learning Centre Washroom	NHC624	0.0037	Passed	0.3900	Passed	Remediation has been completed
North Nova Education Centre	C1005 Main Office Washroom	NHC625	0.0000	Passed	0.1200	Passed	Remediation has been completed
North Nova Education Centre	C1019 Student SRS Washroom	NHC626	0.0022	Passed	0.2100	Passed	Remediation has been completed
North Nova Education Centre	B1114 Cafeteria Recycle Floor	NHC627	0.0095	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	Staff Washroom CEP	NHC628	0.0084	Exceeds Limit	0.9000	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	B1121 Tec Prod Lab Eyewash Station	NHC629	0.0089	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	B1124 Auto Lab Eyewash Station	NHC630	0.0027	Passed	0.2900	Passed	Remediation has been completed
North Nova Education Centre	B1128 Recycle Storage	NHC631	0.0067	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	Boiler Room Utility sink	NHC632	0.0030	Passed	0.1300	Passed	Remediation has been completed
North Nova Education Centre	Gym Locker Room #1	NHC633	0.0025	Passed	0.2700	Passed	Remediation has been completed
North Nova Education Centre	Gym Locker Room #2	NHC634	0.0022	Passed	0.2200	Passed	Remediation has been completed
North Nova Education Centre	Gym Locker Room #3	NHC635	0.0021	Passed	0.2400	Passed	Remediation has been completed
North Nova Education Centre	Gym Locker Room #4	NHC636	0.0022	Passed	0.1600	Passed	Remediation has been completed
North Nova Education Centre	C1062 Boys Washroom A	NHC637	0.0110	Exceeds Limit	0.5500	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C1062 Boys Washroom B	NHC638	0.0590	Exceeds Limit	6.3000	Exceeds Limit	Signage to be added to instruct handwashing only
North Nova Education Centre	C1062 Boys Washroom C	NHC639	0.0480	Exceeds Limit	5.8000	Exceeds Limit	Signage to be added to instruct handwashing only
North Nova Education Centre	C1063 Girls Washroom A	NHC640	0.0073	Exceeds Limit	0.8800	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C1063 Girls Washroom B	NHC641	0.0058	Exceeds Limit	0.5700	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	C1063 Girls Washroom C	NHC642	0.0044	Passed	0.2600	Passed	Remediation has been completed
North Nova Education Centre	C1063 Girls Washroom D	NHC643	0.0083	Exceeds Limit	0.8100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	Custodial Closet Floor	NHC644	0.0028	Passed	0.1100	Passed	Remediation has been completed
North Nova Education Centre	A1176 Boys Washroom A	NHC645	0.0010	Passed	0.1000	Passed	Remediation has been completed
North Nova Education Centre	A1176 Boys Washroom B	NHC646	0.0007	Passed	0.1000	Passed	Remediation has been completed
North Nova Education Centre	A1176 Boys Washroom C	NHC647	0.0013	Passed	0.1400	Passed	Remediation has been completed
North Nova Education Centre	A1174 Girls Washroom A	NHC648	0.0170	Exceeds Limit	2.6000	Exceeds Limit	Signage to be added to instruct handwashing only
North Nova Education Centre	A1174 Girls Washroom B	NHC649	0.0110	Exceeds Limit	1.7000	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	A1174 Girls Washroom C	NHC650	0.0099	Exceeds Limit	1.2000	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	Custodial Closet Floor	NHC651	0.0064	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
North Nova Education Centre	Staff Washroom English Pod	NHC652	0.0015	Passed	0.2300	Passed	Remediation has been completed
North Nova Education Centre	Staff Washroom Math Pod	NHC653	0.0014	Passed	0.2400	Passed	Remediation has been completed
North Nova Education Centre	B1112 Cafeteria Kitchen Sink with Sprayer	NIU620	0.0019	Passed	0.1300	Passed	Remediation has been completed
North Nova Education Centre	C1065 Visual Arts Sink B	NIU621	0.0044	Passed	0.1300	Passed	Remediation has been completed
North River Elementary School	Bottle Filler Outside of Gym F1	LET625	0.0000	Passed	0.1800	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
North River Elementary School	Staff Room Sink T11	LET629	0.0008	Passed	0.1500	Passed	Remediation has been completed
North River Elementary School	Kitchen Hand Washing Sink T14	LET630	0.0078	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
North River Elementary School	Dishwasher Sprayer T15	LET631	0.0180	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
North River Elementary School	Main Kitchen Sink T16	LET632	0.0037	Passed	0.2700	Passed	Remediation has been completed
North River Elementary School	Kitchen Sink by Fridge	LET633	0.0023	Passed	0.2900	Passed	Remediation has been completed
North River Elementary School	First Bottle Filler by Boys Washroom F2	LET634	0.0000	Passed	0.4000	Passed	Remediation has been completed
North River Elementary School	Bottle Filler in between Washroom F3	LET635	0.0000	Passed	0.4200	Passed	Remediation has been completed
North River Elementary School	Raw Water Entering Building Boiler Room	LET636	0.0000	Passed	0.0011	Passed	Remediation has been completed
North River Elementary School	Custodial Floor Sink Gym Wing, T1	NUE847	0.0022	Passed	0.1900	Passed	Remediation has been completed
North River Elementary School	Girls Washroom Gym Wing Left Tap, T2	NUE848	0.0030	Passed	0.3700	Passed	Remediation has been completed
North River Elementary School	Girls Washroom Gym Wing Right Tap, T3	NUE849	0.0010	Passed	0.1900	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Gym Wing Left Tap, T4	NUE850	0.0035	Passed	0.3800	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Gym Wing Right Tap, T5	NUE851	0.0029	Passed	0.3500	Passed	Remediation has been completed
North River Elementary School	Gym Office Washroom, T6	NUE852	0.0014	Passed	0.3200	Passed	Remediation has been completed
North River Elementary School	Girls Locker Room, T7	NUE853	0.0140	Exceeds Limit	0.5600	Passed	Signage to be added to instruct handwashing only
North River Elementary School	Boys Locker Room T8	NUE854	0.0082	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
North River Elementary School	Pre-Primary 21, T9	NUE855	0.0019	Passed	0.1600	Passed	Remediation has been completed
North River Elementary School	Primary 22, T10	NUE856	0.0034	Passed	0.1600	Passed	Remediation has been completed
North River Elementary School	Staff Room Washroom, T12	NUE857	0.0029	Passed	0.1500	Passed	Remediation has been completed
North River Elementary School	Sick Room Washroom, T13	NUE858	0.0011	Passed	0.1700	Passed	Remediation has been completed
North River Elementary School	Custodial Closet 19, T18	NUE859	0.0061	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
North River Elementary School	Handicap Washroom by Comm. 18, T19	NUE860	0.0020	Passed	0.1300	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Left Tap, T20	NUE861	0.0000	Passed	0.0820	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Left Middle, T21	NUE862	0.0000	Passed	0.1200	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Middle Tap, T22	NUE863	0.0000	Passed	0.0950	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Right Middle Tap, T23	NUE864	0.0000	Passed	0.1200	Passed	Remediation has been completed
North River Elementary School	Boys Washroom Right Tap, T24	NUE865	0.0000	Passed	0.0880	Passed	Remediation has been completed
North River Elementary School	Girls Washroom Left Tap, T25	NUE866	0.0041	Passed	0.1600	Passed	Remediation has been completed
North River Elementary School	Girls Washroom Middle Tap, T26	NUE867	0.0022	Passed	0.1400	Passed	Remediation has been completed
North River Elementary School	Girls Washroom Right Tap, T27	NUE868	0.0023	Passed	0.1200	Passed	Remediation has been completed
Northport Consolidated Elementary School	Gym Bottle Filler	PYZ822	0.0000	Passed	0.1400	Passed	Remediation has been completed
Northport Consolidated Elementary School	Staff Room	MPQ228	0.0000	Passed	0.0470	Passed	Remediation has been completed
Northport Consolidated Elementary School	Hallway Bottle Filler	PYZ823	0.0000	Passed	0.0830	Passed	Remediation has been completed
Northport Consolidated Elementary School	Room 5	NHD505	0.0000	Passed	0.0230	Passed	Remediation has been completed
Northport Consolidated Elementary School	Room 1	NHD506	0.0000	Passed	0.0220	Passed	Remediation has been completed
Northport Consolidated Elementary School	Staff Room	NHD507	0.0000	Passed	0.0088	Passed	Remediation has been completed
Northport Consolidated Elementary School	Boys #1	NHD508	0.0000	Passed	0.0100	Passed	Remediation has been completed
Northport Consolidated Elementary School	Boys #2	NHD509	0.0000	Passed	0.0076	Passed	Remediation has been completed
Northport Consolidated Elementary School	Boys #3	NHD510	0.0000	Passed	0.0071	Passed	Remediation has been completed
Northport Consolidated Elementary School	Boys #4	NHD511	0.0000	Passed	0.0081	Passed	Remediation has been completed
Northport Consolidated Elementary School	Custodial	NHD512	0.0000	Passed	0.0055	Passed	Remediation has been completed
Northport Consolidated Elementary School	Girls #1	NHD513	0.0000	Passed	0.0100	Passed	Remediation has been completed
Northport Consolidated Elementary School	Girls #2	NHD514	0.0000	Passed	0.0100	Passed	Remediation has been completed
Northport Consolidated Elementary School	Girls #3	NHD515	0.0000	Passed	0.0096	Passed	Remediation has been completed
Northport Consolidated Elementary School	Girls #4	NHD516	0.0000	Passed	0.0093	Passed	Remediation has been completed
Northport Consolidated Elementary School	Girls #4	NHD517	0.0000	Passed	0.0093	Passed	Remediation has been completed
Northumberland Regional High School	A1072 Library Sink	MYH270	0.0022	Passed	0.0001	Passed	Remediation has been completed
Northumberland Regional High School	A1077 Sink	MYH271	0.0016	Passed	0.0001	Passed	Remediation has been completed
Northumberland Regional High School	A1086 Kitchen A	MYH272	0.0010	Passed	0.0002	Passed	Remediation has been completed
Northumberland Regional High School	A1086 Kitchen Sink B	MYH273	0.0000	Passed	0.0001	Passed	Remediation has been completed
Northumberland Regional High School	A1086 Kitchen Sink C	MYH274	0.6200	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1086 Kitchen Sink D	MYH275	0.5400	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1089 Sink - Back Room	MYH276	4.2000	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1083 Sink A - Art Room	MYH277	4.0000	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1083 Sink B - Art Room	MYH278	2.0000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1084 Sink A - Art Room	MYH279	1.1000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1084 Sink B - Art Room	MYH280	2.1000	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	CEP Kitchen Sink A	MYH281	19.000	Exceeds Limit	0.0001	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Northumberland Regional High School	CEP Kitchen Sink B	MYH282	2.3000	Exceeds Limit	0.0003	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Northumberland Regional High School	CEP Kitchen Handwash	MYH283	6.5000	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Bottle Filler A - By CEP Wing	OVS721	0.0024	Passed	0.4500	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler C - Entrance to Gym	PXR032	0.0000	Passed	0.0061	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler D - French Pod by Washroom	OVS722	0.0024	Passed	0.7700	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler E - English Pod by Washroom	PXR033	0.0014	Passed	0.0046	Passed	Remediation has been completed
Northumberland Regional High School	1122 in Music Room Sink	MYH289	3.2000	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Kitchen Handwash	MYH290	0.8500	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Kitchen Dishwash Sink A	MYH291	1.9000	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Northumberland Regional High School	Kitchen Dishwash Sink B	MYH292	3.8000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Kitchen Dishwash Sink C	MYH293	0.5700	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Kitchen Dishwash Sink D	MYH294	0.0000	Passed	0.0001	Passed	Remediation has been completed
Northumberland Regional High School	Kitchen Sprayer	MYH295	16.0000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Room 2044 - Kitchen	MYH296	0.5100	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Bottle Filler F - Upstairs by Elevator	PXR034	0.0016	Passed	0.0014	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler G - SS Pod Outside Washroom	MYH298	0.0000	Passed	0.0003	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler H - Math Pod by Washroom	OVS723	0.0020	Passed	0.1500	Passed	Remediation has been completed
Northumberland Regional High School	Bottle Filler I - Outside Room 2060	OVS724	0.0037	Passed	0.4700	Passed	Remediation has been completed
Northumberland Regional High School	A2059 - Back of Science Lab	MYH301	16.0000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A2060 Sink A	MYH302	7.9000	Exceeds Limit	0.0000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A2060 Sink B	MYH303	0.8100	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A2060 Sink C	MYH304	5.5000	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Kitchen Sprayer	NIU713	0.0022	Passed	0.0001	Passed	Remediation has been completed
Northumberland Regional High School	041 Handwash Station	NIU712	2.9000	Exceeds Limit	0.0590	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	140 A2059 Back of Science Lab - Sink	NIU714	8.5000	Exceeds Limit	0.7000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	141 A2060 Sink A	NIU715	16.0000	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	143 Sink C	NIU716	5.7000	Exceeds Limit	0.3600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1065 - Admin Office Washroom Sink	NLZ858	1.3000	Exceeds Limit	0.0600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Teen Health	NLZ859	0.0000	Passed	0.0600	Passed	Remediation has been completed
Northumberland Regional High School	Custodial	NLZ860	0.0000	Passed	0.0540	Passed	Remediation has been completed
Northumberland Regional High School	A1012 Boys A - Washroom	NLZ861	0.0000	Passed	0.0580	Passed	Remediation has been completed
Northumberland Regional High School	A1012 Boys B - Washroom	NLZ862	41.0000	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1012 Boys C - Washroom	NLZ863	3.9000	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1013 Girls A - Washroom	NLZ864	24.0000	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1013 Girls B - Washroom	NLZ865	6.0000	Exceeds Limit	0.0700	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1013 Girls C - Washroom	NLZ866	8.5000	Exceeds Limit	0.0580	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Staff Washroom	NLZ867	0.6500	Exceeds Limit	0.0550	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	A1077 Washroom	NLZ868	1.3000	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Gym Office #1	NLZ869	1.6000	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Gym Office #2	NLZ870	4.0000	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Locker Room #1	NLZ871	4.5000	Exceeds Limit	0.0990	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Locker Room #2	NLZ872	4.3000	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Locker Room #3	NLZ873	0.9100	Exceeds Limit	0.0900	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Locker Room #4	NLZ874	0.5200	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1118A - Washroom	NLZ875	8.7000	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1118B - Washroom	NLZ876	18.0000	Exceeds Limit	0.0740	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1118C - Washroom	NLZ877	8.5000	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1119A - Washroom	NLZ878	2.7000	Exceeds Limit	0.0560	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1119B - Washroom	NLZ879	6.3000	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1119C - Washroom	NLZ880	25.0000	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Washroom Gender Neutral Sink	NLZ881	0.0000	Passed	0.0460	Passed	Remediation has been completed
Northumberland Regional High School	B1145 - Utility Sink - Shop	NLZ882	0.7200	Exceeds Limit	0.0530	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B1142 - Utility Sink - Shop	NLZ883	4.3000	Exceeds Limit	0.0450	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Recycle Room A	NLZ884	0.7100	Exceeds Limit	0.0580	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	Recycle Room B	NLZ885	0.9400	Exceeds Limit	0.0420	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2018 - Washroom	NLZ886	5.1000	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2011 - Custodial Closet	NLZ887	16.0000	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2009 - Washroom	NLZ888	0.6800	Exceeds Limit	0.0630	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2012A - Washroom	NLZ889	3.2000	Exceeds Limit	0.0580	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2012B - Washroom	NLZ890	3.5000	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2012C - Washroom	NLZ891	2.1000	Exceeds Limit	0.0720	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2013A - Washroom	NLZ892	9.5000	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2013B - Washroom	NLZ893	3.4000	Exceeds Limit	0.0610	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2013C - Washroom	NLZ894	40.0000	Exceeds Limit	0.0630	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2051A - Eyewash Station	NLZ895	4.3000	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2051B - Eyewash Station	NLZ896	2.6000	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2051C - Eyewash Station	NLZ897	4.6000	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2051D - Eyewash Station	NLZ898	11.0000	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2051E - Eyewash Station	NLZ899	0.0048	Passed	0.5700	Passed	Remediation has been completed
Northumberland Regional High School	2052 - Lab	NLZ900	0.0160	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2041A - Eyewash Station	NLZ901	0.0035	Passed	0.3300	Passed	Remediation has been completed
Northumberland Regional High School	2041B - Eyewash Station	NLZ902	0.0031	Passed	0.0730	Passed	Remediation has been completed
Northumberland Regional High School	2041C - Eyewash Station	NLZ903	0.0045	Passed	0.1600	Passed	Remediation has been completed
Northumberland Regional High School	2041D - Eyewash Station	NLZ904	0.0045	Passed	0.2700	Passed	Remediation has been completed
Northumberland Regional High School	2042 - Lab	NLZ905	0.2000	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2053A - Eyewash Station	NLZ906	0.0034	Passed	0.4000	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Northumberland Regional High School	2053C - Eyewash Station	NLZ907	0.0052	Passed	0.2500	Passed	Remediation has been completed
Northumberland Regional High School	2053D - Eyewash Station	NLZ908	0.0084	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2043A - Eyewash Station	NLZ909	0.0053	Passed	0.1500	Passed	Remediation has been completed
Northumberland Regional High School	2043B - Eyewash Station	NLZ910	0.0018	Passed	0.1500	Passed	Remediation has been completed
Northumberland Regional High School	2043C - Eyewash Station	NLZ911	0.0170	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2043D - Eyewash Station	NLZ912	0.0058	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2043E - Eyewash Station	NLZ913	0.0056	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2045 - Washroom	NLZ914	0.0011	Passed	0.0900	Passed	Remediation has been completed
Northumberland Regional High School	2046 - Washroom	NLZ915	0.0017	Passed	0.0710	Passed	Remediation has been completed
Northumberland Regional High School	2054A - Eyewash Station	NLZ916	0.0007	Passed	0.0550	Passed	Remediation has been completed
Northumberland Regional High School	2054B - Eyewash Station	NLZ917	0.0000	Passed	0.1500	Passed	Remediation has been completed
Northumberland Regional High School	2054C - Eyewash Station	NLZ918	0.0011	Passed	0.0930	Passed	Remediation has been completed
Northumberland Regional High School	2054D - Eyewash Station	NLZ919	0.0350	Exceeds Limit	2.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Northumberland Regional High School	2054E - Eyewash Station	NLZ920	0.1100	Exceeds Limit	0.5200	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B2082A - Girls Washroom	NLZ921	0.0083	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B2082B - Girls Washroom	NLZ922	0.0048	Passed	0.1300	Passed	Remediation has been completed
Northumberland Regional High School	B2082C - Girls Washroom	NLZ923	0.0190	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B2084A - Boys Washroom	NLZ924	0.0079	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B2084B - Boys Washroom	NLZ925	0.0046	Passed	0.1500	Passed	Remediation has been completed
Northumberland Regional High School	B2084C - Boys Washroom	NLZ926	0.0056	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2069 - Staff Washroom	NLZ927	0.0017	Passed	0.1800	Passed	Remediation has been completed
Northumberland Regional High School	2065A - Lab	NLZ928	0.0094	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2065B - Lab	NLZ929	0.0031	Passed	0.0830	Passed	Remediation has been completed
Northumberland Regional High School	2065C - Lab	NLZ930	0.0073	Exceeds Limit	0.0780	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2065D - Lab	NLZ931	0.0008	Passed	0.0760	Passed	Remediation has been completed
Northumberland Regional High School	2065E - Lab	NLZ932	0.0042	Passed	0.3000	Passed	Remediation has been completed
Northumberland Regional High School	2065F - Lab	NLZ933	0.0020	Passed	0.1600	Passed	Remediation has been completed
Northumberland Regional High School	2065G - Lab	NLZ934	0.0058	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2065H - Lab	NLZ935	0.0033	Passed	0.0970	Passed	Remediation has been completed
Northumberland Regional High School	2065I - Lab	NLZ936	0.0026	Passed	0.0850	Passed	Remediation has been completed
Northumberland Regional High School	2063 - Back Lab	NLZ937	0.0029	Passed	0.0700	Passed	Remediation has been completed
Northumberland Regional High School	2058A - Science Lab	NLZ938	0.0040	Passed	0.2100	Passed	Remediation has been completed
Northumberland Regional High School	2058B - Science Lab	NLZ939	0.0031	Passed	0.2700	Passed	Remediation has been completed
Northumberland Regional High School	2058C - Science Lab	NLZ940	0.0021	Passed	0.1100	Passed	Remediation has been completed
Northumberland Regional High School	2061A - Chemistry Lab	NLZ941	0.0045	Passed	0.0700	Passed	Remediation has been completed
Northumberland Regional High School	2061B - Chemistry Lab	NLZ942	0.0050	Passed	0.0970	Passed	Remediation has been completed
Northumberland Regional High School	2061C - Chemistry Lab	NLZ943	0.0092	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2061D - Chemistry Lab	NLZ944	0.0052	Passed	0.0900	Passed	Remediation has been completed
Northumberland Regional High School	2061E - Chemistry Lab	NLZ945	0.0067	Exceeds Limit	0.0810	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2061F - Chemistry Lab	NLZ946	0.0024	Passed	0.0910	Passed	Remediation has been completed
Northumberland Regional High School	2061G - Chemistry Lab	NLZ947	0.0062	Exceeds Limit	0.0770	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2061H - Chemistry Lab	NLZ948	0.0180	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2061I - Chemistry Lab	NLZ949	0.0100	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2032A - Girls Washroom	NLZ950	0.0023	Passed	0.0740	Passed	Remediation has been completed
Northumberland Regional High School	2032B - Girls Washroom	NLZ951	0.0065	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2032C - Girls Washroom	NLZ952	0.0079	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2033A - Boys Washroom	NLZ953	0.0200	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2033B - Boys Washroom	NLZ954	0.0120	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	2032C - Boys Washroom	NLZ955	0.0000	Passed	0.0470	Passed	Remediation has been completed
Northumberland Regional High School	2031 - Staff Washroom	NLZ956	0.0000	Passed	0.0470	Passed	Remediation has been completed
Northumberland Regional High School	Custodial Closet	NLZ957	0.0009	Passed	0.0720	Passed	Remediation has been completed
Northumberland Regional High School	Boiler Room	NLZ958	0.0039	Passed	0.1800	Passed	Remediation has been completed
Northumberland Regional High School	AH Room 3	NLZ959	0.0046	Passed	0.6100	Passed	Remediation has been completed
Northumberland Regional High School	AH Room 2	NLZ960	0.0028	Passed	0.1200	Passed	Remediation has been completed
Northumberland Regional High School	Penthouse	NLZ961	0.0057	Exceeds Limit	0.0990	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	AH Room 4	NLZ962	0.0140	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Northumberland Regional High School	B2083 - Washroom	NLZ963	0.0011	Passed	0.0500	Passed	Remediation has been completed
Northumberland Regional High School	CEP Kitchen	NVP180	0.0000	Passed	0.0410	Passed	Remediation has been completed
Oxford Regional Education Centre	Wood Tech Shop	MSG858	0.0010	Passed	0.4000	Passed	Remediation has been completed
Oxford Regional Education Centre	Mechanical Room	MSG859	0.0000	Passed	0.4300	Passed	Remediation has been completed
Oxford Regional Education Centre	Bottle Filler Replaced Bottle Filler 1st Floor	PBJ460	0.0008	Passed	0.4000	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 110	MSG861	0.0000	Passed	0.7100	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 206	MSG862	0.0013	Passed	0.6100	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 207	MSG863	0.0006	Passed	0.4700	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 208	MSG864	0.0000	Passed	0.5000	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 215	MSG865	0.0000	Passed	0.4500	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 216	NIJ567	0.0000	Passed	0.3500	Passed	Remediation has been completed

Chignecto Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Oxford Regional Education Centre	Room 217	MSG867	0.0000	Passed	0.5200	Passed	Remediation has been completed
Oxford Regional Education Centre	Library	MSG868	0.0045	Passed	1.5000	Passed	Remediation has been completed
Oxford Regional Education Centre	Bottle Filler Replaced Bottle Filler 2nd by Café	PBJ461	0.0005	Passed	0.4200	Passed	Remediation has been completed
Oxford Regional Education Centre	Cafeteria #1	MSG870	0.0011	Passed	0.4900	Passed	Remediation has been completed
Oxford Regional Education Centre	Cafeteria #2	MSG871	0.0019	Passed	0.4000	Passed	Remediation has been completed
Oxford Regional Education Centre	Visual Art #1	MSG872	0.0005	Passed	0.4400	Passed	Remediation has been completed
Oxford Regional Education Centre	Visual Art #2	MSG873	0.0021	Passed	0.4500	Passed	Remediation has been completed
Oxford Regional Education Centre	Bottle Filler by Gym	MSG874	0.0005	Passed	0.8400	Passed	Remediation has been completed
Oxford Regional Education Centre	Staff Room 3rd Floor	MSG875	0.0005	Passed	0.5000	Passed	Remediation has been completed
Oxford Regional Education Centre	Bottle Filler Replaced Bottle Filler 3rd Floor	PBJ462	0.0005	Passed	0.4400	Passed	Remediation has been completed
Oxford Regional Education Centre	Nutrition #1	MSG877	0.0006	Passed	0.5300	Passed	Remediation has been completed
Oxford Regional Education Centre	Nutrition #2	MSG878	0.0012	Passed	0.5400	Passed	Remediation has been completed
Oxford Regional Education Centre	Nutrition #3	MSG879	0.0008	Passed	0.5300	Passed	Remediation has been completed
Oxford Regional Education Centre	Nutrition #4	MSG880	0.0000	Passed	0.5500	Passed	Remediation has been completed
Oxford Regional Education Centre	Nutrition #5	MSG881	0.0022	Passed	0.6900	Passed	Remediation has been completed
Oxford Regional Education Centre	Music Room	MSG882	0.0000	Passed	0.4900	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 324 Custodial	NJX486	0.0007	Passed	0.1700	Passed	Remediation has been completed
Oxford Regional Education Centre	3rd Floor Girls #1	NJX487	0.0010	Passed	0.2800	Passed	Remediation has been completed
Oxford Regional Education Centre	3rd Floor Girls #2	NJX488	0.0010	Passed	0.2200	Passed	Remediation has been completed
Oxford Regional Education Centre	3rd Floor Boys #1	NJX489	0.0006	Passed	0.1600	Passed	Remediation has been completed
Oxford Regional Education Centre	3rd Floor Boys #2	NJX490	0.0005	Passed	0.1600	Passed	Remediation has been completed
Oxford Regional Education Centre	Kitchen #1	NJX491	0.0005	Passed	0.1200	Passed	Remediation has been completed
Oxford Regional Education Centre	Kitchen #2	NJX492	0.0006	Passed	0.1500	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 339	NJX493	0.0010	Passed	0.3700	Passed	Remediation has been completed
Oxford Regional Education Centre	Washroom by Gym	NJX494	0.0008	Passed	0.2800	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 229 Custodial	NJX495	0.0008	Passed	0.1800	Passed	Remediation has been completed
Oxford Regional Education Centre	Washroom by Comm. Room	NJX496	0.0008	Passed	0.2900	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 213	NJX497	0.0000	Passed	0.4900	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 212	NIJ567	0.0000	Passed	0.4900	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 130 Custodial	NJX499	0.0008	Passed	0.2100	Passed	Remediation has been completed
Oxford Regional Education Centre	Main Office	NJX500	0.0000	Passed	0.7600	Passed	Remediation has been completed
Oxford Regional Education Centre	Room 209	NJX501	0.0008	Passed	0.2900	Passed	Remediation has been completed
Oxford Regional Education Centre	3rd Floor Staff Washroom	NJX502	0.0008	Passed	0.6700	Passed	Remediation has been completed
Oxford Regional Education Centre	1st Floor Boys #1	NKA249	0.0006	Passed	0.1800	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Staff Room	MOZ014	0.0018	Passed	6.1000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 202	NIM705	0.0021	Passed	6.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 204	NIM706	0.0014	Passed	6.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 206	NIM707	0.0014	Passed	6.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 208	MOZ019	0.0020	Passed	3.9000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Gym Office	MOZ020	0.1300	Exceeds Limit	6.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Library	NCP237	0.0180	Exceeds Limit	0.0350	Passed	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Custodial	NCP238	0.0033	Passed	3.9000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Boys #1	NCP239	0.0022	Passed	4.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Boys #2	NCP240	0.0032	Passed	3.8000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Boys #3	NCP241	0.0040	Passed	3.6000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Girls #1	NCP242	0.0012	Passed	4.8000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Girls #2	NCP243	0.0022	Passed	4.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Lower Girls #3	NCP244	0.0021	Passed	3.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 107	NCP245	0.0011	Passed	3.6000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 106	NCP246	0.0190	Exceeds Limit	2.9000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 104	NCP247	0.0036	Passed	3.0000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Room 105	NCP248	0.0063	Exceeds Limit	2.4000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Staff Washroom #1	NCP249	0.0011	Passed	0.7100	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Staff Washroom #2	NCP250	0.0006	Passed	0.7000	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Staff Washroom #3	NCP251	0.0018	Passed	0.6400	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Upper Boys #1	NCP252	0.0040	Passed	1.4000	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Upper Boys #2	NCP253	0.0010	Passed	0.9200	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Upper Boys #3	NCP254	0.0011	Passed	0.9300	Passed	Remediation has been completed
Parrsboro Regional Elementary School	Upper Girls #1	NCP255	0.0029	Passed	4.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Upper Girls #2	NCP256	0.0024	Passed	3.9000	Exceeds Limit	Remediation has been completed
Parrsboro Regional Elementary School	Upper Girls #3	NCP257	0.0019	Passed	2.9000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional Elementary School	Upper Custodial	NCP258	0.0000	Passed	0.4200	Passed	Remediation has been completed
Parrsboro Regional High School	Staff Room	MOZ162	0.0060	Exceeds Limit	3.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Room 112	MOZ163	0.0034	Passed	1.1000	Passed	Remediation has been completed
Parrsboro Regional High School	Bottle Filler Lower Hall	MOZ164	0.0039	Passed	1.4000	Passed	Remediation has been completed
Parrsboro Regional High School	Room 107 Sink #1	MOZ165	0.2200	Exceeds Limit	0.4000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Room 107 Sink #2	MOZ166	0.4000	Exceeds Limit	0.3900	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Parrsboro Regional High School	Room 108 Sink #1	MOZ167	0.0200	Exceeds Limit	3.8000	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Room 108 Sink #2	MOZ168	0.0110	Exceeds Limit	3.4000	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Room 108 Sink #3	MOZ169	0.0090	Exceeds Limit	2.6000	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Cafeteria Sink #1	MOZ170	0.0400	Exceeds Limit	1.9000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Cafeteria Sink #2	MOZ171	0.0660	Exceeds Limit	1.4000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Cafeteria Laundry Sink	MOZ172	0.0034	Passed	0.6700	Passed	Remediation has been completed
Parrsboro Regional High School	Food Lab #1	MOZ173	0.0048	Passed	2.0000	Passed	Remediation has been completed
Parrsboro Regional High School	Food Lab #2	MOZ174	0.0087	Exceeds Limit	1.3000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Food Lab #3	MOZ175	0.0044	Passed	2.3000	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Food Lab #4	MOZ176	0.0180	Exceeds Limit	1.2000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Parrsboro Regional High School	Room 202	MOZ179	0.0500	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Boiler Room	MOZ180	0.0008	Passed	4.7000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Gym Office	NCP513	0.0006	Passed	0.6100	Passed	Remediation has been completed
Parrsboro Regional High School	Boys Locker #1	NCP514	0.0014	Passed	5.2000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Boys Locker #2	NCP515	0.0013	Passed	5.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Girl Locker #1	NCP516	0.0013	Passed	5.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Girl Locker #2	NCP517	0.0014	Passed	5.4000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Lower Custodial Sink	NCP518	0.0021	Passed	1.9000	Passed	Remediation has been completed
Parrsboro Regional High School	Staff #1	NCP519	0.0016	Passed	2.4000	Exceeds Limit	Signage to be added to instruct handwashing only
Parrsboro Regional High School	Staff #2	NCP520	0.0020	Passed	1.5000	Passed	Remediation has been completed
Parrsboro Regional High School	Room 214 #1	NCP521	0.0000	Passed	0.2600	Passed	Remediation has been completed
Parrsboro Regional High School	Room 214 #2	NCP522	0.0000	Passed	0.2900	Passed	Remediation has been completed
Parrsboro Regional High School	Room 214 #3	NCP523	0.0000	Passed	0.3100	Passed	Remediation has been completed
Parrsboro Regional High School	Room 214 #4	NCP524	0.0006	Passed	0.3000	Passed	Remediation has been completed
Parrsboro Regional High School	Room 213 #1	NCP525	0.0008	Passed	0.4400	Passed	Remediation has been completed
Parrsboro Regional High School	Room 213 #2	NCP526	0.0000	Passed	0.2900	Passed	Remediation has been completed
Parrsboro Regional High School	Room 213 #3	NCP527	0.0000	Passed	0.2700	Passed	Remediation has been completed
Parrsboro Regional High School	Room 213 #4	NCP528	0.0012	Passed	0.3600	Passed	Remediation has been completed
Parrsboro Regional High School	Upper Custodial	NCP529	0.0013	Passed	0.5200	Passed	Remediation has been completed
Pictou Academy	Source - Municipal	MTG917	0.0028	Passed	0.1200	Passed	Remediation has been completed
Pictou Academy	Staff Room Kitchen Taps	MTG918	0.0017	Passed	0.2100	Passed	Remediation has been completed
Pictou Academy	Bottle Filler 1st Floor	MTG919	0.0010	Passed	0.3500	Passed	Remediation has been completed
Pictou Academy	Room 104	MTG920	0.0039	Passed	0.0840	Passed	Remediation has been completed
Pictou Academy	Room 105	MTH055	0.0052	Passed	0.0230	Passed	Remediation has been completed
Pictou Academy	Family Studies, Sink A	MTH056	0.3200	Exceeds Limit	0.8700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Pictou Academy	Family Studies, Sink B	MTH057	0.0068	Exceeds Limit	0.0360	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Pictou Academy	Family Studies, Sink C	MTH058	0.0180	Exceeds Limit	0.1700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Pictou Academy	Family Studies, Sink D	MTH059	0.0017	Passed	0.0190	Passed	Remediation has been completed
Pictou Academy	Family Studies, Sink E	MTH060	0.0011	Passed	0.0130	Passed	Remediation has been completed
Pictou Academy	Photocopy Room Sink	MTH062	0.0008	Passed	0.0130	Passed	Remediation has been completed
Pictou Academy Gym	Bottle Filler Main Entry	PYA775	0.0045	Passed	0.2400	Passed	Remediation has been completed
Pugwash District High School	Cafeteria Sink #1	MOP845	0.0006	Passed	0.0950	Passed	Remediation has been completed
Pugwash District High School	Cafeteria Sink #2	MOP846	0.0000	Passed	0.0990	Passed	Remediation has been completed
Pugwash District High School	Bottle Filler - Cafeteria	MOP847	0.0000	Passed	0.0330	Passed	Remediation has been completed
Pugwash District High School	Bottle Filler - Gym	MOP848	0.0005	Passed	0.1700	Passed	Remediation has been completed
Pugwash District High School	Lobby Bottle Filler	PZN678	0.0000	Passed	0.1300	Passed	Remediation has been completed
Pugwash District High School	Music Room	MOP850	0.0017	Passed	0.0680	Passed	Remediation has been completed
Pugwash District High School	Learning Centre	MOP851	0.0000	Passed	0.0860	Passed	Remediation has been completed
Pugwash District High School	Staff Room	MOP852	0.0000	Passed	0.0980	Passed	Remediation has been completed
Pugwash District High School	Room #109 Lab	MOP853	0.0030	Passed	0.0950	Passed	Remediation has been completed
Pugwash District High School	Room #122	MOP854	0.0014	Passed	0.1000	Passed	Remediation has been completed
Pugwash District High School	Main Office	MOP855	0.0054	Passed	0.1300	Passed	Remediation has been completed
Pugwash District High School	Office Bottle Filler	PZN681	0.0000	Passed	0.1100	Passed	Remediation has been completed
Pugwash District High School	Food Lab Sink #1	MOP857	0.0013	Passed	0.0750	Passed	Remediation has been completed
Pugwash District High School	Food Lab Sink #2	MOP858	0.0028	Passed	0.0990	Passed	Remediation has been completed
Pugwash District High School	Food Lab Sink #3	MOP859	0.0019	Passed	0.0820	Passed	Remediation has been completed
Pugwash District High School	Food Lab Sink #4	MOP860	0.0013	Passed	0.0800	Passed	Remediation has been completed
Pugwash District High School	Room 102 Sink	MOP861	0.0013	Passed	0.0960	Passed	Remediation has been completed
Pugwash District High School	Junior Wing Bottle Filler	PZN679	0.0000	Passed	0.1200	Passed	Remediation has been completed
Pugwash District High School	Library Storage Room Sink	MOP863	0.0022	Passed	0.0920	Passed	Remediation has been completed
Pugwash District High School	Bottle Filler Upper Circle	MOP864	0.0015	Passed	0.5000	Passed	Remediation has been completed
Pugwash District High School	Art Lab Sink #1	MOP865	0.0055	Exceeds Limit	0.0810	Passed	Signage to be added to instruct handwashing only
Pugwash District High School	Art Lab Sink #2	MOP866	0.0016	Passed	0.1200	Passed	Remediation has been completed
Pugwash District High School	Room J	NIK935	0.0000	Passed	0.0760	Passed	Remediation has been completed
Pugwash District High School	Café Hand Sink	NU597	0.0013	Passed	0.0880	Passed	Remediation has been completed
Pugwash District High School	Girls Locker #1	NU598	0.0000	Passed	0.0800	Passed	Remediation has been completed
Pugwash District High School	Girls Locker #2	NU599	0.0000	Passed	0.0730	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Pugwash District High School	Girls Locker #3	NU600	0.0000	Passed	0.0730	Passed	Remediation has been completed
Pugwash District High School	Boys Locker #1	NU601	0.0000	Passed	0.1100	Passed	Remediation has been completed
Pugwash District High School	Boys Locker #2	NU602	0.0000	Passed	0.1100	Passed	Remediation has been completed
Pugwash District High School	Boys Locker #3	NU603	0.0000	Passed	0.1200	Passed	Remediation has been completed
Pugwash District High School	Gym #1	NU604	0.0008	Passed	0.1200	Passed	Remediation has been completed
Pugwash District High School	Gym #2	NU605	0.0007	Passed	0.0920	Passed	Remediation has been completed
Pugwash District High School	Lobby Girls #1	NU606	0.0006	Passed	0.0380	Passed	Remediation has been completed
Pugwash District High School	Lobby Girls #3	NU607	0.0000	Passed	0.0400	Passed	Remediation has been completed
Pugwash District High School	Lobby Boys #1	NU608	0.0000	Passed	0.0400	Passed	Remediation has been completed
Pugwash District High School	Lobby Boys #3	NU610	0.0000	Passed	0.0400	Passed	Remediation has been completed
Pugwash District High School	Lower Lobby Custodial	NU611	0.0000	Passed	0.0380	Passed	Remediation has been completed
Pugwash District High School	Room 145 #1	NU612	0.0000	Passed	0.0230	Passed	Remediation has been completed
Pugwash District High School	Room 145 #2	NU613	0.0000	Passed	0.0270	Passed	Remediation has been completed
Pugwash District High School	Room 131 #2	NU615	0.0000	Passed	0.0490	Passed	Remediation has been completed
Pugwash District High School	Staff #1	NU616	0.0000	Passed	0.1700	Passed	Remediation has been completed
Pugwash District High School	Staff #2	NU617	0.0000	Passed	0.1700	Passed	Remediation has been completed
Pugwash District High School	Room 129	NU618	0.0009	Passed	0.1100	Passed	Remediation has been completed
Pugwash District High School	Main Office	NU619	0.0012	Passed	0.1100	Passed	Remediation has been completed
Pugwash District High School	Room 119 #1	NU620	0.0006	Passed	0.0750	Passed	Remediation has been completed
Pugwash District High School	Room 119 #2	NU621	0.0000	Passed	0.0750	Passed	Remediation has been completed
Pugwash District High School	Room 118 #1	NU622	0.0006	Passed	0.0750	Passed	Remediation has been completed
Pugwash District High School	Room 118 #2	NU623	0.0005	Passed	0.0770	Passed	Remediation has been completed
Pugwash District High School	Room 118 #3	NU624	0.0019	Passed	0.0760	Passed	Remediation has been completed
Pugwash District High School	Room 118 #4	NU625	0.0007	Passed	0.0810	Passed	Remediation has been completed
Pugwash District High School	Lower Circle Custodial	NU626	0.0008	Passed	0.0820	Passed	Remediation has been completed
Pugwash District High School	Room 221	NU627	0.0015	Passed	0.1200	Passed	Remediation has been completed
Pugwash District High School	Room 220	NU628	0.0006	Passed	0.0930	Passed	Remediation has been completed
Pugwash District High School	Upper Circle Custodial	NU629	0.0009	Passed	0.0810	Passed	Remediation has been completed
Pugwash District High School	Upper Girls #1	NU630	0.0006	Passed	0.0740	Passed	Remediation has been completed
Pugwash District High School	Upper Girls #2	NU631	0.0000	Passed	0.0720	Passed	Remediation has been completed
Pugwash District High School	Upper Girls #3	NU632	0.0000	Passed	0.0730	Passed	Remediation has been completed
Pugwash District High School	Upper Girls #4	NU633	0.0000	Passed	0.0710	Passed	Remediation has been completed
Pugwash District High School	Upper Boys #1	NU634	0.0000	Passed	0.0760	Passed	Remediation has been completed
Pugwash District High School	Upper Boys #2	NU635	0.0000	Passed	0.0730	Passed	Remediation has been completed
Pugwash District High School	Upper Boys #3	NU636	0.0000	Passed	0.0720	Passed	Remediation has been completed
Rawdon District Elementary School	Bottle Filler Main Floor	QEU006	0.0000	Passed	0.0120	Passed	Remediation has been completed
Rawdon District Elementary School	Main Tap in Kitchen	QEU005	0.0018	Passed	0.0005	Passed	Remediation has been completed
Rawdon District Elementary School	Hand Washing Tap Kitchen	QEU004	0.0084	Exceeds Limit	0.0015	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	Bottle Filler Upstairs	QEU007	0.0000	Passed	0.0140	Passed	Remediation has been completed
Rawdon District Elementary School	Staff Room Tap Upstairs	QEU008	0.0051	Passed	0.0006	Passed	Remediation has been completed
Rawdon District Elementary School	Raw Water on Pressure Tank	LCP160	0.0021	Passed	0.0130	Passed	Remediation has been completed
Rawdon District Elementary School	L/L - Boys Washroom Left, T3	NUU933	0.0023	Passed	0.3400	Passed	Remediation has been completed
Rawdon District Elementary School	L/L - Boys Washroom Middle, T4	NUU934	0.1400	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Boys Washroom Right, T5	NUU935	0.12	Exceeds Limit	0.3600	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Custodial Closet 105, T6	NUU936	0.0390	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Girls Washroom Left, T7	NUU937	1.3000	Exceeds Limit	0.4100	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Girls Washroom Middle, T8	NUU938	0.4700	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Girls Washroom Right, T9	NUU939	0.4300	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Gym Girls Locker Room, T10	NUU940	0.3000	Exceeds Limit	0.0530	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Gym Office, T11	NUU941	0.0190	Exceeds Limit	0.0720	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	L/L - Boys Locker Room, T12	NUU942	0.8600	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Boys Washroom Tub Sink, T13	NUU943	0.3200	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Boys Washroom Left, T14	NUU944	0.0270	Exceeds Limit	0.2800	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Boys Washroom Middle, T15	NUU945	0.0610	Exceeds Limit	0.0002	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Boys Washroom Right, T16	NUU946	0.0210	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Girls Washroom Left, T17	NUU947	0.0260	Exceeds Limit	0.5400	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Girls Washroom Middle, T18	NUU948	0.0150	Exceeds Limit	0.0360	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Girls Washroom Right, T19	NUU949	0.0230	Exceeds Limit	0.0260	Passed	Signage to be added to instruct handwashing only
Rawdon District Elementary School	U/F - Staff Washroom, T20	NUU950	0.0023	Passed	0.0240	Passed	Remediation has been completed
Redcliff Middle School	Boiler Room, T1	NKU457	0.0000	Passed	0.0930	Passed	Remediation has been completed
Redcliff Middle School	Tap on Left in Music Room, T2	MOY815	0.0016	Passed	0.1700	Passed	Remediation has been completed
Redcliff Middle School	Tap on Right in Music Room, T3	MOY816	0.0026	Passed	0.1700	Passed	Remediation has been completed
Redcliff Middle School	Tech Ed Room, T4	MOY817	0.0000	Passed	0.1900	Passed	Remediation has been completed
Redcliff Middle School	Against wall in Family Studies, T7	MOY818	0.0000	Passed	0.1700	Passed	Remediation has been completed
Redcliff Middle School	Tap 1st one to right in Family Studies, T9	MOY819	0.0000	Passed	0.3200	Passed	Remediation has been completed
Redcliff Middle School	Tap 2nd to right in Family Studies, T6	NKU458	0.0013	Passed	0.2400	Passed	Remediation has been completed
Redcliff Middle School	Tap 1st one to left in Family Studies, T8	NKU459	0.0010	Passed	0.2500	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Redcliff Middle School	Tap 2nd one to left in Family Studies, T5	NKU460	0.0009	Passed	0.2000	Passed	Remediation has been completed
Redcliff Middle School	Tap in Library Office, T13	MOY823	0.0012	Passed	0.4000	Passed	Remediation has been completed
Redcliff Middle School	Tap on Island in Kitchen, T21	MOY824	0.0038	Passed	0.3200	Passed	Remediation has been completed
Redcliff Middle School	Main Tap in Kitchen, T23	MOY825	0.0009	Passed	0.3200	Passed	Remediation has been completed
Redcliff Middle School	New Bottle Filler Outside Custodial Room by Gym, F1	PLM118	0.0000	Passed	0.0380	Passed	Remediation has been completed
Redcliff Middle School	New Bottle Filler Across from Room 1055, F2	PLM119	0.0008	Passed	0.1600	Passed	Remediation has been completed
Redcliff Middle School	New Bottle Filler Across from Room 1060, F3	PLM120	0.0006	Passed	0.2100	Passed	Remediation has been completed
Redcliff Middle School	Staff Room Tap to the Left, T40	MOY829	0.0029	Passed	0.3600	Passed	Remediation has been completed
Redcliff Middle School	Staff Room Tap to the Right, T39	MOY830	0.0000	Passed	0.4500	Passed	Remediation has been completed
Redcliff Middle School	Learning Centre Tap on Hallway Wall, T41	MOY831	0.0006	Passed	0.4000	Passed	Remediation has been completed
Redcliff Middle School	Learning Centre to the Left, T43	MOY832	0.0025	Passed	0.1500	Passed	Remediation has been completed
Redcliff Middle School	New Bottle Filler Across from Room 1080, F4	PLM121	0.0000	Passed	0.0290	Passed	Remediation has been completed
Redcliff Middle School	Art Room Tap first on right, T52	MOY834	0.0007	Passed	0.5300	Passed	Remediation has been completed
Redcliff Middle School	Art Room Tap 2nd on right, T53	MOY835	0.0012	Passed	0.6400	Passed	Remediation has been completed
Redcliff Middle School	Cafeteria Kit. 1008A, Dish Spray Sink, T24	NDR343	0.0061	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Redcliff Middle School	Custodial 1003A Floor Sink, T25	NDR344	0.0024	Passed	0.5600	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1044, Left Tap, T26	NDR345	0.0014	Passed	0.1900	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1044, Middle Tap, T27	NDR346	0.0017	Passed	0.2700	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1044 Right Tap, T28	NDR347	0.0016	Passed	0.1500	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1045, Left Tap, T29	NDR348	0.0013	Passed	0.3700	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1045, Middle Tap, T30	NDR349	0.0015	Passed	0.2300	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1045, Right Tap, T31	NDR350	0.0010	Passed	0.2200	Passed	Remediation has been completed
Redcliff Middle School	Science Lab 1052 Counter Sink, T33	NDR351	0.0120	Exceeds Limit	0.0590	Passed	Signage to be added to instruct handwashing only
Redcliff Middle School	Boys Washroom 1018 Left Tap, T10	NDR352	0.0007	Passed	0.1200	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1018 Middle Tap, T11	NDR353	0.0024	Passed	0.2300	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1018 Right Tap, T12	NDR354	0.0012	Passed	0.1300	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1017 Left Tap, T14	NDR355	0.0007	Passed	0.1800	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1017 Middle Tap, T15	NDR356	0.0016	Passed	0.2000	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom 1017, Right Tap, T16	NDR357	0.0010	Passed	0.0740	Passed	Remediation has been completed
Redcliff Middle School	Girls Locker 1014, T17	NDR358	0.0016	Passed	0.1200	Passed	Remediation has been completed
Redcliff Middle School	Gym Office 1015, T18	NDR359	0.0018	Passed	0.3600	Passed	Remediation has been completed
Redcliff Middle School	Gym Office 1012, T19	NDR360	0.0021	Passed	0.2600	Passed	Remediation has been completed
Redcliff Middle School	Boys Locker 1011, T20	NDR361	0.0007	Passed	0.2200	Passed	Remediation has been completed
Redcliff Middle School	Science Lab 1052 Counter Sink, Left Tap, T34	NDR362	0.0120	Exceeds Limit	0.0470	Passed	Signage to be added to instruct handwashing only
Redcliff Middle School	Staff Washroom 1100, T35	NDR363	0.0043	Passed	0.2900	Passed	Remediation has been completed
Redcliff Middle School	Sick Room 1-1097 Hand Wash Sink, T36	NDR364	0.0031	Passed	0.5200	Passed	Remediation has been completed
Redcliff Middle School	Sick Room 2-1096 Hand Wash Sink, T37	NDR365	0.0018	Passed	0.6300	Passed	Remediation has been completed
Redcliff Middle School	Staff Washroom 1099, T38	NDR366	0.0025	Passed	0.2900	Passed	Remediation has been completed
Redcliff Middle School	Resource Washroom 1085, T44	NDR367	0.0010	Passed	0.2800	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1083, Left Tap, T45	NDR368	0.0012	Passed	0.2200	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1083 Middle Tap, T46	NDR369	0.0016	Passed	0.1800	Passed	Remediation has been completed
Redcliff Middle School	Boys Washroom 1083 Right Tap, T47	NDR370	0.0015	Passed	0.1500	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom Left Tap, T48	NDR371	0.0011	Passed	0.1600	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom Middle Tap, T49	NDR372	0.0017	Passed	0.3100	Passed	Remediation has been completed
Redcliff Middle School	Girls Washroom Right Tap, T50	NDR373	0.0010	Passed	0.3300	Passed	Remediation has been completed
Redcliff Middle School	Custodial 1068A Floor Sink, T51	NDR374	0.0072	Exceeds Limit	0.4600	Passed	Signage to be added to instruct handwashing only
Redcliff Middle School	Cafeteria Kitchen Hand Sink	NDR375	0.0012	Passed	0.3200	Passed	Remediation has been completed
River Hebert District School	Café #1	LEJ150	0.0000	Passed	0.0036	Passed	Remediation has been completed
River Hebert District School	Café #2	LKO208	0.0000	Passed	0.0000	Passed	Remediation has been completed
River Hebert District School	Café #3	LEJ152	0.0000	Passed	0.0070	Passed	Remediation has been completed
River Hebert District School	Raw Water Boiler Room	LYB514	0.0000	Passed	0.019	Passed	Remediation has been completed
River Hebert District School	Music Room Tap	LEJ155	0.0030	Passed	0.0360	Passed	Remediation has been completed
River Hebert District School	Bottle Filler by Learning Centre	LEJ158	0.0000	Passed	0.0069	Passed	Remediation has been completed
River Hebert District School	Food Lab #1	LKO206	0.0000	Passed	0.0000	Passed	Remediation has been completed
River Hebert District School	Food Lab #2	LKO207	0.0000	Passed	0.0002	Passed	Remediation has been completed
River Hebert District School	Food Lab #3	LEJ162	0.0000	Passed	0.0230	Passed	Remediation has been completed
River Hebert District School	Staff Room Sink	LEJ228	0.0000	Passed	0.0044	Passed	Remediation has been completed
River Hebert District School	Bottle Filler Replaced Bottle Filler by Wood Shop	PFH114	0.0000	Passed	0.0100	Passed	Remediation has been completed
River Hebert District School	Technology Room Sink	LEJ230	0.0000	Passed	0.1500	Passed	Remediation has been completed
River Hebert District School	Sink in Laundry Room	LEJ231	0.0008	Passed	0.0063	Passed	Remediation has been completed
River Hebert District School	Bottle Filler in Upper Hallway	LEJ232	0.0000	Passed	0.0110	Passed	Remediation has been completed
River Hebert District School	Science Room Sink	LKO209	0.0000	Passed	0.0000	Passed	Remediation has been completed
River Hebert District School	Source	LKO210	0.0000	Passed	0.0001	Passed	Signage to be added to instruct handwashing only
River Hebert District School	Custodial Closet Lower Hall	NDQ960	0.0000	Passed	0.0200	Passed	Remediation has been completed
River Hebert District School	Youth Health	QGD964	0.00064	Passed	0.0200	Passed	Remediation has been completed
River Hebert District School	Lower Girls #1	NDQ962	0.0006	Passed	0.0250	Passed	Remediation has been completed
River Hebert District School	Lower Girls #2	NDQ963	0.0037	Passed	0.1900	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
River Hebert District School	Lower Girls #3	NDQ964	0.0000	Passed	0.1100	Passed	Remediation has been completed
River Hebert District School	Lower Boys #1	QGD968	0.0000	Passed	0.0025	Passed	Remediation has been completed
River Hebert District School	Lower Boys #2	NDQ966	0.0000	Passed	0.0390	Passed	Remediation has been completed
River Hebert District School	Lower Boys #3	NDQ967	0.0020	Passed	0.0920	Passed	Remediation has been completed
River Hebert District School	Boys Locker Room	NDQ968	0.0006	Passed	0.1400	Passed	Remediation has been completed
River Hebert District School	Girls Locker Room	NDQ969	0.0000	Passed	0.0120	Passed	Remediation has been completed
River Hebert District School	Learning Centre	NDQ970	0.0000	Passed	0.0047	Passed	Remediation has been completed
River Hebert District School	Primary Washroom	NDQ971	0.0000	Passed	0.0200	Passed	Remediation has been completed
River Hebert District School	Main Boys #1	NDQ972	0.0000	Passed	0.0052	Passed	Remediation has been completed
River Hebert District School	Main Boys #2	NDQ973	0.0000	Passed	0.0043	Passed	Remediation has been completed
River Hebert District School	Main Girls #1	NDQ974	0.0000	Passed	0.0054	Passed	Remediation has been completed
River Hebert District School	Main Girls #2	NDQ975	0.0000	Passed	0.0045	Passed	Remediation has been completed
River Hebert District School	Custodial Closet By Gym	NDQ976	0.0007	Passed	0.0051	Passed	Remediation has been completed
River Hebert District School	Main Office	NDQ977	0.0000	Passed	0.0014	Passed	Remediation has been completed
River Hebert District School	Upper Girls #1	QGD965	0.0030	Passed	0.0330	Passed	Remediation has been completed
River Hebert District School	Upper Girls #2	QGD966	0.01200	Exceeds Limit	0.0490	Passed	Signage to be added to instruct handwashing only
River Hebert District School	Upper Girls #3	QGD967	0.0140	Exceeds Limit	0.0540	Passed	Signage to be added to instruct handwashing only
River Hebert District School	Upper Boys #1	NDQ981	0.0014	Passed	0.0420	Passed	Remediation has been completed
River Hebert District School	Upper Boys #2	NDQ982	0.0010	Passed	0.0300	Passed	Remediation has been completed
River Hebert District School	Upper Boys #3	NDQ983	0.0014	Passed	0.0340	Passed	Remediation has been completed
River Hebert District School	Upper Custodial Closet	NDQ984	0.0006	Passed	0.0040	Passed	Remediation has been completed
River Hebert District School	Washroom By Elevator	NDQ985	0.0000	Passed	0.2600	Passed	Remediation has been completed
River Hebert District School	Staff Washroom	NDQ986	0.0000	Passed	0.0110	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Room 1166, F1	POR933	0.0015	Passed	0.2100	Passed	Remediation has been completed
Riverside Education Centre	Left Bottle Filler by Room 1161, F2	MSH581	0.0000	Passed	0.0640	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 1161, T14	OFM845	0.0030	Passed	0.1500	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 1164, T15	NUV083	0.0041	Passed	0.1900	Passed	Remediation has been completed
Riverside Education Centre	Design & Tech Rm Kitchen, T17	POR934	0.1200	Exceeds Limit	0.0940	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Riverside Education Centre	Bottle Filler by Room 1136, F3	POR935	0.0015	Passed	0.1700	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Room 1131, F4	MSH586	0.0020	Passed	0.0710	Passed	Remediation has been completed
Riverside Education Centre	Room 1136, Kitchen Tap, T25	MSH587	0.0050	Passed	0.0880	Passed	Remediation has been completed
Riverside Education Centre	Room 1133, Kitchen Tap, T32	NUV097	0.0039	Passed	0.0210	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Main Sink Tap, T36	MSH589	0.0024	Passed	0.1700	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Island Sink Tap, T35	MSH590	0.0024	Passed	0.0800	Passed	Remediation has been completed
Riverside Education Centre	Special Needs Kitchen Tap, T39	MSH591	0.0018	Passed	0.0960	Passed	Remediation has been completed
Riverside Education Centre	Special Needs Tap by Washer, T42	OFM847	0.0043	Passed	0.1400	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Room 2166, F5	MSH593	0.0006	Passed	0.0880	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Room 2161, F6	POR936	0.0005	Passed	0.3400	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 2161, T54	NUV114	0.0026	Passed	0.0190	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 2164, T56	OFM848	0.0041	Passed	0.1700	Passed	Remediation has been completed
Riverside Education Centre	Family Studies 1st Kitchen Tap by Entrance, T57	QEV425	0.0018	Passed	0.0120	Passed	Remediation has been completed
Riverside Education Centre	Family Studies 1st Kitchen Tap on Left, T59	QEV426	0.00098	Passed	0.0140	Passed	Remediation has been completed
Riverside Education Centre	Family Studies 2nd Kitchen Tap on Left, T61	QEV427	0.0015	Passed	0.0045	Passed	Remediation has been completed
Riverside Education Centre	Family Studies 1st Kitchen Tap on Right, T60	QEV428	0.00078	Passed	0.0110	Passed	Remediation has been completed
Riverside Education Centre	Family Studies 2nd Kitchen Tap on Right, T62	QEV429	0.00091	Passed	0.0035	Passed	Remediation has been completed
Riverside Education Centre	Family Studies Kitchen Tap on Far Wall, T58	QEV430	0.01200	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	IGS Room, T64	NUV122	0.00270	Passed	0.0180	Passed	Remediation has been completed
Riverside Education Centre	Room off Library Kitchen Tap, T63	MSH604	0.02300	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	Bottle Filler Outside of Staff Room, F7	MSH605	0.0000	Passed	0.0840	Passed	Remediation has been completed
Riverside Education Centre	Staff Room Kitchen Tap, T67	MSH606	0.0008	Passed	0.1300	Passed	Remediation has been completed
Riverside Education Centre	Tap in Washroom, T68	MSH607	0.0210	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	Bottle Filler by Room 2136, F8	MSH608	0.0012	Passed	0.0850	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Room 2131, F9	POR937	0.0011	Passed	0.5300	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 2136, T77	NUV138	0.0018	Passed	0.0710	Passed	Remediation has been completed
Riverside Education Centre	Kitchen Tap, Room 2133, T84	NUV140	0.0003	Passed	0.0190	Passed	Remediation has been completed
Riverside Education Centre	Main Office Kitchen Tap, T86	NUV148	0.0049	Passed	0.1400	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler Outside Music Room, F10	MSH613	0.0000	Passed	0.1100	Passed	Remediation has been completed
Riverside Education Centre	Room off Music Room Kitchen Tap, T96	OFM853	0.0850	Exceeds Limit	0.1500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Riverside Education Centre	Bottle Filler by Boys Locker Room, F11	MSH615	0.0022	Passed	0.1100	Passed	Remediation has been completed
Riverside Education Centre	Bottle Filler by Girls Locker Room, F12	MSH616	0.0008	Passed	0.1200	Passed	Remediation has been completed
Riverside Education Centre	L/L - Washroom by Elevator Left Tap, T1	NUU981	0.0150	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Washroom by Elevator Right Tap, T2	NUV069	0.0065	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Left, T3	NUV070	0.0220	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Middle, T4	NUV071	0.0075	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Right, T5	NUV072	0.0120	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Girls Washroom Left, T8	NUV073	0.0072	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Girls Washroom Middle, T7	NUV074	0.0087	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
Riverside Education Centre	L/L - Girls Right, T6	NUV075	0.0098	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Science 1166 Lab Sink Front by Whiteboard, T11	NUV076	0.0140	Exceeds Limit	0.4500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Science 1166 Right Back Wall, T12	NUV077	0.0039	Passed	0.2000	Passed	Remediation has been completed
Riverside Education Centre	L/L - Science 1166 Left Back Wall, T13	NUV078	0.0210	Exceeds Limit	0.3300	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Science 1166 Centre Right, T9	NUV079	0.0120	Exceeds Limit	0.5200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Science 1166 Centre Left, T10	NUV080	0.0500	Exceeds Limit	0.9300	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Custodial by 1164, T16	NUV081	0.0110	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Left, T19	NUV084	0.0059	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Middle, T20	NUV085	0.0140	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Boys Washroom Right, T21	NUV086	0.0083	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	L/L - Girls Washroom Left, T22	NUV087	0.0053	Passed	0.1300	Passed	Remediation has been completed
Riverside Education Centre	U/L - Girls Washroom Middle, T23	NUV088	0.0081	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom Right, T24	NUV089	0.0180	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom 1136 Kitchen Tap, T25	NUV090	0.0040	Passed	0.2200	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom 1131 Front Island, T28	NUV091	0.0024	Passed	0.1000	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom 1131 Left Front, T26	NUV092	0.0094	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom 1131 Left Back, T29	NUV093	0.0100	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom 1131 Right Front, T27	NUV094	0.0120	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom 1131 Right Back, T30	NUV095	0.0170	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Custodial by 1133, T31	NUV096	0.0034	Passed	0.1400	Passed	Remediation has been completed
Riverside Education Centre	U/L - L/L - Classroom 1133, T32	NUV097	0.0039	Passed	0.2100	Passed	Remediation has been completed
Riverside Education Centre	U/L - Main Kitchen Sprayer, T37	NUV098	0.0044	Passed	0.1500	Passed	Remediation has been completed
Riverside Education Centre	U/L - Main Kitchen Handwash, T34	NUV099	0.0062	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Custodial Storage, T38	NUV100	0.0210	Exceeds Limit	0.5900	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Maintenance Room, T33	NUV101	0.0220	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Special Needs 2170 Washroom Left, T40	NUV102	0.0073	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Special Needs 2170 Washroom Right, T41	NUV103	0.0100	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Left, T43	NUV105	0.0070	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Middle, T44	NUV106	0.0060	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Right, T45	NUV107	0.0120	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom Left, T46	NUV108	0.0077	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom Middle, T47	NUV109	0.0048	Passed	0.1300	Passed	Remediation has been completed
Riverside Education Centre	U/L - Girls Washroom Right, T48	NUV110	0.0014	Passed	0.1100	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom 2166 Island by White Board, T51	NUV111	0.0030	Passed	0.1800	Passed	Remediation has been completed
Riverside Education Centre	U/L - Custodial by 2164, T55	NUV112	0.0000	Passed	0.0490	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom 2161 Kitchen Tap, T54	NUV114	0.0026	Passed	0.1900	Passed	Remediation has been completed
Riverside Education Centre	U/L - Family Studies Far Wall Kitchen Tap Left, T58	NUV120	0.0035	Passed	0.1300	Passed	Remediation has been completed
Riverside Education Centre	U/L - Room Off of Library Kitchen Tap, T64	NUV121	0.0044	Passed	0.2200	Passed	Remediation has been completed
Riverside Education Centre	U/L - IGS Room Kitchen Tap, T64	NUV122	0.0027	Passed	0.1800	Passed	Remediation has been completed
Riverside Education Centre	U/L - Washroom by Staff Room Left, T70	NUV123	0.0021	Passed	0.1500	Passed	Remediation has been completed
Riverside Education Centre	U/L - Washroom by Staff Room Right, T69	NUV124	0.0025	Passed	0.1000	Passed	Remediation has been completed
Riverside Education Centre	U/L - Personal Development Room Washroom Left, T66	NUV125	0.0160	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Personal Development Room Washroom Right, T65	NUV126	0.0068	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Left, T71	NUV127	0.0170	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Middle, T72	NUV128	0.0100	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom Right, T73	NUV129	0.0091	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washrom Left, T74	NUV130	0.0190	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom Middle, T75	NUV131	0.0110	Exceeds Limit	0.1300	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom Right, T76	NUV132	0.0084	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom Lab 2131 Front Island, T80	NUV133	0.0009	Passed	0.1300	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom Lab 2131 Left Front, T78	NUV134	0.0015	Passed	0.1600	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom Lab 2131 Left Back, T81	NUV135	0.0015	Passed	0.1700	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom Lab 2131 Right Front, T79	NUV136	0.0019	Passed	0.1800	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom Lab 2131 Right Back, T82	NUV137	0.0016	Passed	0.1100	Passed	Remediation has been completed
Riverside Education Centre	U/L - Classroom 2136 Kitchen Tap, T77	NUV138	0.0018	Passed	0.0710	Passed	Remediation has been completed
Riverside Education Centre	U/L - Custodial Room By 2133, T83	NUV139	0.0077	Exceeds Limit	0.6200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Classroom 2133 Kitchen Tap, T84	NUV140	0.0030	Passed	0.1900	Passed	Remediation has been completed
Riverside Education Centre	U/L - Boys Washroom by Main Kitchen Left, T90	NUV141	0.0140	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom by Main Kitchen Middle Left, T89	NUV142	0.0120	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom by Main Middle Right, T88	NUV143	0.0180	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Washroom by Main Kitchen Right, T87	NUV144	0.0140	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom by Main Kitchen Left, T91	NUV145	0.0051	Passed	0.1700	Passed	Remediation has been completed
Riverside Education Centre	U/L - Girls Washroom by Main Middle Left, T92	NUV146	0.0150	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom by Main Kitchen Middle, T93	NUV147	0.0240	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom by Main Kitchen Middle Right, T94	NUV148	0.0210	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Washroom by Main Kitchen Right, T95	NUV149	0.0097	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	Bottle Filler by Girls Locker Room, F12	POR939	0.0000	Passed	0.31	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
							To be updated as work progresses. All schools have clean drinkable bottled water available.
Riverside Education Centre	U/L - Bottle Filler Main Lobby, F13	POR938	0.0031	Passed	0.25	Passed	Remediation has been completed
Riverside Education Centre	U/L - Main Office Washroom, T85	NUV151	0.0000	Passed	0.1400	Passed	Remediation has been completed
Riverside Education Centre	U/L - Main Office Supply Room, T86	NUV152	0.0049	Passed	0.1400	Passed	Remediation has been completed
Riverside Education Centre	U/L - Girls Locker Left, T99	NUV153	0.0250	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Girls Locker Middle, T100	NUV154	0.0045	Passed	0.1100	Passed	Remediation has been completed
Riverside Education Centre	U/L - Girls Locker Right, T101	NUV155	0.0150	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Right Gym Office, T97	NUV156	0.0240	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Locker Left, T102	NUV157	0.0180	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Locker Middle, T103	NUV158	0.0220	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Boys Locker Right, T104	NUV159	0.0210	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Left Gym Office, T98	NUV160	0.0160	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Riverside Education Centre	U/L - Schools Plus Back Room Handwash, T105	NUV162	0.0037	Passed	0.3000	Passed	Remediation has been completed
Riverside Education Centre	Industrial Arts Floor Sink, T150	NUV163	0.0020	Passed	0.0890	Passed	Remediation has been completed
Salt Springs Elementary School	Source - Well	NHY489	0.0014	Passed	0.1200	Passed	Remediation has been completed
Salt Springs Elementary School	Office 001 Principal's Office Sink	OPX438	0.0150	Exceeds Limit	0.0830	Passed	Remediation has been completed
Salt Springs Elementary School	Office 019 Staff Rm Sink	QMD452	0	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Kitchen Sink A	MOQ044	0.0012	Passed	0.0330	Passed	Remediation has been completed
Salt Springs Elementary School	Kitchen Sink B	MOQ045	0.0021	Passed	0.0630	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 010	OPX440	0.0360	Exceeds Limit	0.0960	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 012	QMD453	0.0000	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 014	OPX442	0.0004	Passed	0.0730	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 015	MOQ049	0.0043	Passed	0.0650	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 016	QMD454	0.0000	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 017	OPX011	0.0008	Passed	0.0920	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 013	QMD455	0.0000	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Classroom 011	MOQ053	0.0031	Passed	0.0520	Passed	Remediation has been completed
Salt Springs Elementary School	Bottle Filler in Entry Way	MOQ054	0.0020	Passed	0.0290	Passed	Remediation has been completed
Salt Springs Elementary School	Bottle Filler Classroom Hallway	MOQ055	0.0000	Passed	0.2300	Passed	Remediation has been completed
Salt Springs Elementary School	Bottle Filler in Gym	MOQ056	0.0033	Passed	0.0420	Passed	Remediation has been completed
Salt Springs Elementary School	Custodial Closet	NKE372	0.1300	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Gym Washroom Girls	NKE373	0.0150	Exceeds Limit	0.0004	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Gym Washroom Boys	NKE374	0.0009	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Staff Washroom Hall	NKE375	0.0019	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Staff Washroom Office	NKE376	0.0110	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Washroom Girls 1 Sink A	NKE377	0.0017	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Washroom Girls 1 Sink B	NKE378	0.0030	Passed	0.0001	Passed	Remediation has been completed
Salt Springs Elementary School	Washroom Girls 1 Sink C	NKE379	0.0042	Passed	0.0001	Passed	Remediation has been completed
Salt Springs Elementary School	Hall Janitor Closet	NKE380	0.0074	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Washroom Boys 1 Sink A	NKE381	0.0061	Exceeds Limit	0.0000	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Washroom Boys 1 Sink B	NKE382	0.0071	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Washroom Boys 1 Sink C	NKE383	0.0056	Exceeds Limit	0.0001	Passed	Signage to be added to instruct handwashing only
Salt Springs Elementary School	Washroom PP Girls Sink	NKE384	0.0031	Passed	0.0000	Passed	Remediation has been completed
Salt Springs Elementary School	Washroom PP Boys Sink	NKE385	0.0019	Passed	0.0000	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 107 Office Treatment Rm	LCP053	0.0021	Passed	0.1600	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 109 Staff Rm	QMD452	0.0000	Passed	0.0000	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 110 Classroom	QXT105	0.0027	Passed	0.0035	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 154 Sprinkler Rm (Raw Water)	PXB993	0.0083	Exceeds Limit	0.0066	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Rm 154 Sprinkler Rm (Filtered)	PXG994	0.0089	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Rm 124 Classroom	LCP058	0.0027	Passed	0.1200	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 125 Classroom	LCP059	0.0019	Passed	0.1100	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 135 Kitchen Sink A	QMO678	0.0012	Passed	0.0034	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 135 Kitchen Sink B	QMO679	0.00093	Passed	0.0037	Passed	Remediation has been completed
Scotsburn Elementary School	Rm 142 Preprimary	LCP062	0.0230	Exceeds Limit	0.0830	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Scotsburn Elementary School	Corridor 2 Hallway Bottle Filler	PXG997	0.0023	Passed	0.0570	Passed	Remediation has been completed
Scotsburn Elementary School	Custodial Closet	NJX670	0.0037	Passed	0.0056	Passed	Remediation has been completed
Scotsburn Elementary School	Gym Staff Washroom	NJX671	0.0170	Exceeds Limit	0.0061	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Gym Boys Washroom	NJX672	0.0026	Passed	0.0051	Passed	Remediation has been completed
Scotsburn Elementary School	Gym Girls Washroom	NJX673	0.0034	Passed	0.0090	Passed	Remediation has been completed
Scotsburn Elementary School	Staff Washroom Male	NJX674	0.0023	Passed	0.0048	Passed	Remediation has been completed
Scotsburn Elementary School	Staff Washroom Female	NJX675	0.0077	Exceeds Limit	0.0074	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Washroom Boys, Sink A	NJX676	0.0014	Passed	0.0084	Passed	Remediation has been completed
Scotsburn Elementary School	Washroom Boys, Sink B	NJX677	0.0041	Passed	0.0078	Passed	Remediation has been completed
Scotsburn Elementary School	Washroom Girls, Sink A	NJX678	0.0310	Exceeds Limit	0.0072	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Washroom Girls, Sink B	NJX679	0.0480	Exceeds Limit	0.0091	Passed	Signage to be added to instruct handwashing only
Scotsburn Elementary School	Gym Bottle Filler	PXG998	0.0030	Passed	0.0300	Passed	Remediation has been completed
Shubenacadie District Elementary School	Room 156, Kitchen Tap, T8	MSW133	0.0033	Passed	0.5400	Passed	Remediation has been completed
Shubenacadie District Elementary School	Room 138 Kitchen Tap, T38	RNL354	0.0003	Passed	0.1100	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Shubenacadie District Elementary School	Room 139, Kitchen Tap, T37	QSB004	0.0023	Passed	0.0640	Passed	Remediation has been completed
Shubenacadie District Elementary School	Main Kitchen Double Sink Left Hand Tap, T34	QSB005	0.0014	Passed	0.0170	Passed	Remediation has been completed
Shubenacadie District Elementary School	Staff Room 132 Kitchen Tap, T20	QSB002	0.0035	Passed	0.0160	Passed	Remediation has been completed
Shubenacadie District Elementary School	Bottle Filler Across from Staff Room, F5	QSB001	0.0026	Passed	0.0960	Passed	Remediation has been completed
Shubenacadie District Elementary School	Main Kitchen Double Sink Right Hand Tap, T35	QSB006	0.00088	Passed	0.0350	Passed	Remediation has been completed
Shubenacadie District Elementary School	Main Kitchen Single Sink Tap, T36	QSB007	0.00089	Passed	0.0130	Passed	Remediation has been completed
Shubenacadie District Elementary School	Fountain by Main Kitchen, F6	QSB008	0.0000	Passed	0.1000	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Left, T1	NUV662	0.0081	Exceeds Limit	0.7900	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Girls Washroom Middle, T2	NUV733	0.0029	Passed	0.6700	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Right, T3	NUV734	0.0240	Exceeds Limit	0.7200	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Custodial Room by Girls Washroom, T4	NUV735	0.0280	Exceeds Limit	0.5900	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Boys Washroom Left, T7	NUV736	0.0150	Exceeds Limit	2.7000	Exceeds Limit	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Boys Washroom Middle, T6	NUV737	0.0087	Exceeds Limit	2.6000	Exceeds Limit	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Boys Washroom Right, T5	NUV738	0.0058	Exceeds Limit	1.5000	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Office Washroom Left, T9	NUV739	0.0130	Exceeds Limit	0.4900	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Office Washroom Right, T10	NUV740	0.0120	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Principals Office 148, T11	NUV741	0.0074	Exceeds Limit	0.7300	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Pre-Primary 147, T12	NUV742	0.0042	Passed	0.5800	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom By 147 Left, T13	NUV743	0.0017	Passed	0.7500	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom by 147 Middle, T14	NUV744	0.0013	Passed	0.5700	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom by 147 Right, T15	NUV745	0.0012	Passed	0.6600	Passed	Remediation has been completed
Shubenacadie District Elementary School	Custodial Room, T16	NUV746	0.0038	Passed	0.5300	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Left, T19	NUV747	0.0026	Passed	0.8000	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Middle, T18	NUV748	0.0020	Passed	0.6600	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Right, T17	NUV749	0.0020	Passed	0.7700	Passed	Remediation has been completed
Shubenacadie District Elementary School	Staff Room Washroom Left, T21	NUV750	0.0011	Passed	0.3900	Passed	Remediation has been completed
Shubenacadie District Elementary School	Staff Room Washroom Right, T22	NUV751	0.0021	Passed	0.4600	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Gym Left, T26	NUV752	0.0059	Exceeds Limit	0.8200	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Girls Washroom Gym Room, T25	NUV753	0.0021	Passed	0.5400	Passed	Remediation has been completed
Shubenacadie District Elementary School	Girls Washroom Gym Room, T24	NUV754	0.0013	Passed	0.6100	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom Gym Left, T27	NUV755	0.0022	Passed	0.2900	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom Gym Middle, T28	NUV756	0.0023	Passed	0.2400	Passed	Remediation has been completed
Shubenacadie District Elementary School	Boys Washroom Gym Right, T29	NUV757	0.0014	Passed	0.5000	Passed	Remediation has been completed
Shubenacadie District Elementary School	Classroom 109 Washroom, T30	NUV758	0.0028	Passed	0.2300	Passed	Remediation has been completed
Shubenacadie District Elementary School	Classroom 100 Washroom, T31	NUV759	0.0016	Passed	0.1900	Passed	Remediation has been completed
Shubenacadie District Elementary School	Custodial by Gym, T32	NUV760	0.0049	Passed	0.8400	Passed	Remediation has been completed
Shubenacadie District Elementary School	Main Kitchen Handwash Sink, T33	NUV761	0.0032	Passed	0.6800	Passed	Remediation has been completed
Shubenacadie District Elementary School	Learning Centre Washroom, T39	NUV762	0.0210	Exceeds Limit	1.1000	Passed	Signage to be added to instruct handwashing only
Shubenacadie District Elementary School	Learning Centre Quiet Room, T40	NUV763	0.2400	Exceeds Limit	3.9000	Exceeds Limit	Faucet to be decommissioned, remediated, and retested. Other sources available
Shubenacadie District Elementary School	Room 148 Kitchen Tap, T41	RDF220	0.0033	Passed	0.0100	Passed	Remediation has been completed
Shubenacadie District Elementary School	Bottle Filler Acroff from Rm 146, F4	RDF221	0.0520	Exceeds Limit	0.0180	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
South Colchester Academy	Bottle Filler Replaced Gym Bottle Filler, F1	PEJ293	0.0000	Passed	0.0470	Passed	Remediation has been completed
South Colchester Academy	Sink 1(R) Classroom 1640, T19	OGV261	0.0008	Passed	0.0880	Passed	Remediation has been completed
South Colchester Academy	Sink 2(2) Classroom 1640, T20	OGV262	0.0011	Passed	0.0900	Passed	Remediation has been completed
South Colchester Academy	Sink 3(L) Classroom 1640, T21	OGV263	0.0022	Passed	0.1000	Passed	Remediation has been completed
South Colchester Academy	Sink 4(L) Classroom 1640, T22	OGV264	0.0021	Passed	0.0540	Passed	Remediation has been completed
South Colchester Academy	Tap, Classroom 1630M T23	OGV265	0.0021	Passed	0.0930	Passed	Remediation has been completed
South Colchester Academy	Tap, Classroom 1650, T25	OGV266	0.0000	Passed	0.0680	Passed	Remediation has been completed
South Colchester Academy	Tap, Office Library 1261, T26	PEJ295	0.0072	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	Bottle Filler Replaced Bottle Filler Outside 1550, F3	PEJ296	0.0036	Passed	0.0480	Passed	Remediation has been completed
South Colchester Academy	Bottle Filler Replaced Bottle Filler Beside 1321, F4	PEJ297	0.0000	Passed	0.0360	Passed	Remediation has been completed
South Colchester Academy	Tap, Classroom 1460, T37	OGV268	0.0013	Passed	0.0900	Passed	Remediation has been completed
South Colchester Academy	Tap, Kitchen by Stove, T39	PYA482	0.0037	Passed	0.0920	Passed	Remediation has been completed
South Colchester Academy	Tap, Kitchen by Freezer, T40	MUG108	0.0026	Passed	0.9900	Passed	Remediation has been completed
South Colchester Academy	Tap, Tray Washing Right, T42	PYA483	0.0009	Passed	0.0730	Passed	Remediation has been completed
South Colchester Academy	Tap, Tray Washing Left, T43	PYA484	0.0047	Passed	0.0610	Passed	Remediation has been completed
South Colchester Academy	Tap, Room 2650 Graphic Lab, T54	OGV272	0.0006	Passed	0.0620	Passed	Remediation has been completed
South Colchester Academy	Bottle Filler Replaced Bottle Filler Beside 2550, F6	PEJ302	0.0000	Passed	0.0460	Passed	Remediation has been completed
South Colchester Academy	Tap Staff Room 2330, T56	MUG114	0.0036	Passed	0.9500	Passed	Remediation has been completed
South Colchester Academy	Bottle Filler Replaced Bottle Filler Beside 2321 Cust. Room, F7	PEL387	0.0000	Passed	0.0480	Passed	Remediation has been completed
South Colchester Academy	Tap 2460 Classroom, T65	OGV273	0.0020	Passed	0.0870	Passed	Remediation has been completed
South Colchester Academy	Tap (R) 2110 Visual Arts, T66	OGV274	0.0013	Passed	0.0740	Passed	Remediation has been completed
South Colchester Academy	Tap (L) 2110 Visual Arts, T67	OGV275	0.0016	Passed	0.0500	Passed	Remediation has been completed
South Colchester Academy	Boiler, T1	NWL072	0.0023	Passed	0.0370	Passed	Remediation has been completed
South Colchester Academy	Boys Change, T2	NWL073	0.0014	Passed	0.0400	Passed	Remediation has been completed
South Colchester Academy	Girls Change, T3	NWL074	0.0010	Passed	0.0410	Passed	Remediation has been completed
South Colchester Academy	Gym Office 1180C, T4	NWL075	0.0021	Passed	0.0960	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
South Colchester Academy	Gym Office 1180A, T5	NWL076	0.0012	Passed	0.0520	Passed	Remediation has been completed
South Colchester Academy	Girls Change Right, T6	NWL077	0.0041	Passed	0.0440	Passed	Remediation has been completed
South Colchester Academy	Boys Change Right, T7	NWL078	0.0053	Passed	0.0510	Passed	Remediation has been completed
South Colchester Academy	Female Washroom A, T8	NWL079	0.0026	Passed	0.0530	Passed	Remediation has been completed
South Colchester Academy	Female Washroom B, T9	NWL080	0.0013	Passed	0.0370	Passed	Remediation has been completed
South Colchester Academy	Female Washroom C, T10	NWL081	0.0007	Passed	0.0410	Passed	Remediation has been completed
South Colchester Academy	Female Washroom D, T11	NWL082	0.0009	Passed	0.0390	Passed	Remediation has been completed
South Colchester Academy	Female Washroom E, T12	NWL083	0.0009	Passed	0.0370	Passed	Remediation has been completed
South Colchester Academy	Female Washroom F, T13	NWL084	0.0012	Passed	0.0360	Passed	Remediation has been completed
South Colchester Academy	Boys Washroom Left, T15	NWL085	0.0009	Passed	0.0470	Passed	Remediation has been completed
South Colchester Academy	Boys Washroom Middle, T16	NWL086	0.0019	Passed	0.0530	Passed	Remediation has been completed
South Colchester Academy	Boys Washroom Right, T17	NWL087	0.0010	Passed	0.0470	Passed	Remediation has been completed
South Colchester Academy	Washroom 1651, T18	NWL088	0.0008	Passed	0.0690	Passed	Remediation has been completed
South Colchester Academy	1620 Tech, T24	NWL090	0.0000	Passed	0.0570	Passed	Remediation has been completed
South Colchester Academy	1650 Science, T27	NWL093	1.1000	Exceeds Limit	1.9000	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	1360 Recycling, T28	NWL094	0.0012	Passed	0.0660	Passed	Remediation has been completed
South Colchester Academy	1352 Washroom, T29	NWL095	0.0008	Passed	0.0560	Passed	Remediation has been completed
South Colchester Academy	1351 Washroom, T30	NWL096	0.0026	Passed	0.0800	Passed	Remediation has been completed
South Colchester Academy	Boys Washroom Left, T31	NWL097	0.0035	Passed	0.0740	Passed	Remediation has been completed
South Colchester Academy	Boys Washroom Right, T32	NWL098	0.0015	Passed	0.0830	Passed	Remediation has been completed
South Colchester Academy	Custodial 1321 Floor Sink, T33	NWL099	0.0019	Passed	0.0740	Passed	Remediation has been completed
South Colchester Academy	Girls Washroom Left, T34	NWL100	0.0020	Passed	0.0530	Passed	Remediation has been completed
South Colchester Academy	Girls Washroom Middle, T35	NWL101	0.0010	Passed	0.0480	Passed	Remediation has been completed
South Colchester Academy	Girls Washroom Right, T36	NWL102	0.0009	Passed	0.0510	Passed	Remediation has been completed
South Colchester Academy	1176A Music Storage, T38	NWL103	0.0038	Passed	0.1400	Passed	Remediation has been completed
South Colchester Academy	Hand Wash Sink, T41	NWL105	0.0022	Passed	0.0270	Passed	Remediation has been completed
South Colchester Academy	1125 Washroom Student Services, T45	NWL106	0.0007	Passed	0.0370	Passed	Remediation has been completed
South Colchester Academy	Office Area Washroom 1116A, T46	NWL107	0.0007	Passed	0.0440	Passed	Remediation has been completed
South Colchester Academy	2240 Washroom, T47	NWL108	0.0018	Passed	0.0590	Passed	Remediation has been completed
South Colchester Academy	2393 Washroom Boys Left, T48	NWL109	0.0012	Passed	0.0920	Passed	Remediation has been completed
South Colchester Academy	2393 Washroom Boys Right, T49	NWL110	0.0017	Passed	0.0610	Passed	Remediation has been completed
South Colchester Academy	2393 Washroom Custodial Floor, T50	NWL111	0.0012	Passed	0.0640	Passed	Remediation has been completed
South Colchester Academy	2393 Girls Washroom Right, T51	NWL112	0.0013	Passed	0.0440	Passed	Remediation has been completed
South Colchester Academy	2393 Girls Washroom Middle, T52	NWL113	0.0014	Passed	0.0830	Passed	Remediation has been completed
South Colchester Academy	2393 Girls Washroom Left, T53	NWL114	0.0017	Passed	0.0660	Passed	Remediation has been completed
South Colchester Academy	Bottle Filler Replaced Bottle Filler Beside Washroom, F5	PEJ301	0.0000	Passed	0.0600	Passed	Remediation has been completed
South Colchester Academy	U/F - 2343 Recycling, T55	NWL116	0.0021	Passed	0.2000	Passed	Remediation has been completed
South Colchester Academy	U/F - 2332A Washroom, T57	NWL117	0.0010	Passed	0.0430	Passed	Remediation has been completed
South Colchester Academy	U/F - 2332B, Washroom, T58	NWL118	0.0008	Passed	0.0480	Passed	Remediation has been completed
South Colchester Academy	U/F - 2323 Washroom Left, T59F	NWL119	0.0014	Passed	0.0450	Passed	Remediation has been completed
South Colchester Academy	U/F - 2323 Washroom Middle, T60F	NWL120	0.0006	Passed	0.0740	Passed	Remediation has been completed
South Colchester Academy	U/F - 2323 Washroom Right, T61	NWL121	0.0014	Passed	0.0730	Passed	Remediation has been completed
South Colchester Academy	U/F - Custodial Floor Sink, T62	NWL122	0.0026	Passed	0.0710	Passed	Remediation has been completed
South Colchester Academy	U/F - 2322 Washroom 1, T63	NWL123	0.0010	Passed	0.0750	Passed	Remediation has been completed
South Colchester Academy	U/F - 2322 Washroom 2, T64	NWL124	0.0008	Passed	0.0610	Passed	Remediation has been completed
South Colchester Academy	U/F - 2120 Science Lab 1, T68R	NWL125	0.0170	Exceeds Limit	0.0800	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2120 Science Lab 2, T69	NWL126	0.0250	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2120 Science Lab 3, T70	NWL127	0.0220	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2120 Science Lab 4, T71	NWL128	0.0180	Exceeds Limit	0.3900	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2120 Science Lab Island, T72	NWL129	0.0150	Exceeds Limit	0.0990	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - Prep Room 2131, T73	NWL130	0.0055	Exceeds Limit	0.0810	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - Room 2130 A, T74R	NWL131	0.0035	Passed	0.0720	Passed	Remediation has been completed
South Colchester Academy	U/F - Room 2130 B, T75	NWL132	0.0051	Passed	0.0850	Passed	Remediation has been completed
South Colchester Academy	U/F - Room 2130 C, T76	NWL133	0.0600	Exceeds Limit	0.0550	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - Room 2130 D, T77	NWL134	0.0510	Exceeds Limit	0.0410	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 1, T79	NWL135	0.0042	Passed	0.1000	Passed	Remediation has been completed
South Colchester Academy	U/F - 2150 Chemistry 2, T80	NWL136	0.0120	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 3, T81	NWL137	0.0075	Exceeds Limit	0.0650	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 4, T82	NWL138	0.0055	Exceeds Limit	0.0560	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 5, T83	NWL139	0.0073	Exceeds Limit	0.0700	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 6, T84	NWL140	0.0120	Exceeds Limit	0.0850	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 8, T86	NWL141	0.0110	Exceeds Limit	0.0720	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	U/F - 2150 Chemistry 9, T87	NWL142	0.0150	Exceeds Limit	0.0660	Passed	Signage to be added to instruct handwashing only
South Colchester Academy	Custodial 1391 T14	PEJ294	0.0005	Passed	0.0530	Passed	Remediation has been completed
Spring Street Academy	Library	MRN205	0.0000	Passed	0.5300	Passed	Remediation has been completed
Spring Street Academy	Music Room	MRN206	0.0000	Passed	0.4500	Passed	Remediation has been completed
Spring Street Academy	Recycling Room	MRN207	0.0000	Passed	0.5400	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Spring Street Academy	Cafeteria #1	MRN208	0.0000	Passed	0.4800	Passed	Remediation has been completed
Spring Street Academy	Cafeteria #2	MRN209	0.0000	Passed	0.5300	Passed	Remediation has been completed
Spring Street Academy	Cafeteria #3	MRN210	0.0040	Passed	0.2500	Passed	Remediation has been completed
Spring Street Academy	Cafeteria #4	MRN211	0.0005	Passed	0.6000	Passed	Remediation has been completed
Spring Street Academy	Stage	MRN212	0.0006	Passed	0.5200	Passed	Remediation has been completed
Spring Street Academy	Bottle Filler by Gym	MRN213	0.0010	Passed	0.2800	Passed	Remediation has been completed
Spring Street Academy	Bottle Filler Replaced Bottle Filler Lower Hall	PBJ463	0.0040	Passed	0.3500	Passed	Remediation has been completed
Spring Street Academy	Room 104	MRN215	0.0010	Passed	0.3100	Passed	Remediation has been completed
Spring Street Academy	Room 103	MRN216	0.0000	Passed	0.4400	Passed	Remediation has been completed
Spring Street Academy	Room 102	MRN217	0.0000	Passed	0.3800	Passed	Remediation has been completed
Spring Street Academy	Room 101	MRN218	0.0000	Passed	0.4700	Passed	Remediation has been completed
Spring Street Academy	Room 155	MRN219	0.0000	Passed	0.4700	Passed	Remediation has been completed
Spring Street Academy	Room 154	MRN220	0.0000	Passed	0.4400	Passed	Remediation has been completed
Spring Street Academy	Room 153	MRN221	0.0000	Passed	0.4500	Passed	Remediation has been completed
Spring Street Academy	Room 152	MRN222	0.0000	Passed	0.4900	Passed	Remediation has been completed
Spring Street Academy	Room 151 Sink #1	MRN223	0.0021	Passed	0.3500	Passed	Remediation has been completed
Spring Street Academy	Room 151 Sink #2	MRN224	0.0000	Passed	0.5100	Passed	Remediation has been completed
Spring Street Academy	Staff Room	MRN225	0.0000	Passed	0.3900	Passed	Remediation has been completed
Spring Street Academy	Room 211	MRN226	0.0009	Passed	0.2900	Passed	Remediation has been completed
Spring Street Academy	Room 213	MRN227	0.0009	Passed	0.3500	Passed	Remediation has been completed
Spring Street Academy	Room 214	MRN228	0.0010	Passed	0.2800	Passed	Remediation has been completed
Spring Street Academy	Room 216	MRN229	0.0012	Passed	0.2200	Passed	Remediation has been completed
Spring Street Academy	Room 217	MRN230	0.0016	Passed	0.0950	Passed	Remediation has been completed
Spring Street Academy	Room 220	MRN231	0.0013	Passed	0.1800	Passed	Remediation has been completed
Spring Street Academy	Room 221	MRN232	0.0011	Passed	0.2500	Passed	Remediation has been completed
Spring Street Academy	Room 223	MRN233	0.0009	Passed	0.3400	Passed	Remediation has been completed
Spring Street Academy	Room 224	MRN234	0.0010	Passed	0.3400	Passed	Remediation has been completed
Spring Street Academy	Room 227	MRN237	0.0000	Passed	0.4600	Passed	Remediation has been completed
Spring Street Academy	Bottle Filler Replaced Bottle Filler Upper Hall	PBJ464	0.0021	Passed	0.4700	Passed	Remediation has been completed
Springhill Jr/Sr High School	Board Office Kitchen	MVZ098	0.0006	Passed	0.4900	Passed	Remediation has been completed
Springhill Jr/Sr High School	Warehouse	MVZ099	0.0036	Passed	0.4500	Passed	Remediation has been completed
Springhill Jr/Sr High School	Bottle Filler Replaced Bottle Filler by Cafeteria	OYC035	0.0000	Passed	0.0000	Passed	Remediation has been completed
Springhill Jr/Sr High School	Wood Shop	MVZ101	0.0037	Passed	0.9500	Passed	Remediation has been completed
Springhill Jr/Sr High School	Cafeteria	MVZ102	0.0098	Exceeds Limit	0.5500	Passed	Signage to be added to instruct handwashing only
Springhill Jr/Sr High School	1st Staff Room	MVZ103	0.0006	Passed	0.1800	Passed	Remediation has been completed
Springhill Jr/Sr High School	Room 196 Learning Centre	MVZ104	0.0006	Passed	0.2800	Passed	Remediation has been completed
Springhill Jr/Sr High School	Bottle Filler Replaced Bottle Filler by Main Office	OYC034	0.0011	Passed	0.0180	Passed	Remediation has been completed
Springhill Jr/Sr High School	Bottle Filler Replaced Bottle Filler 2nd Junior Wing	OYC036	0.0000	Passed	0.1600	Passed	Remediation has been completed
Springhill Jr/Sr High School	Room 253 Lab	MVZ107	0.0018	Passed	0.2200	Passed	Remediation has been completed
Springhill Jr/Sr High School	Food Lab #1	NJX611	0.0000	Passed	0.0043	Passed	Remediation has been completed
Springhill Jr/Sr High School	Food Lab #2	MVZ109	0.0005	Passed	0.0045	Passed	Remediation has been completed
Springhill Jr/Sr High School	Food Lab #3	MVZ110	0.0026	Passed	0.4200	Passed	Remediation has been completed
Springhill Jr/Sr High School	Food Lab #4	MVZ111	0.0000	Passed	0.1800	Passed	Remediation has been completed
Springhill Jr/Sr High School	Bottle Filler by Gym	MVZ112	0.0008	Passed	0.2800	Passed	Remediation has been completed
Springhill Jr/Sr High School	Room 212	PXH037	0.0000	Passed	0.0810	Passed	Remediation has been completed
Springhill Jr/Sr High School	Café #2	MVZ114	0.0000	Passed	0.1500	Passed	Remediation has been completed
Tatamagouche Regional Academy	001 - Source	MRN075	0.0000	Passed	0.6000	Passed	Remediation has been completed
Tatamagouche Regional Academy	002 - Room 118	MRN076	0.0000	Passed	0.0950	Passed	Remediation has been completed
Tatamagouche Regional Academy	004 - Room 119	MRN077	0.0000	Passed	0.1700	Passed	Remediation has been completed
Tatamagouche Regional Academy	005 - Room 121	MRN078	0.0000	Passed	0.2900	Passed	Remediation has been completed
Tatamagouche Regional Academy	006 - Room 124 Kitchen Tap	MRN079	0.0000	Passed	0.2800	Passed	Remediation has been completed
Tatamagouche Regional Academy	007 - Room 124 Upper Bottle Filler	MRN080	0.0000	Passed	0.0830	Passed	Remediation has been completed
Tatamagouche Regional Academy	008 - Room 124 Lower Bottle Filler	PBJ466	0.0000	Passed	0.0520	Passed	Remediation has been completed
Tatamagouche Regional Academy	009 - Room 129	MRN082	0.0000	Passed	0.1900	Passed	Remediation has been completed
Tatamagouche Regional Academy	011 - Room 130	MRN083	0.0000	Passed	0.1600	Passed	Remediation has been completed
Tatamagouche Regional Academy	017 - Outside Gym - Upper Bottle Filler	MRN084	0.0000	Passed	0.1500	Passed	Remediation has been completed
Tatamagouche Regional Academy	018 - Outside Gym - Lower Bottle Filler	PBJ465	0.0000	Passed	0.0840	Passed	Remediation has been completed
Tatamagouche Regional Academy	023 - 216 Lower Bottle Filler	MRN086	0.0000	Passed	0.1900	Passed	Remediation has been completed
Tatamagouche Regional Academy	024 - 216 Upper Bottle Filler	MRN087	0.0000	Passed	0.1000	Passed	Remediation has been completed
Tatamagouche Regional Academy	025 - 141 A - Sink A	MRN088	0.0024	Passed	0.0450	Passed	Remediation has been completed
Tatamagouche Regional Academy	026 - 141 A - Sprayer A	MRN089	0.0016	Passed	0.1100	Passed	Remediation has been completed
Tatamagouche Regional Academy	027 - 141 A - Sink B	MRN090	0.0000	Passed	0.1100	Passed	Remediation has been completed
Tatamagouche Regional Academy	028 - 141 A - Sink C	MRN091	0.0035	Passed	0.1900	Passed	Remediation has been completed
Tatamagouche Regional Academy	034 - 200 C	MRN092	0.0000	Passed	0.0590	Passed	Remediation has been completed
Tatamagouche Regional Academy	035 - 200 C - Upper Bottle Filler	MRN093	0.0000	Passed	0.1400	Passed	Remediation has been completed
Tatamagouche Regional Academy	036 - 200 C - Lower Bottle Filler	PBJ468	0.0000	Passed	0.0510	Passed	Remediation has been completed
Tatamagouche Regional Academy	039 - 238 - Sink A	MRN095	0.0000	Passed	0.1600	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Tatamagouche Regional Academy	040 - 238 - Sink B	MRN096	0.0000	Passed	0.2000	Passed	Remediation has been completed
Tatamagouche Regional Academy	041 - 238 - Sink C	MRN097	0.0000	Passed	0.1100	Passed	Remediation has been completed
Tatamagouche Regional Academy	042 - 238 - Sink D	MRN098	0.0000	Passed	0.1500	Passed	Remediation has been completed
Tatamagouche Regional Academy	044 - 238	MRN099	0.0000	Passed	0.1100	Passed	Remediation has been completed
Tatamagouche Regional Academy	054 - 216 Lower Bottle Filler	PBJ467	0.0000	Passed	0.0460	Passed	Remediation has been completed
Tatamagouche Regional Academy	055 - 218	MRN101	0.0000	Passed	0.2100	Passed	Remediation has been completed
Tatamagouche Regional Academy	080 - 222 Sink A	MRN102	0.0000	Passed	0.1500	Passed	Remediation has been completed
Tatamagouche Regional Academy	081 - 222 Sink B	MRN103	0.0018	Passed	0.0940	Passed	Remediation has been completed
Thorburn Consolidated School	Source-Well	MUN075	0.0024	Passed	0.0200	Passed	Remediation has been completed
Thorburn Consolidated School	Room 112 - Sink	MUN079	0.0700	Exceeds Limit	0.1400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 303 Kitchen Sink	MUN080	0.0380	Exceeds Limit	0.3000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Gym Office Sink	MUN081	0.0640	Exceeds Limit	0.3200	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Kitchen Sink	MUN083	0.0027	Passed	0.1600	Passed	Remediation has been completed
Thorburn Consolidated School	Room 111 - Sink	MUN084	0.0420	Exceeds Limit	0.2100	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 106 Sink	MUN087	0.0630	Exceeds Limit	0.0940	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 106 Tech Room Hall Sink	MUN088	0.1600	Exceeds Limit	0.4900	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 107 Sink	MUN089	0.0120	Exceeds Limit	0.1400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Staff Kitchen Sink	MUN090	0.0078	Exceeds Limit	0.0510	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 105 Sink	MUN091	0.0042	Passed	0.0870	Passed	Remediation has been completed
Thorburn Consolidated School	Room 100 Kitchenette Sink	MUN093	0.0170	Exceeds Limit	0.0560	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 203 Sink	MUN094	0.0073	Exceeds Limit	0.1700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 204 Sink	MUN095	0.0097	Exceeds Limit	0.1700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 207	MUN096	0.0130	Exceeds Limit	0.0870	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 206 Sink	MUN099	0.0130	Exceeds Limit	0.1600	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 209 Sink	MUN100	0.1200	Exceeds Limit	0.5900	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 213 Sink	MUN102	0.0150	Exceeds Limit	0.1600	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Room 217 Sink	MUN103	0.0110	Exceeds Limit	0.1400	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	004 Room 303 Washroom	NEE711	0.0000	Passed	0.0270	Passed	Remediation has been completed
Thorburn Consolidated School	005 Office Area Washroom Sink A	NEE712	0.0013	Passed	0.0320	Passed	Remediation has been completed
Thorburn Consolidated School	006 Office Area Washroom Sink B	NEE713	0.0008	Passed	0.0330	Passed	Remediation has been completed
Thorburn Consolidated School	008 Washroom Gym Office Sink A	NEE714	0.0420	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	009 Washroom Gym Office Sink B	NEE715	0.0360	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	011 Locker Room Boys A	NEE716	0.0770	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	012 Locker Room Boys B	NEE717	0.0810	Exceeds Limit	0.3900	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	013 Locker Room Girls A	NEE718	0.1600	Exceeds Limit	0.4500	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	014 Locker Room Girls B	NEE719	0.0770	Exceeds Limit	0.3800	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	016 Kitchen Washroom Sink	NEE720	0.0460	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	018 Room 114 Janitors Room	NEE721	0.0059	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	020 Washroom 2/3 Boys Sink A	NEE722	0.0160	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	021 Washroom 2/3 Boys Sink B	NEE723	0.0035	Passed	0.1400	Passed	Remediation has been completed
Thorburn Consolidated School	022 Washroom 2/3 Boys Sink C	NEE724	0.0180	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	023 Washroom 2/3 Girls Sink A	NEE725	0.0130	Exceeds Limit	0.4600	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	024 Washroom 2/3 Girls Sink B	NEE726	0.0130	Exceeds Limit	0.3200	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	025 Washroom 2/3 Girls Sink C	NEE727	0.0160	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	027 Laundry Sink Room	NEE728	0.0031	Passed	0.0760	Passed	Remediation has been completed
Thorburn Consolidated School	030 Room 106 Washroom Sink	NEE729	0.0160	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	032 Washroom Primary Boys Sink	NEE730	0.0015	Passed	0.0750	Passed	Remediation has been completed
Thorburn Consolidated School	033 Washroom Primary Girls A	NEE731	0.0290	Exceeds Limit	0.2000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	034 Washroom Primary Girls B	NEE732	0.0018	Passed	0.1200	Passed	Remediation has been completed
Thorburn Consolidated School	036 Staff Washroom Sink	NEE733	0.0049	Passed	0.1100	Passed	Remediation has been completed
Thorburn Consolidated School	045 Washroom 3/4 Boys A	NEE734	0.0210	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	046 Washroom 3/4 Boys B	NEE735	0.0210	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	047 Washroom 3/4 Boys C	NEE736	0.0460	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	048 Washroom 3/4 Girls Sink A	NEE737	0.0310	Exceeds Limit	0.4100	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	049 Washroom 3/4 Girls Sink B	NEE738	0.0250	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	050 Washroom 3/4 Girls Sink C	NEE739	0.0290	Exceeds Limit	0.4700	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	054 Janitors Room Sink	NEE740	0.0100	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	055 Washroom Junior High Boys A	NEE741	0.0068	Exceeds Limit	0.0730	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	056 Washroom Junior High Boys B	NEE742	0.0140	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	058 Washroom Junior High Girls A	NEE744	0.0350	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	059 Washroom Junior High Girls B	NEE745	0.0190	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	060 Washroom Junior High Girls C	NEE746	0.0240	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	061 Library Washroom	NEE747	0.0140	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	063 Janitors Room Sink	NEE748	0.0530	Exceeds Limit	0.2900	Passed	Signage to be added to instruct handwashing only
Thorburn Consolidated School	Bottle Filler E Upstairs by Boys Washroom	PYA744	0.0023	Passed	0.4100	Passed	Remediation has been completed
Thorburn Consolidated School	Bottle Filler A Gym	PYA740	0.0180	Exceeds Limit	0.2300	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Thorburn Consolidated School	Bottle Filler B Downstairs by Office	PYA741	0.0030	Passed	0.2300	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Thorburn Consolidated School	Bottle Filler C Downstairs by Primary End	PYA742	0.0045	Passed	0.2400	Passed	Remediation has been completed
Thorburn Consolidated School	Bottle Filler D Upstairs by Girls Washroom End	PYA743	0.0320	Exceeds Limit	0.3000	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Trenton Elementary School	001 Room 240 Classroom	LES833	0.0011	Passed	0.7000	Passed	Remediation has been completed
Trenton Elementary School	002 Floor Hallway (Bottle Filler)	LES834	0.0015	Passed	0.4500	Passed	Remediation has been completed
Trenton Elementary School	003 Room 247 (Staff Room)	LES835	0.0009	Passed	0.5600	Passed	Remediation has been completed
Trenton Elementary School	004 1st Hallway (Bottle Filler Mid Hallway)	LES836	0.0013	Passed	0.3000	Passed	Remediation has been completed
Trenton Elementary School	005 1st Floor Hallway (Bottle Filler by Gym)	LES837	0.0000	Passed	0.5500	Passed	Remediation has been completed
Trenton Elementary School	006 Kitchen (Kitchen Off of Gym, Sink)	LES838	0.0009	Passed	0.7500	Passed	Remediation has been completed
Trenton Elementary School	007 Utility Room (Source Sample)	LES839	0.0023	Passed	0.3800	Passed	Remediation has been completed
Trenton Elementary School	008 Room 147 Main Room Sink	NGT237	0.0017	Passed	0.0960	Passed	Remediation has been completed
Trenton Elementary School	009 Room 149 Girls Washroom Sink A	NGT238	0.0098	Exceeds Limit	0.4300	Passed	Signage to be added to instruct handwashing only
Trenton Elementary School	010 Room 149 Girls Washroom Sink B	NGT239	0.0190	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Trenton Elementary School	011 Room 149 Girls Washroom Sink C	NGT240	0.0020	Passed	0.1800	Passed	Remediation has been completed
Trenton Elementary School	012 Room 149 Girls Washroom Sink D	NGT241	0.0040	Passed	0.2300	Passed	Remediation has been completed
Trenton Elementary School	013 Room 146 Boys Washroom Sink A	NGT242	0.0064	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Trenton Elementary School	014 Room 146 Boys Washroom Sink B	NGT243	0.0045	Passed	0.2500	Passed	Remediation has been completed
Trenton Elementary School	015 Room 146 Boys Washroom Sink C	NGT244	0.0024	Passed	0.2000	Passed	Remediation has been completed
Trenton Elementary School	016 Room 146 Boys Washroom Sink D	NGT245	0.0036	Passed	0.2400	Passed	Remediation has been completed
Trenton Middle School	017 Room 114 Art Room	OPX656	0.0025	Passed	0.2300	Passed	Remediation has been completed
Trenton Middle School	021 Room 116 Classroom	OPX657	0.0066	Exceeds Limit	0.3000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Trenton Middle School	022 Room 117 Classroom	OPX658	0.0100	Exceeds Limit	0.5700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Trenton Middle School	024 Room 122 Sink A Kitchen	MVY971	0.0041	Passed	0.1300	Passed	Remediation has been completed
Trenton Middle School	025 Room 122 Sink B Kitchen	MVY972	0.0030	Passed	0.0830	Passed	Remediation has been completed
Trenton Middle School	026 Room 122 Sink C Kitchen	MVY973	0.0019	Passed	0.1900	Passed	Remediation has been completed
Trenton Middle School	030 Room 211 Janitors Closet Sink	MVY974	0.0014	Passed	0.8300	Passed	Remediation has been completed
Trenton Middle School	031 Room 212 Sink A Meeting Rm Washroom	OPX659	0.0220	Exceeds Limit	0.3100	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	032 Room 212 Sink B Meeting Rm Washroom	OPX660	0.0033	Passed	0.6700	Passed	Remediation has been completed
Trenton Middle School	033 Room 213 Sink A Home Ec	MVY977	0.0045	Passed	0.3500	Passed	Remediation has been completed
Trenton Middle School	034 Room 213 Sink B Home Ec	OPX661	0.0057	Exceeds Limit	0.3700	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Trenton Middle School	035 Room 213 Sink C Home Ec	OPX662	0.0025	Passed	0.3500	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Trenton Middle School	036 Room 213 Sink D Home Ec	MVY980	0.0024	Passed	0.0670	Passed	Remediation has been completed
Trenton Middle School	037 Room 214 Classroom	MVY981	0.0021	Passed	0.6700	Passed	Remediation has been completed
Trenton Middle School	040 Room 217 Staff Room Kitchen Sink	MVY982	0.0029	Passed	0.5200	Passed	Remediation has been completed
Trenton Middle School	043 Room 222 Office	MVY983	0.0009	Passed	0.6000	Passed	Remediation has been completed
Trenton Middle School	045 Room E103 Gym Office	OPX663	0.0013	Passed	0.3600	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Trenton Middle School	055 Room E200	MVY985	0.0018	Passed	0.3100	Passed	Remediation has been completed
Trenton Middle School	059 Room E110 Sink A Locker Room	MVY986	0.0038	Passed	0.2800	Passed	Remediation has been completed
Trenton Middle School	060 Room E110 Sink B Locker Room	OPX665	0.0061	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	061 Room E115 Book Room Utility Sink	MVY988	0.0270	Exceeds Limit	0.0460	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	062 Room E116 Boiler Utility Sink	OPX664	0.0600	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	063 Room 207 FoSS Office Area Sink	MVY990	0.0010	Passed	0.5000	Passed	Remediation has been completed
Trenton Middle School	072 Room 307 Classroom Sink	MVY991	0.0039	Passed	0.4100	Passed	Remediation has been completed
Trenton Middle School	110 Janitors Room	NIM932	0.0000	Passed	0.4800	Passed	Remediation has been completed
Trenton Middle School	112 Girls Washroom Sink A	NIM932	0.0000	Passed	0.2400	Passed	Remediation has been completed
Trenton Middle School	112 Girls Washroom Sink B	NIM933	0.0000	Passed	0.2300	Passed	Remediation has been completed
Trenton Middle School	112 Girls Washroom Sink C	NIM934	0.0013	Passed	0.2500	Passed	Remediation has been completed
Trenton Middle School	113 Lab Sink A	NIM935	1.7000	Exceeds Limit	0.5200	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink B	NIM936	0.0440	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink C	NIM937	0.0680	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink D	NIM938	0.0410	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink E	NIM939	0.1400	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink F	NIM940	0.0110	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink G	NIM941	0.0240	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink H	NIM942	0.2900	Exceeds Limit	3.3000	Exceeds Limit	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink I	NIM943	0.5700	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink J	NIM944	4.6000	Exceeds Limit	1.3000	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	113 Lab Sink K	NIM945	3.8000	Exceeds Limit	4.6000	Exceeds Limit	Signage to be added to instruct handwashing only
Trenton Middle School	115 Boys Washroom Sink A	NIM946	0.0018	Passed	0.1900	Passed	Remediation has been completed
Trenton Middle School	115 Boys Washroom Sink B	NIM947	0.0014	Passed	0.2100	Passed	Remediation has been completed
Trenton Middle School	115 Boys Washroom Sink C	NIM948	0.0055	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	Janitors Room	NIM949	0.0031	Passed	0.3000	Passed	Remediation has been completed
Trenton Middle School	215A Washroom	NIM950	0.0010	Passed	0.2000	Passed	Remediation has been completed
Trenton Middle School	215 Washroom	NIM951	0.0019	Passed	0.2700	Passed	Remediation has been completed
Trenton Middle School	217 Washroom Sink A	NIM952	0.0012	Passed	0.3700	Passed	Remediation has been completed
Trenton Middle School	217 Washroom Sink B	NIM953	0.0008	Passed	0.3300	Passed	Remediation has been completed
Trenton Middle School	310 Janitors Room	NIM954	0.0037	Passed	0.2900	Passed	Remediation has been completed
Trenton Middle School	Gym Boys Washroom Sink	NIM955	0.0009	Passed	0.0880	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Trenton Middle School	Girls Washroom Sink	NIM956	0.0110	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	Janitors Closet	NIM957	0.0015	Passed	0.2000	Passed	Remediation has been completed
Trenton Middle School	Girls Locker Room Sink A	NIM958	0.0890	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	Girls Locker Room Sink B	NIM959	0.0130	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	E105 Washroom Sink A	NIM960	0.0450	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	E105 Washroom Sink B	NIM961	0.0041	Passed	0.0580	Passed	Remediation has been completed
Trenton Middle School	E105 Janitors Closet	NIM962	0.0006	Passed	0.3000	Passed	Remediation has been completed
Trenton Middle School	209 Boys Washroom Sink A	NIM963	0.0014	Passed	0.1700	Passed	Remediation has been completed
Trenton Middle School	209 Boys Washroom Sink B	NIM964	0.0010	Passed	0.1700	Passed	Remediation has been completed
Trenton Middle School	210 Girls Washroom Sink A	NIM965	0.0034	Passed	0.0830	Passed	Remediation has been completed
Trenton Middle School	210 Girls Washroom Sink B	NIM966	0.0032	Passed	0.1100	Passed	Remediation has been completed
Trenton Middle School	211 Janitors Closet	NIM967	0.0038	Passed	0.2100	Passed	Remediation has been completed
Trenton Middle School	212 Meeting Room Washroom	NIM968	0.0029	Passed	0.2400	Passed	Remediation has been completed
Trenton Middle School	309 Boys Washroom A	NIM969	0.0057	Exceeds Limit	0.2500	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	309 Boys Washroom B	NIM970	0.0069	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	310 Girls Washroom A	NIM971	0.0039	Passed	0.0810	Passed	Remediation has been completed
Trenton Middle School	310 Girls Washroom B	NIM972	0.0023	Passed	0.1600	Passed	Remediation has been completed
Trenton Middle School	310 Girls Washroom C	NIM973	0.0058	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Trenton Middle School	3rd Floor Janitor Closet	NIM974	0.0067	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Truro Elementary School	Bottle Filler Replaced Bottle Filler Outside Gym, F1	PCS327	0.0000	Passed	0.1300	Passed	Remediation has been completed
Truro Elementary School	Room 1052 Kitchen Tap, T7	MPQ441	0.0000	Passed	0.3700	Passed	Remediation has been completed
Truro Elementary School	Kitchen Main Tap by Door, T8	NSR933	0.0034	Passed	0.0230	Passed	Remediation has been completed
Truro Elementary School	Kitchen Tap in Island, T11	MPQ443	0.0018	Passed	0.2100	Passed	Remediation has been completed
Truro Elementary School	Bottle Filler Replaced High Bottle Filler by Main Floor W/R F2	PCS328	0.0024	Passed	0.9200	Passed	Remediation has been completed
Truro Elementary School	Low Bottle Filler by Main Floor W/R F3	MPQ445	0.0000	Passed	0.1900	Passed	Remediation has been completed
Truro Elementary School	Room 1030, Kitchen Tap, T24	MPQ446	0.0000	Passed	0.2300	Passed	Remediation has been completed
Truro Elementary School	Room 1028, Kitchen Tap, T25	MPQ447	0.0007	Passed	0.2100	Passed	Remediation has been completed
Truro Elementary School	Room 1026, Kitchen Tap, T26	MPQ448	0.0000	Passed	0.2300	Passed	Remediation has been completed
Truro Elementary School	Room 1021, Kitchen Tap, T30	MPQ449	0.0000	Passed	0.3200	Passed	Remediation has been completed
Truro Elementary School	Room 1018, Kitchen Tap, T33	MPQ450	0.0000	Passed	0.1800	Passed	Remediation has been completed
Truro Elementary School	Room 1023, Kitchen Tap, T29	MPQ451	0.0000	Passed	0.2400	Passed	Remediation has been completed
Truro Elementary School	Room 1017, Kitchen Tap, T34	MPQ452	0.0007	Passed	0.3500	Passed	Remediation has been completed
Truro Elementary School	Room 1014, Kitchen Tap, T36	MPQ453	0.0000	Passed	0.2600	Passed	Remediation has been completed
Truro Elementary School	Room 1013, Kitchen Tap, T35	MPQ454	0.0000	Passed	0.1900	Passed	Remediation has been completed
Truro Elementary School	Room 1010, Kitchen Tap, T37	MPQ455	0.0007	Passed	0.2400	Passed	Remediation has been completed
Truro Elementary School	Room 1009, Kitchen Tap, T38	MPQ456	0.0005	Passed	0.2200	Passed	Remediation has been completed
Truro Elementary School	Room 1006, Kitchen Tap, T40	MPQ457	0.0000	Passed	0.3100	Passed	Remediation has been completed
Truro Elementary School	Room 1005, Kitchen Tap, T39	MPQ458	0.0000	Passed	0.2800	Passed	Remediation has been completed
Truro Elementary School	Room 1002, Kitchen Tap, T41	MPQ459	0.0000	Passed	0.3600	Passed	Remediation has been completed
Truro Elementary School	Staff Room 2039, Kitchen Tap, T57	MPQ460	0.0000	Passed	0.1400	Passed	Remediation has been completed
Truro Elementary School	Bottle Filler Upstairs by Washroom, F4	PCS345	0.0011	Passed	0.4700	Passed	Remediation has been completed
Truro Elementary School	Room 2031, Kitchen Tap, T54	MPQ462	0.0010	Passed	0.4000	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler across from Tech. Ed., F1	PCS404	0.0000	Passed	0.0007	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler near Girls Washroom Main Floor, F2	OYL859	0.0000	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Room 37 Kitchen Sink, T17	MPQ756	0.0050	Passed	0.2600	Passed	Remediation has been completed
Truro Junior High School	Room 006, Kitchen Sink, T18	MPQ757	0.0006	Passed	0.1100	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler near Staff Room Entrance, F3	PCS405	0.0007	Passed	0.2600	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler near Gym, F4	OYL8560	0.0000	Passed	0.1400	Passed	Remediation has been completed
Truro Junior High School	Staff Rm Kitchen Tap, T19	MPQ760	0.0000	Passed	0.1300	Passed	Remediation has been completed
Truro Junior High School	Recycle Rm Kitchen Tap, T25	MPQ761	0.0022	Passed	0.2400	Passed	Remediation has been completed
Truro Junior High School	Single Tap in Kitchen, T28	OYL861	0.0026	Passed	0.1800	Passed	Remediation has been completed
Truro Junior High School	Double Sink Tap on Right, T30	PCS406	0.0039	Passed	0.2100	Passed	Remediation has been completed
Truro Junior High School	Double Sink Tap on Left, T29	MPQ764	0.0038	Passed	0.1800	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler upstairs by Room 227, F5	OYL863	0.0000	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Bottle Filler Replaced Bottle Filler upstairs by Room 209, F6	PCS407	0.0000	Passed	0.0670	Passed	Remediation has been completed
Truro Junior High School	Family Studies RM 222 Sink on Left, T58	MPQ767	0.0049	Passed	0.2100	Passed	Remediation has been completed
Truro Junior High School	Family Studies RM 222 Sink on Right, T59	MPQ768	0.0036	Passed	0.2200	Passed	Remediation has been completed
Truro Junior High School	Family Studies RM 222 Sink on Left, T60	NQT432	0.0029	Passed	0.2000	Passed	Remediation has been completed
Truro Junior High School	Family Studies RM 222 Sink on Right, T61	MPQ770	0.0018	Passed	0.2100	Passed	Remediation has been completed
Truro Junior High School	RM 203, Kitchen Sink on Left, T52	MPQ771	0.0012	Passed	0.1000	Passed	Remediation has been completed
Truro Junior High School	RM 203, Kitchen Sink on Right, T53	MPQ772	0.0018	Passed	0.1600	Passed	Remediation has been completed
Truro Junior High School	Staff Washroom 032, Hall across from Tech Ed 031, T1	NQT335	0.0000	Passed	0.1300	Passed	Remediation has been completed
Truro Junior High School	Science 012 Island Lab Sink, T2	NQT336	0.0023	Passed	0.8300	Passed	Remediation has been completed
Truro Junior High School	Sprinkler Room 013, Between Labs 012/015, T2A	NQT337	0.0083	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Truro Junior High School	Science 015 Count Lab Sinks at Back by Window Left Tap, T3	NQT338	0.0019	Passed	0.0750	Passed	Remediation has been completed
Truro Junior High School	Science 015 Count Lab Sinks at Back by Window 2nd Left Tap, T4	NQT339	0.0026	Passed	0.4400	Passed	Remediation has been completed
Truro Junior High School	Science 015 Count Lab Sinks at Back by Window 3rd Left Tap, T5	NQT340	0.0025	Passed	0.4900	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Truro Junior High School	Science 015 Count Lab Sinks at Back by Window 4th Left Tap, T6	NQT341	0.0016	Passed	0.3500	Passed	Remediation has been completed
Truro Junior High School	Science 015 Island Lab Sink, T7	NQT342	0.0071	Exceeds Limit	0.4700	Passed	Signage to be added to instruct handwashing only
Truro Junior High School	Tech Ed 0303, T8	NQT343	0.0018	Passed	0.1500	Passed	Remediation has been completed
Truro Junior High School	Boiler Room 025, T9	NQT344	0.0037	Passed	0.2000	Passed	Remediation has been completed
Truro Junior High School	Custodial 033 Custodial Floor Sink, T10	NQT345	0.0055	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Truro Junior High School	Girl's Washroom 035 Left Tap, T11	NQT346	0.0008	Passed	0.0720	Passed	Remediation has been completed
Truro Junior High School	Girl's Washroom 035 Middle Tap, T12	NQT347	0.0000	Passed	0.0800	Passed	Remediation has been completed
Truro Junior High School	Girl's Washroom 035 Right Tap, T13	NQT348	0.0010	Passed	0.0890	Passed	Remediation has been completed
Truro Junior High School	Boy's Washroom 036 Left Tap, T14	NQT349	0.0010	Passed	0.1400	Passed	Remediation has been completed
Truro Junior High School	Boy's Washroom 036 Middle Tap, T15	NQT350	0.0007	Passed	0.1300	Passed	Remediation has been completed
Truro Junior High School	Boy's Washroom 036 Right Tap, T16	NQT351	0.0008	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Learning Support Washroom 005, T19A	NQT352	0.0000	Passed	0.2100	Passed	Remediation has been completed
Truro Junior High School	Library 081 Storage Room behind Library Desk, T19B	NQT353	0.0350	Exceeds Limit	0.7700	Passed	Signage to be added to instruct handwashing only
Truro Junior High School	Sick Room 045 Washroom in Main Office, T20	NQT396	0.0012	Passed	0.5500	Passed	Remediation has been completed
Truro Junior High School	Staff Washroom 053A, T21	NQT397	0.0045	Passed	0.4900	Passed	Remediation has been completed
Truro Junior High School	Staff Washroom 053, Room 132, T22	PLM548	0.0026	Passed	0.0012	Passed	Remediation has been completed
Truro Junior High School	Staff Washroom 054, T23	NQT399	0.0000	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Schools Plus 058 Washroom, T24	NQT400	0.0016	Passed	0.3500	Passed	Remediation has been completed
Truro Junior High School	Music Room 0606, T26	NQT401	0.0018	Passed	0.2500	Passed	Remediation has been completed
Truro Junior High School	Kitchen 065 Handwash Sink - T27	NQT402	0.0012	Passed	0.3100	Passed	Remediation has been completed
Truro Junior High School	Kitchen 065 Sprayer Sink - T31	NQT403	0.0031	Passed	0.4100	Passed	Remediation has been completed
Truro Junior High School	Girl's Washroom across from Room 076 Left Tap, T32	NQT404	0.0011	Passed	0.0670	Passed	Remediation has been completed
Truro Junior High School	Girl's Washroom across from Room 076 Right Tap, T33	NQT405	0.0000	Passed	0.0710	Passed	Remediation has been completed
Truro Junior High School	Boy's Washroom across from Room 076 Right Tap, T34	NQT406	0.0006	Passed	0.0780	Passed	Remediation has been completed
Truro Junior High School	Boy's Washroom across from Room 076 Left Tap, T35	NQT407	0.0013	Passed	0.0720	Passed	Remediation has been completed
Truro Junior High School	Custodial Room 085 Custodial Front Sink, T35A	NQT408	0.0010	Passed	0.2400	Passed	Remediation has been completed
Truro Junior High School	Boy's Change 106 Left Tap, T36	NQT409	0.0007	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Boy's Change 106 Right Tap, T37	NQT410	0.0009	Passed	0.1000	Passed	Remediation has been completed
Truro Junior High School	Gym Office 101, Washroom Sink, T38	NQT411	0.0011	Passed	0.3200	Passed	Remediation has been completed
Truro Junior High School	Girl's Change 098 Left Tap, T39	NQT412	0.0030	Passed	0.2100	Passed	Remediation has been completed
Truro Junior High School	Girl's Change 098 Right Tap, T40	NQT413	0.0014	Passed	0.2400	Passed	Remediation has been completed
Truro Junior High School	Boy's Change 088 Left Tap, T41	NQT414	0.0007	Passed	0.0940	Passed	Remediation has been completed
Truro Junior High School	Boy's Change 088 Right Tap, T42	NQT415	0.0009	Passed	0.0890	Passed	Remediation has been completed
Truro Junior High School	Gym Office 091, Washroom Sink, T43	NQT416	0.0010	Passed	0.1200	Passed	Remediation has been completed
Truro Junior High School	Girl's Change 096 Left Tap, T44	NQT417	0.0029	Passed	0.2000	Passed	Remediation has been completed
Truro Junior High School	Girl's Change 096 Right Tap, T45	NQT418	0.0016	Passed	0.1600	Passed	Remediation has been completed
Truro Junior High School	UF - Boy's Washroom 231 Left Tap, T46	NQT419	0.0007	Passed	0.0850	Passed	Remediation has been completed
Truro Junior High School	UF - Boy's Washroom 231 Middle Tap, T47	NQT420	0.0005	Passed	0.0950	Passed	Remediation has been completed
Truro Junior High School	UF - Boy's Washroom 231 Right Tap, T48	NQT421	0.0000	Passed	0.1000	Passed	Remediation has been completed
Truro Junior High School	UF - Girl's Washroom 230 Left Tap, T49	NQT422	0.0007	Passed	0.0670	Passed	Remediation has been completed
Truro Junior High School	UF - Girl's Washroom 230 Middle Tap, T50	NQT423	0.0110	Exceeds Limit	0.3400	Passed	Signage to be added to instruct handwashing only
Truro Junior High School	UF - Girl's Washroom 230 Right Tap, T51	NQT424	0.0005	Passed	0.0710	Passed	Remediation has been completed
Truro Junior High School	UF - Assessible Washroom 224, T54	NQT425	0.0009	Passed	0.1400	Passed	Remediation has been completed
Truro Junior High School	UF - Staff Washroom 223, T55	PLM546	0.0019	Passed	0.0042	Passed	Remediation has been completed
Truro Junior High School	Science 209 Island Lab Sink, T56	NQT427	0.0012	Passed	0.3100	Passed	Remediation has been completed
Truro Junior High School	Electrical 221A Custodial Floor Sink, T57	NQT428	0.0005	Passed	0.1300	Passed	Remediation has been completed
Truro Junior High School	Room 37 Kitchen Sink, T17	NQT429	0.0041	Passed	0.3300	Passed	Remediation has been completed
Uniacke District School	Kitchen Sink in Main Office, T27	LDD281	0.0027	Passed	0.2000	Passed	Remediation has been completed
Uniacke District School	Bottle Filler Near Room 252, F5	LDD282	0.0087	Exceeds Limit	0.0860	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Uniacke District School	Bottle Filler Near Room 132, Basement, F4	LDD283	0.0016	Passed	0.1000	Passed	Remediation has been completed
Uniacke District School	Bottle Filler Near Room 202, F3	MYW219	0.0000	Passed	0.0000	Passed	Remediation has been completed
Uniacke District School	Raw Water Entering Building	LDD373	0.0003	Passed	0.0027	Passed	Remediation has been completed
Uniacke District School	Tap in Classroom 208, T13	LDD286	0.0029	Passed	0.3300	Passed	Remediation has been completed
Uniacke District School	Bottle Filler by Library, F1	MYW220	0.0000	Passed	0.0000	Passed	Remediation has been completed
Uniacke District School	Learning Centre Tap, T6	NRQ789	0.0022	Passed	0.0480	Passed	Remediation has been completed
Uniacke District School	Kitchen Sink on Left, T9	NRQ835	0.0047	Passed	0.0620	Passed	Remediation has been completed
Uniacke District School	Kitchen Sink on Right, T10	NRQ836	0.0041	Passed	0.0930	Passed	Remediation has been completed
Uniacke District School	Kitchen Sprayer, T11 (REMOVED)	NRQ834	0.1100	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Kitchen Hand Washing Sink, T12	MYW225	0.0027	Passed	0.0600	Passed	Remediation has been completed
Uniacke District School	Bottle Filler by Boiler Room Door, F8 (REMOVED)	LDD301	0.0095	Exceeds Limit	0.1300	Passed	Remediation has been completed
Uniacke District School	Sink in Staff Room 115, T68	QKQ173	0.0013	Passed	0.0170	Passed	Remediation has been completed
Uniacke District School	Bottle Filler by Music Room, F10	MYW226	0.0006	Passed	0.1100	Passed	Remediation has been completed
Uniacke District School	Bottle Filler Near Room 243, F6	MYW227	0.0000	Passed	0.0054	Passed	Remediation has been completed
Uniacke District School	Bottle Filler Near Room 326, F9	LDD305	0.0027	Passed	0.1400	Passed	Remediation has been completed
Uniacke District School	Double Sink by Ent. In Home Ec, T53	MYW228	0.0047	Passed	0.0980	Passed	Remediation has been completed
Uniacke District School	Single Sink on Island in Home Ec, T54 (Removed)	LDD307	0.0120	Exceeds Limit	0.1700	Passed	Remediation has been completed
Uniacke District School	Double Sink by White Board Home Ec, T52	QEV000	0.0026	Passed	0.0010	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
							To be updated as work progresses. All schools have clean drinkable bottled water available.
Uniacke District School	Sink by Fridge in Home Ec, T55	QKQ174	0.0017	Passed	0.0032	Passed	Remediation has been completed
Uniacke District School	Sink by Dishwasher in Home Ec, T50	NRQ832	0.0025	Passed	0.0230	Passed	Remediation has been completed
Uniacke District School	Laundry Sink in Home Ec, T51	NRQ833	0.0200	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Bottle Filler by Room 319, F7	LDD371	0.0012	Passed	0.1000	Passed	Remediation has been completed
Uniacke District School	Sink in Room 132, T22	QEU997	0.0000	Passed	0.0003	Passed	Remediation has been completed
Uniacke District School	Raw Water by Main Valve	LDD373	0.0027	Passed	0.0130	Passed	Remediation has been completed
Uniacke District School	Boys Washroom by Room 133 Left Tap, T23	NRQ775	0.0016	Passed	0.1200	Passed	Remediation has been completed
Uniacke District School	Boys Washroom by Room 133 Left Tap, T24	NRQ776	0.0022	Passed	0.1100	Passed	Remediation has been completed
Uniacke District School	Boys Washroom by Room 133 Middle Right Tap, T25	NRQ777	0.0018	Passed	0.1000	Passed	Remediation has been completed
Uniacke District School	Boys Washroom by Room 133 Right Tap, T26	NRQ778	0.0022	Passed	0.1300	Passed	Remediation has been completed
Uniacke District School	Tap in Room 132, T22	NRQ779	0.0010	Passed	0.0340	Passed	Remediation has been completed
Uniacke District School	Custodian Room Tap by Room 138, T21	NRQ780	0.0023	Passed	0.1500	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Left Tap, T20	NRQ781	0.0019	Passed	0.0890	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Left Tap #2, T19	NRQ782	0.0028	Passed	0.1800	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Middle Left Tap, T18	NRQ783	0.0016	Passed	0.0890	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Middle Right Tap, T17	NRQ784	0.0019	Passed	0.1700	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Right Tap #2, T16	NRQ785	0.0023	Passed	0.1100	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 138 Right Tap, T15	NRQ786	0.0013	Passed	0.0970	Passed	Remediation has been completed
Uniacke District School	Washroom by Library, T7	NRQ787	0.0073	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Washroom by Learning Centre, T8	NRQ788	0.0073	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Custodian Room by Room 113, T2	NRQ790	0.0160	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Room 113 Washroom Tap, T1	NRQ791	0.0026	Passed	0.1100	Passed	Remediation has been completed
Uniacke District School	Room 112 Washroom Tap, T3	NRQ792	0.0025	Passed	0.0770	Passed	Remediation has been completed
Uniacke District School	Room 109 Washroom Tap, T4	NRQ793	0.0090	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Room 108 Washroom Tap, T5	NRQ794	0.0040	Passed	0.1000	Passed	Remediation has been completed
Uniacke District School	Washroom Tap by Resource Room, T14	NRQ795	0.0068	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Washroom Tap in Main Office, T28	NRQ796	0.0070	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 251 Left Tap, T40	NRQ797	0.0042	Passed	0.1800	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 251 Middle Left Tap, T39	NRQ798	0.0048	Passed	0.1800	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Room 251 Middle Right Tap, T38	NRQ799	0.0066	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 251 Right Tap, T37	QKQ173	0.0013	Passed	0.0002	Passed	Remediation has been completed
Uniacke District School	Staff Washroom by Room 251, T36	NRQ801	0.0030	Passed	0.0990	Passed	Remediation has been completed
Uniacke District School	Custodian Room by Room 251, T35	NRQ802	0.0057	Exceeds Limit	0.0630	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Room 251 Left Tap, T32	NRQ803	0.0056	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Room 251 Left Tap, T33	NRQ804	0.0080	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Room 251 Right Tap, T34	NRQ805	0.0063	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Room 232 Off of Gym T28	NRQ806	0.0088	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Change Room Tap, T29	NRQ807	0.0130	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Change Room Tap, T30	NRQ808	0.0038	Passed	0.2000	Passed	Remediation has been completed
Uniacke District School	Room 236 Off of Gym, T31	NRQ809	0.0065	Exceeds Limit	0.2200	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Staff Washroom by Boiler Room, T61	NRQ810	0.0071	Exceeds Limit	0.0890	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Custodian Room by Boiler Room, T62	NRQ811	0.0065	Exceeds Limit	0.0910	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Boiler Room Left Tap, T57	NRQ812	0.0049	Passed	0.1700	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Boiler Room, Middle Tap, P58	NRQ813	0.0054	Passed	0.1500	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Boiler Room Middle Tap, T59	NRQ814	0.0047	Passed	0.1500	Passed	Remediation has been completed
Uniacke District School	Girls Washroom by Boiler Room Right Tap, T60	NRQ815	0.0057	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Boiler Room Left Tap, T63	NRQ816	0.0190	Exceeds Limit	0.3000	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Boiler Room Middle Tap, T64	NRQ817	0.0110	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Boiler Room Right Tap, T65	NRQ818	0.0270	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Room 122 Tap, T66	NRQ820	0.0230	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Music Room 117 Tap, T69	NRQ821	0.0350	Exceeds Limit	0.2600	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 326 Left Tap, T49	NRQ822	0.0190	Exceeds Limit	0.3500	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 326 Middle Left Tap, T48	NRQ823	0.0140	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 326 Middle Right Tap, T47	NRQ824	0.0120	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Girls Washroom by Room 326 Right Tap, T46	NRQ825	0.0094	Exceeds Limit	0.1800	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Staff Washroom by Room 326, T45	NRQ826	0.0047	Passed	0.0980	Passed	Remediation has been completed
Uniacke District School	Custodian Room Tap by Room 326, T44	NRQ827	0.0085	Exceeds Limit	0.1500	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Room 326 Left Tap, T41	NRQ828	0.0077	Exceeds Limit	0.2300	Passed	Signage to be added to instruct handwashing only
Uniacke District School	Boys Washroom by Room 326 Middle Tap, T42	NRQ829	0.0054	Passed	0.2000	Passed	Remediation has been completed
Uniacke District School	Boys Washroom by Room 326 Right Tap, T43	NRQ830	0.0060	Exceeds Limit	0.2100	Passed	Signage to be added to instruct handwashing only
Upper Stewiacke Elementary School	Kitchen Sink on Left, T8	MOP511	0.0043	Passed	0.1800	Passed	Remediation has been completed
Upper Stewiacke Elementary School	Kitchen Sink on Right, T9	MOP512	0.0043	Passed	0.1300	Passed	Remediation has been completed
Upper Stewiacke Elementary School	Staff Kitchen Sink, T6	MOP513	0.0019	Passed	0.0550	Passed	Remediation has been completed
Upper Stewiacke Elementary School	Bottle Filler Replaced Bottle Filler, F1	QES097	0.0000	Passed	0.00980	Passed	Remediation has been completed
Upper Stewiacke Elementary School	Girls Washroom Left Tap, T1	NJX628	0.0130	Exceeds Limit	0.9400	Passed	Signage to be added to instruct handwashing only
Upper Stewiacke Elementary School	Girls Washroom Right Tap, T2	NJX629	0.0050	Passed	0.5500	Passed	Remediation has been completed
Upper Stewiacke Elementary School	Boys Washroom Left Tap, T5	NJX630	0.0032	Passed	0.4400	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Upper Stewiacke Elementary School	Boys Washroom Left Tap, T4	NJX631	0.0056	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Upper Stewiacke Elementary School	Staff Washroom Tap, T3	NJX632	0.0310	Exceeds Limit	0.5800	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	Bottle Filler by Reading Recovery F1	MQT020	0.0025	Passed	0.7100	Passed	Remediation has been completed
Valley Elementary School	Bottle Filler Bottom Floor by Room 105 F2 - Removed	LEK590	0.0064	Exceeds Limit	0.5200	Passed	Remediation has been completed
Valley Elementary School	Upper F1 Bottle Filler by Main Office, F3	PUX950	0.0008	Passed	0.0100	Passed	Remediation has been completed
Valley Elementary School	Staff Room Upstairs T6	MQT019	0.0001	Passed	0.0710	Passed	Remediation has been completed
Valley Elementary School	Bottle Filler by Room 202 - Removed	LEK593	0.0088	Exceeds Limit	0.6500	Passed	Remediation has been completed
Valley Elementary School	Kitchen Sink Room #105 - Removed	LEK594	0.0190	Exceeds Limit	0.1200	Passed	Remediation has been completed
Valley Elementary School	New Bottle Filler by Gym F4	LEK595	0.0000	Passed	0.8300	Passed	Remediation has been completed
Valley Elementary School	Kitchen Sink Right Side T20	MQT021	0.0032	Passed	0.1300	Passed	Remediation has been completed
Valley Elementary School	Kitchen Sink Left Side T21	MQT022	0.0017	Passed	0.1500	Passed	Remediation has been completed
Valley Elementary School	Hand Washing Sink Kitchen T19	LEK598	0.1100	Exceeds Limit	1.7000	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	Raw Water	LL0535	0.0010	Passed	0.0130	Passed	Remediation has been completed
Valley Elementary School	L/F Classroom 104 Pre-Primary, T1	NUV859	0.0012	Passed	0.0400	Passed	Remediation has been completed
Valley Elementary School	L/F Custodial Closet by Boys Washroom, T2	NUV878	0.02100	Exceeds Limit	0.0900	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Boys Washroom, T3	NUV879	0.0002	Passed	0.0500	Passed	Remediation has been completed
Valley Elementary School	L/F Girls Washroom, T4	NUV880	0.0014	Passed	0.0520	Passed	Remediation has been completed
Valley Elementary School	L/F Principal Office Washroom, T5	NUV881	0.0220	Exceeds Limit	0.0940	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Staff Room Washroom, T7	NUV882	0.0025	Passed	0.0560	Passed	Remediation has been completed
Valley Elementary School	L/F Girls Washroom, T8 Left	NUV883	0.0630	Exceeds Limit	0.0530	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Girls Washroom, T9 Right	NUV884	0.0790	Exceeds Limit	0.0790	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Boys Washroom Right, T10	NUV885	0.0680	Exceeds Limit	0.0740	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Boys Washroom Left, T11	NUV886	0.0760	Exceeds Limit	0.0510	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Custodial, T12	NUV887	0.0210	Exceeds Limit	0.0760	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Classroom 213 Washroom, T13	NUV888	0.0100	Exceeds Limit	0.0510	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Classroom 213 Washroom, T14	NUV889	0.0630	Exceeds Limit	0.0580	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Classroom 102, Washroom T15	NUV890	0.0036	Passed	0.0370	Passed	Remediation has been completed
Valley Elementary School	L/F Classroom 101 Washroom, T16	NUV891	0.0150	Exceeds Limit	0.0470	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Foyer Handicap Washroom, T17	NUV892	0.0190	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Gym Custodial Closet, T18	NUV893	0.0240	Exceeds Limit	0.0860	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Kitchen Handwash, T19	NUV894	0.0530	Exceeds Limit	0.0840	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Girls Change Room, T22	NUV895	0.0032	Passed	0.0470	Passed	Remediation has been completed
Valley Elementary School	L/F Gym Office, T23	NUV896	0.0260	Exceeds Limit	0.0250	Passed	Signage to be added to instruct handwashing only
Valley Elementary School	L/F Boys Change Room, T24	NUV897	0.0250	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
Wallace Consolidated Elementary School	Kitchen #1	OLO852	0.0000	Passed	0.0096	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Kitchen #2	OLO853	0.0000	Passed	1.5000	Passed	Remediation has been completed
Wallace Consolidated Elementary School	1st Floor Washroom	NFC704	0.0029	Passed	0.0310	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Primary Room	NFC705	0.0000	Passed	0.0012	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Library	NFC706	0.0000	Passed	0.0008	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Girls #3	NFC709	0.0000	Passed	0.0057	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Boys #1	NFC710	0.0008	Passed	0.0050	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Boys #2	NFC711	0.0000	Passed	0.0017	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Boys #3	NFC712	0.0000	Passed	0.1100	Passed	Remediation has been completed
Wallace Consolidated Elementary School	2nd Floor Custodial	NFC713	0.0000	Passed	0.0045	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Grade 4/5 Room	NFC714	0.0016	Passed	0.0110	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Grade 5/6 Room	NFC715	0.0000	Passed	0.0000	Passed	Remediation has been completed
Wallace Consolidated Elementary School	3rd Floor Custodial	NFC716	0.0000	Passed	0.0008	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Principals Office	NFC718	0.0012	Passed	0.0056	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Staff Room	QSN877	0.0000	Passed	0.0014	Passed	Remediation has been completed
Wallace Consolidated Elementary School	Kitchen #3	OLO854	0.0000	Passed	0.0042	Passed	Remediation has been completed
Walter Duggan Consolidated School	001 Supply	NUO914	0.0000	Passed	0.0068	Passed	Remediation has been completed
Walter Duggan Consolidated School	002 Room 170	MPP901	0.0000	Passed	0.0410	Passed	Remediation has been completed
Walter Duggan Consolidated School	007 Room 157	MPP902	0.0020	Passed	0.0110	Passed	Remediation has been completed
Walter Duggan Consolidated School	008 Room 161A - Sink A	MPP903	0.0024	Passed	0.2100	Passed	Remediation has been completed
Walter Duggan Consolidated School	009 Room 161A - Sink B	MPP904	0.0017	Passed	0.3100	Passed	Remediation has been completed
Walter Duggan Consolidated School	010 Room 159 - Sink A	MPP905	0.0016	Passed	0.1500	Passed	Remediation has been completed
Walter Duggan Consolidated School	011 Room 159A - Sink B	MPP906	0.0039	Passed	0.1600	Passed	Remediation has been completed
Walter Duggan Consolidated School	012 Room 102	MPP907	0.0035	Passed	0.0740	Passed	Remediation has been completed
Walter Duggan Consolidated School	013 Room 103	MPP908	0.0011	Passed	0.1100	Passed	Remediation has been completed
Walter Duggan Consolidated School	015 Room 128	MPP909	0.0011	Passed	0.0700	Passed	Remediation has been completed
Walter Duggan Consolidated School	016 Room 121	MPP910	0.0006	Passed	0.0720	Passed	Remediation has been completed
Walter Duggan Consolidated School	019 Room 119	MPP911	0.0010	Passed	0.0760	Passed	Remediation has been completed
Walter Duggan Consolidated School	021 Room 114	MPP912	0.0012	Passed	0.0890	Passed	Remediation has been completed
Walter Duggan Consolidated School	022 Room 115	MPP913	0.0000	Passed	0.0890	Passed	Remediation has been completed
Walter Duggan Consolidated School	023 Room 117	MPP914	0.0008	Passed	0.0580	Passed	Remediation has been completed
Walter Duggan Consolidated School	024 Room 118	MPP915	0.0000	Passed	0.0690	Passed	Remediation has been completed
Walter Duggan Consolidated School	025 Room 113	MPP916	0.0015	Passed	0.1100	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
Walter Duggan Consolidated School	027 Room 136	NUO913	0.0000	Passed	0.0240	Passed	Remediation has been completed
Walter Duggan Consolidated School	028 Room 146	MPP919	0.0047	Passed	0.1300	Passed	Remediation has been completed
Walter Duggan Consolidated School	042 Bottle Filler by Gym	MPP920	0.0000	Passed	0.0250	Passed	Remediation has been completed
Walter Duggan Consolidated School	043 Bottle Filler Down Main Hall	MPP921	0.0000	Passed	0.0800	Passed	Remediation has been completed
Walter Duggan Consolidated School	044 Bottle Filler Up Main Hall	MPP922	0.0000	Passed	0.0860	Passed	Remediation has been completed
Walter Duggan Consolidated School	Boys Washroom Caf Sink A	NFE358	0.0000	Passed	0.0059	Passed	Remediation has been completed
Walter Duggan Consolidated School	Boys Washroom Caf Sink B	NFE359	0.0023	Passed	0.0071	Passed	Remediation has been completed
Walter Duggan Consolidated School	Girls Washroom Caf Sink A	NFE360	0.0000	Passed	0.0066	Passed	Remediation has been completed
Walter Duggan Consolidated School	Girls Washroom Caf Sink B	NFE361	0.0000	Passed	0.0031	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 106 Janitors Room Sink	NFE362	0.0000	Passed	0.0047	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 121 Girls Washroom Sink	NFE363	0.0000	Passed	0.0230	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 121 Boys Washroom Sink	NFE364	0.0000	Passed	0.0410	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 119 Washroom Sink	NFE365	0.0000	Passed	0.0270	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 147 Sink	NFE366	0.0000	Passed	0.0180	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Girls Washroom A	NFE368	0.0000	Passed	0.0270	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Girls Washroom B	NFE369	0.0000	Passed	0.0180	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Girls Washroom C	NFE370	0.0000	Passed	0.0160	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Boys Washroom A	NFE371	0.0000	Passed	0.0160	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Boys Washroom B	NFE372	0.0007	Passed	0.0210	Passed	Remediation has been completed
Walter Duggan Consolidated School	Downstairs Boys Washroom C	NFE373	0.0000	Passed	0.0170	Passed	Remediation has been completed
Walter Duggan Consolidated School	Room 202 Janitors Room Sink	NFE374	0.0000	Passed	0.0270	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Washroom Girls A	NFE375	0.0000	Passed	0.0200	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Washroom Girls B	NFE376	0.0000	Passed	0.0220	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Washroom Girls C	NFE377	0.0000	Passed	0.0190	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Boys Washroom A	NFE378	0.0000	Passed	0.0230	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Boys Washroom B	NFE379	0.0000	Passed	0.0170	Passed	Remediation has been completed
Walter Duggan Consolidated School	Upstairs Boys Washroom C	NFE380	0.0000	Passed	0.0170	Passed	Remediation has been completed
West Colchester Consolidated School	Staff Room Kitchen Sink T2	QCQ275	0.0037	Passed	0.0007	Passed	Remediation has been completed
West Colchester Consolidated School	Bottom Floor, F1	QCQ276	0.0000	Passed	0.0026	Passed	Remediation has been completed
West Colchester Consolidated School	Pre-Primary Kitchen Sink T6	QCQ277	0.0000	Passed	0.0026	Passed	Remediation has been completed
West Colchester Consolidated School	Fountain Outside Office, F3	QCQ278	0.0016	Passed	0.0160	Passed	Remediation has been completed
West Colchester Consolidated School	Kitchen Sink of Left T20	QSC020	0.0012	Passed	0.0008	Passed	Remediation has been completed
West Colchester Consolidated School	Kitchen Sink of Right T21	QSC021	0.0011	Passed	0.0006	Passed	Remediation has been completed
West Colchester Consolidated School	Laundry Sink in Home Ec T22	MOP101	0.0990	Exceeds Limit	0.6900	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Kitchen Sink on Right T23	QCQ281	0.0028	Passed	0.0027	Passed	Remediation has been completed
West Colchester Consolidated School	Kitchen Sink in Middle T24	QCQ282	0.0042	Passed	0.0037	Passed	Remediation has been completed
West Colchester Consolidated School	Kitchen Sink on Left T25	QCQ283	0.0043	Passed	0.0027	Passed	Remediation has been completed
West Colchester Consolidated School	Upstairs Fountain F2	QCQ284	0.0000	Passed	0.0025	Passed	Remediation has been completed
West Colchester Consolidated School	Bottle Filler Outside Office, F3	QCQ278	0.0016	Passed	0.0160	Passed	Remediation has been completed
West Colchester Consolidated School	Boiler Room Raw Water, T1A	NSS084	0.0000	Passed	0.0009	Passed	Remediation has been completed
West Colchester Consolidated School	Staff Washroom 1st, T3	NWL786	0.0190	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Staff Washroom 2nd, T4	NWL802	0.0110	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Hall Washroom by Pre-Primary, T5	NWL803	0.0061	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Boys Washroom Right, T7	NWL804	0.0049	Passed	0.9400	Passed	Remediation has been completed
West Colchester Consolidated School	Boys Washroom Middle Right, T8	NWL805	0.0034	Passed	0.9600	Passed	Remediation has been completed
West Colchester Consolidated School	Boys Washroom Middle Left, T9	NWL806	0.0030	Passed	0.9100	Passed	Remediation has been completed
West Colchester Consolidated School	Boys Washroom Left, T10	NWL807	0.0027	Passed	0.7700	Passed	Remediation has been completed
West Colchester Consolidated School	Girls Washroom Right, T11	NWL808	0.0300	Exceeds Limit	0.7800	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Girls Washroom Middle Right, T12	NWL809	0.0310	Exceeds Limit	0.6500	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Girls Washroom Middle Left, T13	NWL810	0.0450	Exceeds Limit	0.7600	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Custodial Room by Staff Room, T1	NWL811	0.1300	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Girls Washroom Left, T14	NWL812	0.0370	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Custodial Room by Room 12, T15	NWL813	0.1700	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Science Lab, Back Counter Work, T19	NWL814	0.6500	Exceeds Limit	0.0420	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Custodial Room in Boys Locker, T26	NWL815	0.2100	Exceeds Limit	1.0000	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Boys Locker, T27	NWL816	0.0380	Exceeds Limit	0.2700	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Girls Locker, T28	NWL817	0.0480	Exceeds Limit	0.5100	Passed	Signage to be added to instruct handwashing only
West Colchester Consolidated School	Woodshop, T29	NWL818	0.0071	Exceeds Limit	0.1600	Passed	Signage to be added to instruct handwashing only
West End Memorial School	Upper Bottle Filler	PJY821	0.0030	Passed	0.1500	Passed	Remediation has been completed
West End Memorial School	Boiler Room #2	LLP088	0.0006	Passed	0.1200	Passed	Remediation has been completed
West End Memorial School	Pre Primary Sink	LET809	0.0038	Passed	0.2700	Passed	Remediation has been completed
West End Memorial School	Staff Room Sink	LLP089	0.0078	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
West End Memorial School	Classroom #1 Sink	LET813	0.0010	Passed	0.3000	Passed	Remediation has been completed
West End Memorial School	Bottle Filler in Lower End	PJY820	0.0011	Passed	0.7300	Passed	Remediation has been completed
West End Memorial School	Class #3 Sink Tap	LLP090	0.0009	Passed	0.0150	Passed	Remediation has been completed
West End Memorial School	Class #2 Sink Tap	LLP091	0.0000	Passed	0.0002	Passed	Remediation has been completed
West End Memorial School	Girls #1	NEF090	0.0000	Passed	0.0370	Passed	Remediation has been completed
West End Memorial School	Girls #2	NEF091	0.0000	Passed	0.0450	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
West End Memorial School	Custodial by Staff Room	NEF092	0.0000	Passed	0.0530	Passed	Remediation has been completed
West End Memorial School	Boys #1	NEF093	0.0000	Passed	0.1400	Passed	Remediation has been completed
West End Memorial School	Boys #2	NEF094	0.0000	Passed	0.1300	Passed	Remediation has been completed
West End Memorial School	Boys #3	NEF095	0.0000	Passed	0.0800	Passed	Remediation has been completed
West End Memorial School	Staff Room	NEF096	0.0000	Passed	0.1100	Passed	Remediation has been completed
West End Memorial School	Custodial in Lower End	NEF097	0.0000	Passed	0.0210	Passed	Remediation has been completed
West End Memorial School	Staff in Lower End	NEF098	0.0000	Passed	0.0230	Passed	Remediation has been completed
West Highlands Elementary School	Boiler Room	MTG944	0.0038	Passed	0.9100	Passed	Remediation has been completed
West Highlands Elementary School	Cafeteria #1	MTG945	0.0009	Passed	0.8900	Passed	Remediation has been completed
West Highlands Elementary School	Cafeteria #2	MTG946	0.0006	Passed	0.1700	Passed	Remediation has been completed
West Highlands Elementary School	Cafeteria #3	MTG947	0.0016	Passed	0.7300	Passed	Remediation has been completed
West Highlands Elementary School	Breakfast Program Room	MTG948	0.0006	Passed	0.5900	Passed	Remediation has been completed
West Highlands Elementary School	Bottle Filler by Gym	MTG949	0.0031	Passed	0.4500	Passed	Remediation has been completed
West Highlands Elementary School	Music Room	MTG950	0.0014	Passed	1.4000	Passed	Remediation has been completed
West Highlands Elementary School	Bottle Filler Replaced Bottle Filler Lower Hall	OYC003	0.0000	Passed	0.7400	Passed	Remediation has been completed
West Highlands Elementary School	Learning Centre	MTG952	0.0005	Passed	0.5300	Passed	Remediation has been completed
West Highlands Elementary School	Room 116	MTG953	0.0010	Passed	0.5500	Passed	Remediation has been completed
West Highlands Elementary School	Room 124	MTG954	0.0000	Passed	0.5600	Passed	Remediation has been completed
West Highlands Elementary School	Room 121	MTG955	0.0000	Passed	0.6600	Passed	Remediation has been completed
West Highlands Elementary School	Room 118	MTG956	0.0000	Passed	0.5000	Passed	Remediation has been completed
West Highlands Elementary School	Mechanical Room	MTG957	0.0000	Passed	0.0600	Passed	Remediation has been completed
West Highlands Elementary School	Staff Room	MTG958	0.0000	Passed	0.4800	Passed	Remediation has been completed
West Highlands Elementary School	Bottle Filler Upper Hall	MTG959	0.0005	Passed	0.3700	Passed	Remediation has been completed
West Highlands Elementary School	Visual Art #1	MTG960	0.0000	Passed	0.1400	Passed	Remediation has been completed
West Highlands Elementary School	Visual Art #2	MTG961	0.0008	Passed	0.1700	Passed	Remediation has been completed
West Highlands Elementary School	Room 215	MTG962	0.0000	Passed	0.6000	Passed	Remediation has been completed
West Pictou Consolidated School	Room 109 Custodial Closet Sink	NGT250	0.0280	Exceeds Limit	0.0970	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Room 147 Custodial Closet Sink	NGT251	0.1200	Exceeds Limit	0.5100	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Room 219 Custodial Closet Sink A	NGT252	0.0120	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Room 219 Custodial Closet Sink B	NGT253	0.0800	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Boys Washroom Sink A	NGT254	0.0110	Exceeds Limit	0.0690	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Boys Washroom Sink B	NGT255	0.0090	Exceeds Limit	0.0320	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Boys Washroom Sink C	NGT256	0.0140	Exceeds Limit	0.1400	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Boys Washroom Sink D	NGT257	0.0190	Exceeds Limit	0.4700	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Girls Washroom Sink A	NGT258	0.0580	Exceeds Limit	0.5000	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Girls Washroom Sink B	NGT259	0.0110	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Girls Washroom Sink C	NGT260	0.0090	Exceeds Limit	0.0690	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Main Hall Girls Washroom Sink D	NGT261	0.0130	Exceeds Limit	0.1900	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Gym Locker Room Boys Sink	NGT262	0.0400	Exceeds Limit	0.0520	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Gym Locker Room Girls Sink	NGT263	0.0081	Exceeds Limit	0.0760	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Primary End Boys Washroom Sink	NGT264	0.0088	Exceeds Limit	0.0570	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Primary End Girls Washroom Sink	NGT265	0.0180	Exceeds Limit	0.4000	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Room 161 Learning Centre Washroom Sink	NGT266	0.0130	Exceeds Limit	0.5300	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Boys Washroom Sink A	NGT267	0.0170	Exceeds Limit	0.1200	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Boys Washroom Sink B	NGT268	0.0110	Exceeds Limit	0.0910	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Boys Washroom Sink C	NGT269	0.0140	Exceeds Limit	0.1000	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Boys Washroom Sink D	NGT270	0.0270	Exceeds Limit	0.4400	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Girls Washroom Sink A	NGT271	0.0110	Exceeds Limit	0.1700	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Girls Washroom Sink B	NGT272	0.0110	Exceeds Limit	0.0580	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Girls Washroom Sink C	NGT273	0.0100	Exceeds Limit	0.0960	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	2nd Floor Girls Washroom Sink D	NGT274	0.0063	Exceeds Limit	0.1100	Passed	Signage to be added to instruct handwashing only
West Pictou Consolidated School	Room 117 Art Supply Room	LEK430	0.0052	Passed	0.0070	Passed	Remediation has been completed
West Pictou Consolidated School	Room 119 Learning Common	LEK431	0.0031	Passed	0.0880	Passed	Remediation has been completed
West Pictou Consolidated School	Room 120 Tech Ed	ODH568	0.0049	Passed	0.0020	Passed	Remediation has been completed
West Pictou Consolidated School	Room 122 Classroom Sink	LEK433	0.0008	Passed	0.0140	Passed	Remediation has been completed
West Pictou Consolidated School	Room 142 Cafeteria Sink	LEK434	0.0008	Passed	0.0590	Passed	Remediation has been completed
West Pictou Consolidated School	Room 143 Kitchen Sink A	LEK435	0.0007	Passed	0.0086	Passed	Remediation has been completed
West Pictou Consolidated School	Room 143 Kitchen Sink B	LEK436	0.0015	Passed	0.0760	Passed	Remediation has been completed
West Pictou Consolidated School	Room 143 Kitchen Sink C	LEK437	0.0000	Passed	0.0420	Passed	Remediation has been completed
West Pictou Consolidated School	Room 143 Kitchen Sink C - Hand Sprayer	LEK438	0.0008	Passed	0.0120	Passed	Remediation has been completed
West Pictou Consolidated School	Room 143 Kitchen Sink D- Handwashing Sink	LEK439	0.0011	Passed	0.0140	Passed	Remediation has been completed
West Pictou Consolidated School	Room 150 Classroom Sink	LEK472	0.0049	Passed	0.0040	Passed	Remediation has been completed
West Pictou Consolidated School	Room 151 Classroom Sink	LEK473	0.0011	Passed	0.0170	Passed	Remediation has been completed
West Pictou Consolidated School	Room 156 Music Room	LEK474	0.0040	Passed	0.0170	Passed	Remediation has been completed
West Pictou Consolidated School	1st Floor Hallway - New Fountain	LEK475	0.0000	Passed	0.0044	Passed	Remediation has been completed
West Pictou Consolidated School	Room 163 Learning Centre Sink	LEK476	0.0006	Passed	0.0360	Passed	Remediation has been completed
West Pictou Consolidated School	Room 169 Staff Room Sink	LEK477	0.0005	Passed	0.0280	Passed	Remediation has been completed

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Next Steps
To be updated as work progresses. All schools have clean drinkable bottled water available.							
West Pictou Consolidated School	1st Floor Hallway - Fountain by main entry	LEK478	0.0000	Passed	0.0038	Passed	Remediation has been completed
West Pictou Consolidated School	Room 215 Classroom Sink	LEK479	0.0000	Passed	0.0027	Passed	Remediation has been completed
West Pictou Consolidated School	2nd Floor Hallway Fountain	LEK480	0.0001	Passed	0.0068	Passed	Remediation has been completed
West Pictou Consolidated School	Room 207 Sink A	LEK481	0.0005	Passed	0.0045	Passed	Remediation has been completed
West Pictou Consolidated School	Room 207 Sink B	LEK487	0.0000	Passed	0.0150	Passed	Remediation has been completed
West Pictou Consolidated School	Room 207 Sink C	LEK488	0.0018	Passed	0.0093	Passed	Remediation has been completed
West Pictou Consolidated School	Room 227 Classroom Sink	LEK489	0.0012	Passed	0.0180	Passed	Remediation has been completed
West Pictou Consolidated School	Room 225 Classroom Sink	LEK490	0.0000	Passed	0.0022	Passed	Remediation has been completed
West Pictou Consolidated School	Pump Room - Boiler Room Sink	LEK491	0.0021	Passed	0.0220	Passed	Remediation has been completed
Winding River Consolidated School	Library Room 106, Kitchen, Tap-T1	MSW778	0.0044	Passed	0.4900	Passed	Remediation has been completed
Winding River Consolidated School	Bottle Filler Across from Library, F1	MSW779	0.0000	Passed	0.1800	Passed	Remediation has been completed
Winding River Consolidated School	Staff Room 161 Kitchen, Tap, T13	MSW780	0.0008	Passed	0.4000	Passed	Remediation has been completed
Winding River Consolidated School	Learning Centre Room 162, Kitchen Tap, T15	MSW781	0.0013	Passed	0.5600	Passed	Remediation has been completed
Winding River Consolidated School	Visual Arts Room 154 Tap on Right, T42	MSW782	0.0055	Exceeds Limit	0.2000	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Visual Arts Room 154 Tap on Right, T41	MSW783	0.0061	Exceeds Limit	0.2400	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Bottle Filler by Recycle Room, F3	MSW784	0.0000	Passed	0.2300	Passed	Remediation has been completed
Winding River Consolidated School	Recycle Room, 133, T33	MSW785	0.0012	Passed	0.4500	Passed	Remediation has been completed
Winding River Consolidated School	Main Kitchen Tap, T39	MSW786	0.0009	Passed	0.2200	Passed	Remediation has been completed
Winding River Consolidated School	Bottle Filler by Reading Recovery Room, F2	MSW787	0.0008	Passed	0.3100	Passed	Remediation has been completed
Winding River Consolidated School	Room 188, Kitchen Tap, T25	MSW788	0.0030	Passed	0.2900	Passed	Remediation has been completed
Winding River Consolidated School	Room 185 Kitchen Tap, T28	MSW789	0.0018	Passed	0.2500	Passed	Remediation has been completed
Winding River Consolidated School	Room 175, Kitchen Tap, T23	MSW790	0.0032	Passed	0.7000	Passed	Remediation has been completed
Winding River Consolidated School	Room 177, Kitchen Tap, T24	MSW791	0.0018	Passed	0.5400	Passed	Remediation has been completed
Winding River Consolidated School	Room 184, Kitchen Tap, T29	MSW792	0.0016	Passed	0.4000	Passed	Remediation has been completed
Winding River Consolidated School	Room 182, Kitchen Tap, T30	MSW793	0.0025	Passed	0.3700	Passed	Remediation has been completed
Winding River Consolidated School	Room 178, Kitchen Tap, T31	MSW794	0.0020	Passed	0.5400	Passed	Remediation has been completed
Winding River Consolidated School	Room 180, Kitchen Tap, T32	QSB841	0.0015	Passed	0.0390	Passed	Remediation has been completed
Winding River Consolidated School	Music Room 150, T2	NHI331	0.0037	Passed	0.8800	Passed	Remediation has been completed
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Lft Tap, T3	NHI332	0.0065	Exceeds Limit	0.7100	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Mid Tap, T4	NHI333	0.0035	Passed	0.5200	Passed	Remediation has been completed
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Rgt Tap, T5	NHI334	0.0032	Passed	0.5600	Passed	Remediation has been completed
Winding River Consolidated School	Custodial Room Across from Library Cust Fir Sink, T6	NHI335	0.0014	Passed	0.1100	Passed	Remediation has been completed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps), Lft Tap, T7	NHI336	0.0026	Passed	0.5200	Passed	Remediation has been completed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps), 2nd Lft Tap, T8	NHI337	0.0041	Passed	1.0000	Passed	Remediation has been completed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps) 3rd Lft Tap, T9	NHI338	0.0058	Exceeds Limit	0.6700	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps) 4th Lft Tap, T10	NHI339	0.0057	Exceeds Limit	0.9300	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Staff Female Washroom in Staff Room (Push on Taps), T11	NHI340	0.0021	Passed	0.6500	Passed	Remediation has been completed
Winding River Consolidated School	Staff Male Washroom in Staff Room, T12	NHI341	0.0045	Passed	0.9200	Passed	Remediation has been completed
Winding River Consolidated School	Everyone Washroom By Learning Centre 162, T14	NHI342	0.0013	Passed	0.6400	Passed	Remediation has been completed
Winding River Consolidated School	Main Office Washroom (Push on Tap), T16	NHI343	0.0027	Passed	0.8600	Passed	Remediation has been completed
Winding River Consolidated School	Boys Washroom Across from Main Office (Push on Tap) Left Tap, T17	NHI344	0.0052	Passed	0.4800	Passed	Remediation has been completed
Winding River Consolidated School	Boys Washroom Across From Main Office (Push on Tap) Mid Tap, T18	NHI345	0.0036	Passed	0.4800	Passed	Remediation has been completed
Winding River Consolidated School	Boys Washroom Across From Main Office (Push on Tap) Rgt Tap, T19	NHI346	0.0034	Passed	0.4000	Passed	Remediation has been completed
Winding River Consolidated School	Custodian Room Across from Custodial Floor Sink, T20	NHI347	0.0015	Passed	0.7300	Passed	Remediation has been completed
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Lft Tap, T21	NHI348	0.0130	Exceeds Limit	0.7400	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Lft Tap, T22	NHI349	0.0029	Passed	0.5100	Passed	Remediation has been completed
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Rgt Tap, T22A	NHI350	0.0031	Passed	0.4300	Passed	Remediation has been completed
Winding River Consolidated School	Classroom 188 Washroom (Push on Tap), T26	NHI351	0.0067	Exceeds Limit	1.3000	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Classroom 185 Washroom (Push on Tap), T27	NHI352	0.0040	Passed	0.8600	Passed	Remediation has been completed
Winding River Consolidated School	Boys Change Room (Push on Taps), Lft Tap, T34	NHI353	0.0054	Passed	1.7000	Passed	Faucet to be decommissioned, remediated, and retested. Other sources available
Winding River Consolidated School	Boys Change Room (Push on Taps), Rgt Tap, T35	NHI354	0.0076	Exceeds Limit	0.8400	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Gym Office Washroom, T36	NHI355	0.0070	Exceeds Limit	0.9300	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Girls Change Room (Push on Taps), Lft Tap, T37	NHI356	0.0060	Exceeds Limit	0.6100	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Girls Change Room (Push on Taps), Rgt Tap, T38	NHI357	0.0057	Exceeds Limit	0.5100	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Kitchen 135 Main Sink Handwash Sink, T40	NHI358	0.0032	Passed	0.7600	Passed	Remediation has been completed
Winding River Consolidated School	Boiler Room 155, T43	NHI359	0.0040	Passed	2.5000	Exceeds Limit	Signage to be added to instruct handwashing only
Winding River Consolidated School	Kitchen Cust Floor Sink	NHI360	0.0230	Exceeds Limit	0.4100	Passed	Signage to be added to instruct handwashing only
Winding River Consolidated School	Room 129 Sick Room Kitchen Sink (New), T99	QSB840	0.0000	Passed	0.0072	Passed	Remediation has been completed